

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381602729
 CustomerID: PGCS62
 CustomerPO:
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 03/24/16 10:50 AM
 Analysis Date: 3/24/2016
 Collected: 3/18/2016

Project: **Berwyn Heights**

Test Site: **Berwyn Heights**
College Park, MD 20740

Test Report: Radon in Air Test Results**Samples for EMSL Kit 141844**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239370	Main Office	0.9	3/18/2016	3/21/2016	70	50	Customer
381602729-0001			5:30:00 PM	9:37:00 AM			

Sample Notes:

Samples for EMSL Kit 141848

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
240787	Room 118	1.4	3/18/2016	3/21/2016	70	50	Customer
381602729-0002			5:32:00 PM	9:39:00 AM			

Sample Notes:

239584	Room 118	0.1	3/18/2016	3/21/2016	70	50	Duplicate
381602729-0003			5:32:00 PM	9:39:00 AM			

Sample Notes:

Duplicate RPD = 173.3%

Samples for EMSL Kit 141840

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239380	114 Media Center	0.8	3/18/2016	3/21/2016	70	50	Customer
381602729-0004			5:34:00 PM	9:41:00 AM			

Sample Notes:

Samples for EMSL Kit 141836

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239574	Room 126	0.5	3/18/2016	3/21/2016	70	50	Customer
381602729-0005			5:35:00 PM	9:42:00 AM			

Sample Notes:

Samples for EMSL Kit 142194

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239718	Room 127	0.8	3/18/2016	3/21/2016	70	50	Customer
381602729-0006			5:37:00 PM	9:43:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381602729
 CustomerID: PGCS62
 CustomerPO:
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 03/24/16 10:50 AM
 Analysis Date: 3/24/2016
 Collected: 3/18/2016

Project: **Berwyn Heights**

Test Site: **Berwyn Heights**
College Park, MD 20740

Test Report: Radon in Air Test Results**Samples for EMSL Kit 141839**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239381	Room 130	1	3/18/2016	3/21/2016	70	50	Customer
381602729-0007			5:38:00 PM	9:44:00 AM			

Sample Notes:

Samples for EMSL Kit 142200

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239658	Room 131	1.6	3/18/2016	3/21/2016	70	50	Customer
381602729-0008			5:40:00 PM	9:45:00 AM			

Sample Notes:

Samples for EMSL Kit 141847

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
240808	Room 134	1	3/18/2016	3/21/2016	70	50	Customer
381602729-0009			5:41:00 PM	9:47:00 AM			

Sample Notes:

Samples for EMSL Kit 141849

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
240801	Room 137	1.1	3/18/2016	3/21/2016	70	50	Customer
381602729-0010			5:43:00 PM	9:48:00 AM			

Sample Notes:

Samples for EMSL Kit 141838

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239362	Room 138	1.7	3/18/2016	3/21/2016	70	50	Customer
381602729-0011			5:45:00 PM	9:49:00 AM			

Sample Notes:

239597	Room 138	1.7	3/18/2016	3/21/2016	70	50	Duplicate
381602729-0012			5:45:00 PM	9:49:00 AM			

Sample Notes:

Duplicate RPD = 0%

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381602729
 CustomerID: PGCS62
 CustomerPO:
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 03/24/16 10:50 AM
 Analysis Date: 3/24/2016
 Collected: 3/18/2016

Project: **Berwyn Heights**

Test Site: **Berwyn Heights**
College Park, MD 20740

Test Report: Radon in Air Test Results**Samples for EMSL Kit 141835**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239416	Room 147	1.1	3/18/2016	3/21/2016	70	50	Customer
381602729-0013			5:47:00 PM	9:50:00 AM			

Sample Notes:

239589	Room 147	0.1	3/18/2016	3/21/2016	70	50	Blank
381602729-0014			5:47:00 PM	9:50:00 AM			

Sample Notes:**Samples for EMSL Kit 141837**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239596	Room 150	1.4	3/18/2016	3/21/2016	70	50	Customer
381602729-0015			5:50:00 PM	9:51:00 AM			

Sample Notes:

The radon test was performed using a liquid scintillation radon detector/s and counted on a liquid scintillation counter using approved EPA testing protocols for Radon in Air testing. The EPA recommends fixing your home if the average of two short-term tests taken in the lowest lived-in level of the home show radon levels that are equal to or greater than 4.0pCi/L. The EPA recommends retesting your home every two years.

Please contact EMSL Analytical, Inc. or your State Health Department for further information.

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of Radon in Air.

Report Note

Analyst(s)

Kathryn Lickfield (15)

Laura Freeman *Subash Rashat*

Laura Freeman, Interim Laboratory Manager &
 Subash Rashat, New Jersey Radiation Specialist NJ MES 10152
 or other approved signatory

In no event shall EMSL be liable for indirect, special, consequential, or incidental damages, including, but not limited to, damages for loss of profit or goodwill regardless of the negligence (either sole or concurrent) of EMSL and whether EMSL has been informed of the possibility of such damages, arising out of or in connection with EMSL's services thereunder or the delivery, use, reliance upon or interpretation of test results by client or any third party. We accept no legal responsibility for the purposes for which the client uses the test results. In no event shall EMSL be liable to a client or any third party, whether based upon theories of tort, contract or any other legal or equitable theory, in excess of the amount paid to EMSL by client thereunder. The test results meets all NELAC requirements unless otherwise specified. Accreditations: NRSB ARL6006, NJ DEP 03036, MEB 92525, PA 2573, IN 00455, IA L00032, RI RAS-024, ME 20200C, NE RMB-1083, NY ELAP 10872, NM 885-10L, FL RB2034, OH RL-39, NRPP #106178AL, KS-LB-0005

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ Accreditations: NRSB ARL6006, NJ DEP 03036, MEB 92525, PA 2573, IN 00455, IA L00032, RI RAS-024, ME 20200C, NE RMB-1083, NY ELAP 10872, NM 885-10L, FL RB2034, OH RL-39, NRPP #106178AL, KS-LB-0005. Subash Rashat certification #MES10152

Initial report from 04/01/2016 09:22:49

Please visit www.radontestinglab.com