

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381601786
 CustomerID: PGCS62
 CustomerPO: 608048
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 03/01/16 11:41 AM
 Analysis Date: 3/3/2016
 Collected: 2/26/2016

Project: **Gaywood ES**

Test Site: **Gaywood ES**
Seabrook, MD 20706

Test Report: Radon in Air Test Results**Samples for EMSL Kit 139099**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
234462	Main Office	0.1	2/26/2016	2/29/2016	70	50	Customer
381601786-0001			2:00:00 PM	7:00:00 AM			

Sample Notes:

Samples for EMSL Kit 139124

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
234590	Room 2	0.1	2/26/2016	2/29/2016	70	50	Customer
381601786-0002			2:03:00 PM	7:03:00 AM			

Sample Notes:

Samples for EMSL Kit 139023

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
234864	Room 6	0.1	2/26/2016	2/29/2016	70	50	Customer
381601786-0003			2:05:00 PM	7:07:00 AM			

Sample Notes:

Samples for EMSL Kit 139025

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
234655	Room 5	0.1	2/26/2016	2/29/2016	70	50	Customer
381601786-0004			2:08:00 PM	7:09:00 AM			

Sample Notes:

232380	Room 5	-0.1	2/26/2016	2/29/2016	70	50	Blank
381601786-0005			2:08:00 PM	7:09:00 AM			

Sample Notes:

Samples for EMSL Kit 139024

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
234711	Room 1	0.1	2/26/2016	2/29/2016	70	50	Customer
381601786-0006			2:11:00 PM	7:12:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381601786
 CustomerID: PGCS62
 CustomerPO: 608048
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 03/01/16 11:41 AM
 Analysis Date: 3/3/2016
 Collected: 2/26/2016

Project: **Gaywood ES**

Test Site: **Gaywood ES**
Seabrook, MD 20706

Test Report: Radon in Air Test Results**Samples for EMSL Kit 140170**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
237045	Room 18	0.3	2/26/2016	2/29/2016	70	50	Customer
381601786-0007			2:15:00 PM	7:14:00 AM			

Sample Notes:

Samples for EMSL Kit 139096

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
234458	Room 20	0.4	2/26/2016	2/29/2016	70	50	Customer
381601786-0008			2:17:00 PM	7:17:00 AM			

Sample Notes:

Samples for EMSL Kit 140179

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
236991	Room 24	0.1	2/26/2016	2/29/2016	70	50	Customer
381601786-0009			2:19:00 PM	7:20:00 AM			

Sample Notes:

Samples for EMSL Kit 139112

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
234602	Text Book Storage	0.4	2/26/2016	2/29/2016	70	50	Customer
381601786-0010			2:21:00 PM	7:23:00 AM			

Sample Notes:

234440	Text Book Storage	0.4	2/26/2016	2/29/2016	70	50	Duplicate
381601786-0011			2:21:00 PM	7:23:00 AM			

Sample Notes:

Duplicate RPD = 0%

Samples for EMSL Kit 139020

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
234783	Room 25	0.2	2/26/2016	2/29/2016	70	50	Customer
381601786-0012			2:24:00 PM	7:26:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381601786
 CustomerID: PGCS62
 CustomerPO: 608048
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 03/01/16 11:41 AM
 Analysis Date: 3/3/2016
 Collected: 2/26/2016

Project: **Gaywood ES**

Test Site: **Gaywood ES**
Seabrook, MD 20706

Test Report: Radon in Air Test Results**Samples for EMSL Kit 140135**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
237069	Room 21	0.4	2/26/2016	2/29/2016	70	50	Customer
381601786-0013			2:27:00 PM	7:28:00 AM			

Sample Notes:

234008	Room 21	0	2/26/2016	2/29/2016	70	50	Blank
381601786-0014			2:27:00 PM	7:28:00 AM			

Sample Notes:**Samples for EMSL Kit 140149**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
237060	Room 17	0.2	2/26/2016	2/29/2016	70	50	Customer
381601786-0015			2:30:00 PM	7:30:00 AM			

Sample Notes:**Samples for EMSL Kit 140133**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
237061	Room 9	0.1	2/26/2016	2/29/2016	70	50	Customer
381601786-0016			2:32:00 PM	7:33:00 AM			

Sample Notes:**Samples for EMSL Kit 140150**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
237020	Room 11	0.1	2/26/2016	2/29/2016	70	50	Customer
381601786-0017			2:34:00 PM	7:37:00 AM			

Sample Notes:**Samples for EMSL Kit 140146**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
237081	Room 13	0.2	2/26/2016	2/29/2016	70	50	Customer
381601786-0018			2:36:00 PM	7:40:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (800) 220-3675 / (856) 786-0327

<http://www.EMSL.com>cinnaminsonradonlab@emsl.com

EMSL Order: 381601786

CustomerID: PGCS62

CustomerPO: 608048

ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 03/01/16 11:41 AM
 Analysis Date: 3/3/2016
 Collected: 2/26/2016

Project: **Gaywood ES**

Test Site: **Gaywood ES**
Seabrook, MD 20706

Test Report: Radon in Air Test Results**Samples for EMSL Kit 140136**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
237087	Room 15	0.1	2/26/2016	2/29/2016	70	50	Customer
381601786-0019			2:38:00 PM	7:42:00 AM			

Sample Notes:**Samples for EMSL Kit 140178**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
237053	Room 12	0.1	2/26/2016	2/29/2016	70	50	Customer
381601786-0020			2:40:00 PM	7:44:00 AM			

Sample Notes:

237183	Room 12	0.1	2/26/2016	2/29/2016	70	50	Duplicate
381601786-0021			2:40:00 PM	7:44:00 AM			

Sample Notes:**Duplicate RPD = 0%****Samples for EMSL Kit 140180**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
237022	Room 10	0.1	2/26/2016	2/29/2016	70	50	Customer
381601786-0022			2:43:00 PM	7:46:00 AM			

Sample Notes:**Samples for EMSL Kit 140168**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
236977	Stage	0.2	2/26/2016	2/29/2016	70	50	Customer
381601786-0023			2:45:00 PM	7:48:00 AM			

Sample Notes:

237121	Stage	0.2	2/26/2016	2/29/2016	70	50	Duplicate
381601786-0024			2:45:00 PM	7:48:00 AM			

Sample Notes:**Duplicate RPD = 0%**



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (800) 220-3675 / (856) 786-0327

<http://www.EMSL.com>

cinnaminsonradonlab@emsl.com

EMSL Order:	381601786
CustomerID:	PGCS62
CustomerPO:	608048
ProjectID:	

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 03/01/16 11:41 AM
 Analysis Date: 3/3/2016
 Collected: 2/26/2016

Project: **Gaywood ES**

Test Site: **Gaywood ES**
Seabrook, MD 20706

Test Report: Radon in Air Test Results

The radon test was performed using a liquid scintillation radon detector/s and counted on a liquid scintillation counter using approved EPA testing protocols for Radon in Air testing. The EPA recommends fixing your home if the average of two short-term tests taken in the lowest lived-in level of the home show radon levels that are equal to or greater than 4.0pCi/L. The EPA recommends retesting your home every two years.

Please contact EMSL Analytical, Inc. or your State Health Department for further information.

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of Radon in Air.

Report Note

Analyst(s)

Tiffanie Cosgrove (24)




Laura Freeman, Interim Laboratory Manager &
 Subash Rashat, New Jersey Radiation Specialist NJ MES 10152
 or other approved signatory

In no event shall EMSL be liable for indirect, special, consequential, or incidental damages, including, but not limited to, damages for loss of profit or goodwill regardless of the negligence (either sole or concurrent) of EMSL and whether EMSL has been informed of the possibility of such damages, arising out of or in connection with EMSL's services thereunder or the delivery, use, reliance upon or interpretation of test results by client or any third party. We accept no legal responsibility for the purposes for which the client uses the test results. In no event shall EMSL be liable to a client or any third party, whether based upon theories of tort, contract or any other legal or equitable theory, in excess of the amount paid to EMSL by client thereunder. The test results meets all NELAC requirements unless otherwise specified. Accreditations: NRSB ARL6006, NJ DEP 03036, MEB 92525, PA 2573, IN 00455, IA L00032, RI RAS-024, ME 20200C, NE RMB-1083, NY ELAP 10872, NM 885-10L, FL RB2034, OH RL-39, NRPP #106178AL, KS-LB-0005

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ Accreditations: NRSB ARL6006, NJ DEP 03036, MEB 92525, PA 2573, IN 00455, IA L00032, RI RAS-024, ME 20200C, NE RMB-1083, NY ELAP 10872, NM 885-10L, FL RB2034, OH RL-39, NRPP #106178AL, KS-LB-0005. Subash Rashat certification #MES10152

Report Amended: 03/10/2016 12:05:52 Replaces the Inital Report 03/10/2016 12:03:42. Reason Code: Data Entry-Change to kit number

Please visit www.radontestinglab.com