

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381602712
 CustomerID: PGCS62
 CustomerPO:
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 03/24/16 10:50 AM
 Analysis Date: 3/25/2016
 Collected: 3/18/2016

Project: **Samuel Chase**

Test Site: **Samuel Chase**
Temple Hills, MD 20748

Test Report: Radon in Air Test Results**Samples for EMSL Kit 140599**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
	Main Office		3/18/2016	3/21/2016	70	50	Customer
381602712-0001			3:22:00 PM	8:47:00 AM			

Sample Notes: Not Analyzed
 Not Received

Samples for EMSL Kit 140576

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239313	Rm 24	-0.1	3/18/2016	3/21/2016	70	50	Customer
381602712-0002			3:25:00 PM	8:48:00 AM			

Sample Notes:

Samples for EMSL Kit 141733

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239458	Rm 12	0.1	3/18/2016	3/21/2016	70	50	Customer
381602712-0003			3:25:00 PM	8:48:00 AM			

Sample Notes:

Samples for EMSL Kit 140574

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239154	Rm 14	-0.1	3/18/2016	3/21/2016	70	50	Customer
381602712-0004			3:26:00 PM	8:49:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381602712
 CustomerID: PGCS62
 CustomerPO:
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 03/24/16 10:50 AM
 Analysis Date: 3/25/2016
 Collected: 3/18/2016

Project: **Samuel Chase**

Test Site: **Samuel Chase**
Temple Hills, MD 20748

Test Report: Radon in Air Test Results**Samples for EMSL Kit 140592**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239167	Rm 22	-0.2	3/18/2016	3/21/2016	70	50	Customer
381602712-0005			3:26:00 PM	8:49:00 AM			

Sample Notes:

238718	Rm 22	-0.1	3/18/2016	3/21/2016	70	50	Duplicate
381602712-0006			3:26:00 PM	8:49:00 AM			

Sample Notes:**Duplicate RPD = 0%****Samples for EMSL Kit 140583**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239189	Media Center	0	3/18/2016	3/21/2016	70	50	Customer
381602712-0007			3:28:00 PM	8:51:00 AM			

Sample Notes:**Samples for EMSL Kit 140591**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239169	Rm 102	0	3/18/2016	3/21/2016	70	50	Customer
381602712-0008			3:30:00 PM	8:52:00 AM			

Sample Notes:**Samples for EMSL Kit 140577**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
238773	Rm 101	0.2	3/18/2016	3/21/2016	70	50	Customer
381602712-0009			3:32:00 PM	8:53:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381602712
 CustomerID: PGCS62
 CustomerPO:
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 03/24/16 10:50 AM
 Analysis Date: 3/25/2016
 Collected: 3/18/2016

Project: **Samuel Chase**

Test Site: **Samuel Chase**
Temple Hills, MD 20748

Test Report: Radon in Air Test Results**Samples for EMSL Kit 140598**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239137	Rm 106	-0.1	3/18/2016	3/21/2016	70	50	Customer
381602712-0010			3:32:00 PM	8:54:00 AM			

Sample Notes:

239179	Rm 106	0	3/18/2016	3/21/2016	70	50	Duplicate
381602712-0011			3:32:00 PM	8:54:00 AM			

Sample Notes:**Duplicate RPD = 0%****Samples for EMSL Kit 140585**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239066	Rm 107	0	3/18/2016	3/21/2016	70	50	Customer
381602712-0012			3:33:00 PM	8:57:00 AM			

Sample Notes:

238731	Rm 107	-0.2	3/18/2016	3/21/2016	70	50	Blank
381602712-0013			3:33:00 PM	8:57:00 AM			

Sample Notes:**Samples for EMSL Kit 140586**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239221	Rm 112	0.3	3/18/2016	3/21/2016	70	50	Customer
381602712-0014			3:35:00 PM	8:57:00 AM			

Sample Notes:**Samples for EMSL Kit 140617**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239238	Rm 113	0.3	3/18/2016	3/21/2016	70	50	Customer
381602712-0015			3:35:00 PM	8:57:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (800) 220-3675 / (856) 786-0327

<http://www.EMSL.com>cinnaminsonradonlab@emsl.com

EMSL Order: 381602712

CustomerID: PGCS62

CustomerPO:

ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 03/24/16 10:50 AM
 Analysis Date: 3/25/2016
 Collected: 3/18/2016

Project: **Samuel Chase**

Test Site: **Samuel Chase**
Temple Hills, MD 20748

Test Report: Radon in Air Test Results

The radon test was performed using a liquid scintillation radon detector/s and counted on a liquid scintillation counter using approved EPA testing protocols for Radon in Air testing. The EPA recommends fixing your home if the average of two short-term tests taken in the lowest lived-in level of the home show radon levels that are equal to or greater than 4.0pCi/L. The EPA recommends retesting your home every two years.

Please contact EMSL Analytical, Inc. or your State Health Department for further information.

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of Radon in Air.

Report Note

Analyst(s)

Tiffanie Cosgrove (14)

Laura Freeman, Interim Laboratory Manager &
 Subash Rashat, New Jersey Radiation Specialist NJ MES 10152
 or other approved signatory

In no event shall EMSL be liable for indirect, special, consequential, or incidental damages, including, but not limited to, damages for loss of profit or goodwill regardless of the negligence (either sole or concurrent) of EMSL and whether EMSL has been informed of the possibility of such damages, arising out of or in connection with EMSL's services thereunder or the delivery, use, reliance upon or interpretation of test results by client or any third party. We accept no legal responsibility for the purposes for which the client uses the test results. In no event shall EMSL be liable to a client or any third party, whether based upon theories of tort, contract or any other legal or equitable theory, in excess of the amount paid to EMSL by client thereunder. The test results meets all NELAC requirements unless otherwise specified. Accreditations: NRSB ARL6006, NJ DEP 03036, MEB 92525, PA 2573, IN 00455, IA L00032, RI RAS-024, ME 20200C, NE RMB-1083, NY ELAP 10872, NM 885-10L, FL RB2034, OH RL-39, NRPP #106178AL, KS-LB-0005

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ Accreditations: NRSB ARL6006, NJ DEP 03036, MEB 92525, PA 2573, IN 00455, IA L00032, RI RAS-024, ME 20200C, NE RMB-1083, NY ELAP 10872, NM 885-10L, FL RB2034, OH RL-39, NRPP #106178AL, KS-LB-0005. Subash Rashat certification #MES10152

Initial report from 04/01/2016 10:00:29

Please visit www.radontestinglab.com