

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381603430
 CustomerID: PGCS62
 CustomerPO: 608048
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 04/08/16 10:33 AM
 Analysis Date: 4/12/2016
 Collected: 4/1/2016

Project: **William Hall**

Test Site: **William Hall ES**
Capitol Heights, MD 20743

Test Report: Radon in Air Test Results**Samples for EMSL Kit 143184**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241447	Main Office	0.2	4/1/2016	4/4/2016	70	50	Customer
381603430-0001			9:15:00 AM	11:10:00 AM			

Sample Notes:

Samples for EMSL Kit 143235

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241442	Room 100	0.1	4/1/2016	4/4/2016	70	50	Customer
381603430-0002			9:17:00 AM	9:52:00 AM			

Sample Notes:

240022	Room 100	0.1	4/1/2016	4/4/2016	70	50	Blank
381603430-0003			9:17:00 AM	9:52:00 AM			

Sample Notes:

Samples for EMSL Kit 143215

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241406	G100 Room	0.2	4/1/2016	4/4/2016	70	50	Customer
381603430-0004			9:19:00 AM	9:36:00 AM			

Sample Notes:

240034	G100 Room	0	4/1/2016	4/4/2016	70	50	Blank
381603430-0005			9:19:00 AM	9:36:00 AM			

Sample Notes:

Samples for EMSL Kit 143222

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241366	H102	0.2	4/1/2016	4/4/2016	70	50	Customer
381603430-0006			9:20:00 AM	9:56:00 AM			

Sample Notes:

241570	H102	0.2	4/1/2016	4/4/2016	70	50	Duplicate
381603430-0007			9:20:00 AM	9:56:00 AM			

Sample Notes:

Duplicate RPD = 0%

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381603430
 CustomerID: PGCS62
 CustomerPO: 608048
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 04/08/16 10:33 AM
 Analysis Date: 4/12/2016
 Collected: 4/1/2016

Project: **William Hall**

Test Site: **William Hall ES**
Capitol Heights, MD 20743

Test Report: Radon in Air Test Results**Samples for EMSL Kit 143185**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241817	H116	0.3	4/1/2016	4/4/2016	70	50	Customer
381603430-0008			9:24:00 AM	11:05:00 AM			

Sample Notes:

240365	H116	0.2	4/1/2016	4/4/2016	70	50	Blank
381603430-0009			9:24:00 AM	11:05:00 AM			

Sample Notes:**Samples for EMSL Kit 143237**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241309	H104	0.3	4/1/2016	4/4/2016	70	50	Customer
381603430-0010			9:26:00 AM	11:08:00 AM			

Sample Notes:**Samples for EMSL Kit 143238**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241344	H112	0.2	4/1/2016	4/4/2016	70	50	Customer
381603430-0011			9:30:00 AM	11:10:00 AM			

Sample Notes:

241523	H112	0.2	4/1/2016	4/4/2016	70	50	Duplicate
381603430-0012			9:30:00 AM	11:10:00 AM			

Sample Notes:**Duplicate RPD = 0%****Samples for EMSL Kit 143219**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241536	H106	0.1	4/1/2016	4/4/2016	70	50	Customer
381603430-0013			9:33:00 AM	9:49:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (800) 220-3675 / (856) 786-0327

<http://www.EMSL.com>cinnaminsonradonlab@emsl.com

EMSL Order: 381603430

CustomerID: PGCS62

CustomerPO: 608048

ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 04/08/16 10:33 AM
 Analysis Date: 4/12/2016
 Collected: 4/1/2016

Project: **William Hall**

Test Site: **William Hall ES**
Capitol Heights, MD 20743

Test Report: Radon in Air Test Results**Samples for EMSL Kit 143236**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241337	H108	0.3	4/1/2016	4/4/2016	70	50	Customer
381603430-0014			9:35:00 AM	11:06:00 AM			

Sample Notes:**Samples for EMSL Kit 143221**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241551	H110	0.3	4/1/2016	4/4/2016	70	50	Customer
381603430-0015			9:38:00 AM	10:58:00 AM			

Sample Notes:**Samples for EMSL Kit 143218**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241628	G122	0.2	4/1/2016	4/4/2016	70	50	Customer
381603430-0016			9:40:00 AM	9:42:00 AM			

Sample Notes:

241649	G122	0.2	4/1/2016	4/4/2016	70	50	Duplicate
381603430-0017			9:40:00 AM	9:42:00 AM			

Sample Notes:**Duplicate RPD = 0%****Samples for EMSL Kit 143214**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241458	G103	0.2	4/1/2016	4/4/2016	70	50	Customer
381603430-0018			9:42:00 AM	9:33:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381603430
 CustomerID: PGCS62
 CustomerPO: 608048
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 04/08/16 10:33 AM
 Analysis Date: 4/12/2016
 Collected: 4/1/2016

Project: **William Hall**

Test Site: **William Hall ES**
Capitol Heights, MD 20743

Test Report: Radon in Air Test Results**Samples for EMSL Kit 143226**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241439	G126		4/1/2016	4/4/2016	70	50	Customer
381603430-0019			9:45:00 AM	10:10:00 AM			

Sample Notes: Not Analyzed
 Device received open by lab.

Samples for EMSL Kit 143239

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241504	G104	0.3	4/1/2016	4/4/2016	70	50	Customer
381603430-0020			9:48:00 AM	9:40:00 AM			

Sample Notes:

Samples for EMSL Kit 143229

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241471	G107	0.2	4/1/2016	4/4/2016	70	50	Customer
381603430-0021			9:50:00 AM	10:56:00 AM			

Sample Notes:

Samples for EMSL Kit 143228

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241599	G115	0.4	4/1/2016	4/4/2016	70	50	Customer
381603430-0022			9:52:00 AM	10:08:00 AM			

Sample Notes:

241577	G115	0.1	4/1/2016	4/4/2016	70	50	Duplicate
381603430-0023			9:52:00 AM	10:08:00 AM			

Sample Notes:

Duplicate RPD = 120%

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381603430
 CustomerID: PGCS62
 CustomerPO: 608048
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 04/08/16 10:33 AM
 Analysis Date: 4/12/2016
 Collected: 4/1/2016

Project: **William Hall**

Test Site: **William Hall ES**
Capitol Heights, MD 20743

Test Report: Radon in Air Test Results**Samples for EMSL Kit 143240**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241374	G108	0.3	4/1/2016	4/4/2016	70	50	Customer
381603430-0024			9:55:00 AM	9:48:00 AM			

Sample Notes:

Samples for EMSL Kit 143227

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241409	G114	0.4	4/1/2016	4/4/2016	70	50	Customer
381603430-0025			9:58:00 AM	10:55:00 AM			

Sample Notes:

Samples for EMSL Kit 143234

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241451	G113	0.3	4/1/2016	4/4/2016	70	50	Customer
381603430-0026			10:00:00 AM	9:30:00 AM			

Sample Notes:

Samples for EMSL Kit 143242

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241388	G111	0.2	4/1/2016	4/4/2016	70	50	Customer
381603430-0027			10:03:00 AM	9:45:00 AM			

Sample Notes:

241588	G111	0.1	4/1/2016	4/4/2016	70	50	Duplicate
381603430-0028			10:03:00 AM	9:45:00 AM			

Sample Notes:

Duplicate RPD = 66.7%

Samples for EMSL Kit 143231

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241563	F105	0.2	4/1/2016	4/4/2016	70	50	Customer
381603430-0029			10:05:00 AM	9:38:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (800) 220-3675 / (856) 786-0327

<http://www.EMSL.com>cinnaminsonradonlab@emsl.com

EMSL Order: 381603430

CustomerID: PGCS62

CustomerPO: 608048

ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 04/08/16 10:33 AM
 Analysis Date: 4/12/2016
 Collected: 4/1/2016

Project: **William Hall**

Test Site: **William Hall ES**
Capitol Heights, MD 20743

Test Report: Radon in Air Test Results**Samples for EMSL Kit 143241**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241486	F106	0.2	4/1/2016	4/4/2016	70	50	Customer
381603430-0030			10:06:00 AM	10:12:00 AM			

Sample Notes:**Samples for EMSL Kit 143230**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241695	F107	0.3	4/1/2016	4/4/2016	70	50	Customer
381603430-0031			10:10:00 AM	10:36:00 AM			

Sample Notes:**Samples for EMSL Kit 143220**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241386	F108		4/1/2016	4/4/2016	70	50	Customer
381603430-0032			10:12:00 AM	10:00:00 AM			

Sample Notes: Not Analyzed
 Device received open by lab.

Samples for EMSL Kit 143211

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241508	A127	0.2	4/1/2016	4/4/2016	70	50	Customer
381603430-0033			10:15:00 AM	10:15:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381603430
 CustomerID: PGCS62
 CustomerPO: 608048
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 04/08/16 10:33 AM
 Analysis Date: 4/12/2016
 Collected: 4/1/2016

Project: **William Hall**

Test Site: **William Hall ES**
Capitol Heights, MD 20743

Test Report: Radon in Air Test Results**Samples for EMSL Kit 143205**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241573	A120	0.3	4/1/2016	4/4/2016	70	50	Customer
381603430-0034			10:18:00 AM	10:18:00 AM			

Sample Notes:

240052	A120	0.1	4/1/2016	4/4/2016	70	50	Blank
381603430-0035			10:18:00 AM	10:18:00 AM			

Sample Notes:**Samples for EMSL Kit 143187**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241461	D100 Media Center	0.5	4/1/2016	4/4/2016	70	50	Customer
381603430-0036			10:26:00 AM	10:05:00 AM			

Sample Notes:**Samples for EMSL Kit 143204**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241692	C109	0.7	4/1/2016	4/4/2016	70	50	Customer
381603430-0037			10:25:00 AM	10:45:00 AM			

Sample Notes:**Samples for EMSL Kit 143186**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241347	Music Room C106	0.3	4/1/2016	4/4/2016	70	50	Customer
381603430-0038			10:30:00 AM	10:48:00 AM			

Sample Notes:**Samples for EMSL Kit 143201**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241327	E100	0.1	4/1/2016	4/4/2016	70	50	Customer
381603430-0039			10:33:00 AM	10:18:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381603430
 CustomerID: PGCS62
 CustomerPO: 608048
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 04/08/16 10:33 AM
 Analysis Date: 4/12/2016
 Collected: 4/1/2016

Project: **William Hall**

Test Site: **William Hall ES**
Capitol Heights, MD 20743

Test Report: Radon in Air Test Results**Samples for EMSL Kit 143223**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241488	E101	0.5	4/1/2016	4/4/2016	70	50	Customer
381603430-0040			10:35:00 AM	10:24:00 AM			

Sample Notes:

Samples for EMSL Kit 143200

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241310	E107	0.1	4/1/2016	4/4/2016	70	50	Customer
381603430-0041			10:38:00 AM	10:20:00 AM			

Sample Notes:

Samples for EMSL Kit 143199

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241369	E102	0.3	4/1/2016	4/4/2016	70	50	Customer
381603430-0042			10:42:00 AM	10:42:00 AM			

Sample Notes:

Samples for EMSL Kit 143206

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241517	E103	0.4	4/1/2016	4/4/2016	70	50	Customer
381603430-0043			10:45:00 AM	10:22:00 AM			

Sample Notes:

Samples for EMSL Kit 143198

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241633	E105	0.1	4/1/2016	4/4/2016	70	50	Customer
381603430-0044			10:50:00 AM	10:30:00 AM			

Sample Notes:

241606	E105	0.1	4/1/2016	4/4/2016	70	50	Duplicate
381603430-0045			10:50:00 AM	10:30:00 AM			

Sample Notes:

Duplicate RPD = 0%

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381603430
 CustomerID: PGCS62
 CustomerPO: 608048
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 04/08/16 10:33 AM
 Analysis Date: 4/12/2016
 Collected: 4/1/2016

Project: **William Hall**

Test Site: **William Hall ES**
Capitol Heights, MD 20743

Test Report: Radon in Air Test Results**Samples for EMSL Kit 143209**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241555	F111	0.3	4/1/2016	4/4/2016	70	50	Customer
381603430-0046			10:53:00 AM	10:28:00 AM			

Sample Notes:

Samples for EMSL Kit 143208

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241321	F112	0.1	4/1/2016	4/4/2016	70	50	Customer
381603430-0047			10:58:00 AM	10:50:00 AM			

Sample Notes:

241568	F112	-0.1	4/1/2016	4/4/2016	70	50	Duplicate
381603430-0048			10:58:00 AM	10:50:00 AM			

Sample Notes:

Duplicate RPD = 200%

Samples for EMSL Kit 143190

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241371	F110	0.1	4/1/2016	4/4/2016	70	50	Customer
381603430-0049			11:00:00 AM	10:40:00 AM			

Sample Notes:

Samples for EMSL Kit 143210

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241426	F108	0.4	4/1/2016	4/4/2016	70	50	Customer
381603430-0050			11:05:00 AM	10:33:00 AM			

Sample Notes:

The radon test was performed using a liquid scintillation radon detector/s and counted on a liquid scintillation counter using approved EPA testing protocols for Radon in Air testing. The EPA recommends fixing your home if the average of two short-term tests taken in the lowest lived-in level of the home show radon levels that are equal to or greater than 4.0pCi/L. The EPA recommends retesting your home every two years.

Please contact EMSL Analytical, Inc. or your State Health Department for further information.
 All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of Radon in Air.

Report Note

