



Environmental Consultants and Engineers

1818 New York Avenue Suite 217
Washington, DC 20002

www.globalincusa.net

May 23, 2019

Prince Georges County
Environmental Safety Office
13306 Old Marlboro Pike
Upper Marlboro, MD 20772

Attention: Mr. Alex Baylor

RE: Indoor Air Quality Screening

Global Project Number: 19-015
School: Dr. Henry A. Wise Jr. High School

Dear Mr. Baylor,

On May 18, 2019, Global Inc.'s (GLOBAL) team of Industrial Hygienists under the supervision of GLOBAL's Certified Industrial Hygienist, Ms. Lauren Kesslak, conducted an Indoor Air Quality Screening at Dr. Henry A. Wise Jr. High School located at 12650 Brooke Ln, Upper Marlboro, MD 20772.

Methodology

The IAQ evaluation included a visual assessment, sampling for non-viable mold spores in air, and measurement of comfort parameters (temperature, humidity, carbon dioxide, and carbon monoxide) in randomly selected representative locations within the building. During the visual assessment of representative locations, and when noted, GLOBAL documented those areas with suspected mold growth, water intrusions, and wet conditions that have the potential to lead to mold growth. GLOBAL also noted any unusual odors. At least one microbial air sample was collected for every 10,000 Square Feet (SF) of space in the building and the analytical results for the interior spaces were compared to an outdoor (ambient) sample collected on the same day.

Microbial samples (including a field blank for quality control) were delivered under strict chain-of-custody procedures were to Hayes Microbial Consulting - an AIHA EMPAT-certified laboratory in Midlothian, Virginia for analysis by microscopy. The sample chain-of-custody and laboratory report is attached.

Observations and Results

GLOBAL's inspector conducted a walkthrough with Prince Georges County Public School (PGCPS) personnel present. Rooms were selected in a random manner throughout the building so as to prevent sampling bias.



Environmental Consultants and Engineers

1818 New York Avenue Suite 217
Washington, DC 20002

www.globalincusa.net

Mold-in-Air Samples

There are no definitive regulations or standardized guidelines for addressing airborne mold in an indoor setting. If building systems (ventilation, envelope) are functioning properly, the indoor fungal ecology profile should be consistent with what is encountered outdoors and the spore concentrations should be below the ambient levels. Laboratory analytical results are attached at the end of this report.

Temperature

The American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) have published recommendations for year-round acceptable temperatures in Standard 55-2016 (*Thermal Environmental Conditions for Human Occupancy*). The summer comfort range is 73 to 79°F. It is important to note that ASHRAE standards are intended as a suggested guideline as opposed to a regulation.

Relative Humidity (RH)

Relative humidity is a key factor for mold growth. Mold has the potential of growing on suitable surfaces with humidity levels above 60%. ASHRAE standard 62.1-2013 (*Ventilation for Acceptable Indoor Air Quality*) recommends a maximum indoor relative humidity of 65% to preclude the likelihood of condensation on cool surfaces encouraging mold growth. All the indoor relative humidity readings were below the ASHRAE recommended level of 65%.

Carbon Monoxide

Carbon monoxide (CO) is a colorless and odorless gas that is produced by the incomplete combustion of carbon-containing fuels. Oil, gasoline, diesel fuels, wood, coke, and coal are the major sources of CO. All registered CO concentrations were below the EPA National Ambient Air Quality Standard (NAAQS) of 9 ppm.

Carbon Dioxide

Under conditions of maximum occupancy, ASHRAE Standard 62.1-2013, Appendix C, infers that the acceptable carbon dioxide upper limit is the prevailing outdoor carbon dioxide concentration plus 700 parts per million (ppm). On May 18, 2019, the outdoor (ambient) carbon dioxide concentration was approximately 426.5 ppm so indoor concentrations should not exceed approximately 1126.5 ppm (700 + 426.5). All indoor carbon dioxide measurements were within the ASHRAE standards.

Observations are presented in Table 1 and testing results are presented in Table 2.



Environmental Consultants and Engineers

1818 New York Avenue Suite 217
Washington, DC 20002

www.globalincusa.net

Table 1: Observations

Location	Observations
A245	No issues
C209	No issues
C215	No issues
C229	No issues
C226	No issues
G103	No issues
G108	No issues
D201	No issues
B219	No issues
B213	No issues
A221	No issues
A216	No issues
A211	No issues
A201	No issues
G149	No issues
F100	No issues
D217	No issues
D212	No issues
B224	No issues
B207	No issues
D204	No issues
D139	No issues
C121	No issues
C131	No issues
E112	No issues
G130	No issues
D183	No issues
D174	No issues
A112	No issues
A106	No issues
A102	No issues
D143	No issues
B123	No issues
B105	No issues
B118	No issues



Environmental Consultants and Engineers

1818 New York Avenue Suite 217
Washington, DC 20002

www.globalincusa.net

A314	No issues
A308	No issues
A304	No issues
C305	No issues
C316	No issues
B305	No issues
D303	No issues
B818	No issues
B312	No issues
B310	No issues

Table 2: Air Quality Results

Sample Location	Temp °F	RH%	CO ppm	CO2 ppm	Normal Fungal Ecology?
Standards	ASHRAE 68 to 75°F	ASHRAE <65%	NAAQS <9	ASHRAE 1126.5	
Ambient	80.7	54.8	0	426.5	N/A
A245	72.3	41.85	0	443	Yes
C209	71.85	46.9	0	484	Yes
C215	72.2	48.5	0	478.5	Yes
C229	71.6	47.9	0	502.5	Yes
C226	71.6	48.6	0	493	Yes
G103	72	62.5	0	463.5	Yes
G108	72.1	50.8	0	503.5	Yes
D201	72.3	43.8	0	471.5	Yes
B219	72.2	45.75	0	447.5	Yes
B213	73.35	45.6	0	443	Yes
A221	72.4	42.7	0	478.5	Yes
A216	72.4	42.35	0	454.5	Yes
A211	72.35	42.85	0	474	Yes



Environmental Consultants and Engineers

1818 New York Avenue Suite 217
Washington, DC 20002

www.globalincusa.net

Sample Location	Temp °F	RH%	CO ppm	CO2 ppm	Normal Fungal Ecology?
Standards	ASHRAE 68 to 75°F	ASHRAE <65%	NAAQS <9	ASHRAE 1126.5	
A201	72.6	42.5	0	460	Yes
G149	71.05	519.5	0	519.5	Yes
F100	71.4	52.05	0	466.5	Yes
D217	71.4	46.15	0	989	Yes
D212	71.45	46.25	0	482.5	Yes
B224	72.1	46.5	0	474	Yes
B207	72.45	46.3	0	423	Yes
D204	72.4	44.1	0	511	Yes
D139	71.35	50.45	0	458	Yes
C121	71.45	45.95	0	533	Yes
C131	72.05	55.7	0	463	Yes
E112	72.75	50.65	0	483	Yes
G130	71.4	56.95	0	462.5	Yes
D183	71.45	55	0	463	Yes
D174	70.75	50.9	0	498	Yes
A112	70.8	41.95	0	511.5	Yes
A106	69.95	42.2	0	494	Yes
A102	69.8	43.2	0	486.5	Yes
D143	68.55	62.65	0	481	Yes
B123	70.1	56.15	0	475	Yes
B105	71.3	56	0	513.5	Yes
B118	71.8	53.6	0	518.5	Yes



Environmental Consultants and Engineers

1818 New York Avenue Suite 217
Washington, DC 20002

www.globalincusa.net

Sample Location	Temp °F	RH%	CO ppm	CO2 ppm	Normal Fungal Ecology?
Standards	ASHRAE 68 to 75°F	ASHRAE <65%	NAAQS <9	ASHRAE 1126.5	
A314	69.75	47.25	0	515.5	Yes
A308	70.95	46.6	0	528	Yes
A304	70.6	44.15	0	502	Yes
C305	69.8	54.8	0	497	Yes
C316	70.3	54.85	0	506.5	Yes
B305	71.3	46.4	0	504.5	Yes
D303	70.3	46.15	0	475.5	Yes
B818	69.9	46.65	0	478	Yes
B312	70.9	44.75	0	450	Yes
B310	71.55	46.15	0	468.5	Yes



Environmental Consultants and Engineers

1818 New York Avenue Suite 217
Washington, DC 20002

www.globalincusa.net

Conclusions

No indoor air quality issues related to mold were found during the screening performed on May 18, 2019, and all mold samples were found to have a normal ecology for an indoor environment.

It has been our pleasure to conduct these IAQ Screening services for the Prince Georges County Public School system. If you have any questions, please feel free to contact us.

Regards,

A handwritten signature in black ink, appearing to read "Lauren E. Kesslak".

Lauren E. Kesslak, MS, CIH, CSP
Certified Industrial Hygienist

Analysis Report prepared for

Global, Inc.

1818 New York Ave.
Suite 217
Washington, DC, 20002

Phone: (443) 691-0455

19-015
Henry Wise

Collected: May 18, 2019
Received: May 23, 2019
Reported: May 23, 2019

We would like to thank you for trusting Hayes Microbial for your analytical needs!
We received 44 samples by FedEx in good condition for this project on May 23rd, 2019.

The results in this analysis pertain only to this job, collected on the stated date, and should not be used in the interpretation of any other job. This report may not be duplicated, except in full, without the written consent of Hayes Microbial Consulting, LLC..

This laboratory bears no responsibility for sample collection activities, analytical method limitations, or your use of the test results. Interpretation and use of test results are your responsibility. Any reference to health effects or interpretation of mold levels is strictly the opinion of Hayes Microbial. In no event, shall Hayes Microbial or any of its employees be liable for lost profits or any special, incidental or consequential damages arising out of the use of these test results.



Steve Hayes, BSMT(ASCP)
Laboratory Director
Hayes Microbial Consulting, LLC.



EPA Laboratory ID: VA01419



Lab ID: #188863



NVLAP Lab Code: 500096-0



DPH License: #PH-0198

Sample Number	1	HWHS/51819-01			2	HWHS/51819-02			3	HWHS/51819-03			4	HWHS/51819-04		
Sample Name	Ambient			E130 - Gym			E112 - Dance Studio			C131 - Locker Room						
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter						
Reporting Limit	13 spores/m ³			13 spores/m ³			13 spores/m ³			13 spores/m ³						
Background	2			2			1			2						
Fragments	27/m ³			ND			ND			ND						
Organism	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total				
Alternaria																
Ascospores	288	3840	60.3%	2	27	100.0%	1	13	100.0%	2	27	66.7%				
Aspergillus Penicillium	4	53	<1%													
Basidiospores	176	2347	36.8%							1	13	33.3%				
Bipolaris Drechslera																
Chaetomium																
Cladosporium	9	120	1.9%													
Curvularia																
Epicoccum																
Fusarium																
Memnoniella																
Myxomycetes																
Pithomyces																
Stachybotrys																
Stemphylium																
Torula																
Ulocladium																
Cercospora	1	13	<1%													
Pestalotiopsis																
Total	478	6373	100%	2	27	100%	1	13	100%	3	40	100%				

Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality
------------------------	-----------------	-------------------------------	------------------------------------	-------------------

Collected: **May 18, 2019**

Received: **May 23, 2019**

Reported: **May 23, 2019**



Project Analyst:
 Ramesh Poluri, PhD

P. Ramesh

Date:
05 - 23 - 2019

Reviewed By:
 Steve Hayes, BSMT

Stephen N. Hayes

Date:
05 - 23 - 2019

Sample Number	5 HWHS/51819-05			6 HWHS/51819-06			7 HWHS/51819-07			8 HWHS/51819-08		
Sample Name	C121 - School Store			D143 - Classroom			A102 - Classroom			A106 - Classroom		
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter		
Reporting Limit	13 spores/m ³			13 spores/m ³			13 spores/m ³			13 spores/m ³		
Background	1			2			1			1		
Fragments	ND			ND			ND			ND		
Organism	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total
Alternaria												
Ascospores	1	13	100.0%	2	27	100.0%	1	13	50.0%	1	13	100.0%
Aspergillus Penicillium												
Basidiospores							1	13	50.0%			
Bipolaris Drechslera												
Chaetomium												
Cladosporium												
Curvularia												
Epicoccum												
Fusarium												
Memnoniella												
Myxomycetes												
Pithomyces												
Stachybotrys												
Stemphylium												
Torula												
Ulocladium												
Cercospora												
Pestalotiopsis												
Total	1	13	100%	2	27	100%	2	26	100%	1	13	100%

Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality
------------------------	-----------------	-------------------------------	------------------------------------	-------------------

Collected: **May 18, 2019**

Received: **May 23, 2019**

Reported: **May 23, 2019**



Project Analyst:
Ramesh Poluri, PhD

P. Ramesh

Date:
05 - 23 - 2019

Reviewed By:
Steve Hayes, BSMT

Stephen N. Hayes

Date:
05 - 23 - 2019

Sample Number	9	HWHS/51819-09			10	HWHS/51819-10			11	HWHS/51819-11			12	HWHS/51819-12		
Sample Name	A112 - Classroom			B105 - Classroom			B123 - Classroom			B118 - Classroom						
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter						
Reporting Limit	13 spores/m ³			13 spores/m ³			13 spores/m ³			13 spores/m ³						
Background	1			1			2			1						
Fragments	ND			ND			ND			ND						
Organism	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total				
Alternaria																
Ascospores	1	13	50.0%	1	13	100.0%	1	13	33.3%	1	13	100.0%				
Aspergillus Penicillium																
Basidiospores	1	13	50.0%				2	27	66.7%							
Bipolaris Drechslera																
Chaetomium																
Cladosporium																
Curvularia																
Epicoccum																
Fusarium																
Memnoniella																
Myxomycetes																
Pithomyces																
Stachybotrys																
Stemphylium																
Torula																
Ulocladium																
Cercospora																
Pestalotiopsis																
Total	2	26	100%	1	13	100%	3	40	100%	1	13	100%				

Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality
------------------------	-----------------	-------------------------------	------------------------------------	-------------------

Collected: May 18, 2019

Received: May 23, 2019

Reported: May 23, 2019



Project Analyst:
Ramesh Poluri, PhD

P. Ramesh

Date:
05 - 23 - 2019

Reviewed By:
Steve Hayes, BSMT

Stephen N. Hayes

Date:
05 - 23 - 2019

Sample Number	13	HWHS/51819-13			14	HWHS/51819-14			15	HWHS/51819-15			16	HWHS/51819-16		
Sample Name	D139 - Office			F100 - Cafeteria			D183 - Classroom			G108 - Classroom						
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter						
Reporting Limit	13 spores/m ³			13 spores/m ³			13 spores/m ³			13 spores/m ³						
Background	2			2			1			2						
Fragments	ND			ND			ND			ND						
Organism	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total				
Alternaria																
Ascospores	2	27	100.0%	3	40	75.0%	1	13	100.0%	1	13	50.0%				
Aspergillus Penicillium																
Basidiospores				1	13	25.0%										
Bipolaris Drechslera																
Chaetomium																
Cladosporium																
Curvularia																
Epicoccum																
Fusarium																
Memnoniella																
Myxomycetes										1	13	50.0%				
Pithomyces																
Stachybotrys																
Stemphylium																
Torula																
Ulocladium																
Cercospora																
Pestalotiopsis																
Total	2	27	100%	4	53	100%	1	13	100%	2	26	100%				

Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality
------------------------	-----------------	-------------------------------	------------------------------------	-------------------

Collected: **May 18, 2019**

Received: **May 23, 2019**

Reported: **May 23, 2019**



Project Analyst:
Ramesh Poluri, PhD

P. Ramesh

Date:
05 - 23 - 2019

Reviewed By:
Steve Hayes, BSMT

Stephen N. Hayes

Date:
05 - 23 - 2019

Sample Number	17	HWHS/51819-17			18	HWHS/51819-18			19	HWHS/51819-19			20	HWHS/51819-20		
Sample Name	G103 - Black Box			D212			D217			C229						
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter						
Reporting Limit	13 spores/m ³			13 spores/m ³			13 spores/m ³			13 spores/m ³						
Background	2			2			1			1						
Fragments	ND			ND			ND			ND						
Organism	Raw Count	Count / m³	% of Total	Raw Count	Count / m³	% of Total	Raw Count	Count / m³	% of Total	Raw Count	Count / m³	% of Total				
Alternaria																
Ascospores	3	40	75.0%	1	13	33.3%	1	13	100.0%	1	13	50.0%				
Aspergillus Penicillium																
Basidiospores																
Bipolaris Drechslera																
Chaetomium																
Cladosporium	1	13	25.0%							1	13	50.0%				
Curvularia																
Epicoccum																
Fusarium																
Memnoniella																
Myxomycetes																
Pithomyces																
Stachybotrys																
Stemphylium																
Torula																
Ulocladium																
Cercospora																
Pestalotiopsis				2	27	66.7%										
Total	4	53	100%	3	40	100%	1	13	100%	2	26	100%				

Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality
------------------------	-----------------	-------------------------------	------------------------------------	-------------------



Collected: May 18, 2019	Received: May 23, 2019	Reported: May 23, 2019
Project Analyst: Ramesh Poluri, PhD <i>P. Ramesh</i>	Date: 05 - 23 - 2019	Reviewed By: Steve Hayes, BSMT <i>Stephen N. Hayes</i>
Date: 05 - 23 - 2019		Date: 05 - 23 - 2019

Sample Number	21	HWHS/51819-21			22	HWHS/51819-22			23	HWHS/51819-23			24	HWHS/51819-24		
Sample Name	C226			C215			C209			B224						
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter						
Reporting Limit	13 spores/m ³			13 spores/m ³			13 spores/m ³			13 spores/m ³						
Background	1			2			1			1						
Fragments	ND			ND			ND			ND						
Organism	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total				
Alternaria																
Ascospores	1	13	100.0%	2	27	100.0%	1	13	100.0%	3	40	75.0%				
Aspergillus Penicillium																
Basidiospores										1	13	25.0%				
Bipolaris Drechslera																
Chaetomium																
Cladosporium																
Curvularia																
Epicoccum																
Fusarium																
Memnoniella																
Myxomycetes																
Pithomyces																
Stachybotrys																
Stemphylium																
Torula																
Ulocladium																
Cercospora																
Pestalotiopsis																
Total	1	13	100%	2	27	100%	1	13	100%	4	53	100%				

Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality
------------------------	-----------------	-------------------------------	------------------------------------	-------------------

Collected: **May 18, 2019**

Received: **May 23, 2019**

Reported: **May 23, 2019**



Project Analyst:
Ramesh Poluri, PhD

P. Ramesh

Date:
05 - 23 - 2019

Reviewed By:
Steve Hayes, BSMT

Stephen N. Hayes

Date:
05 - 23 - 2019

Sample Number	25 HWHS/51819-25			26 HWHS/51819-26			27 HWHS/51819-27			28 HWHS/51819-28		
Sample Name	B207			D204			D201			B219		
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter		
Reporting Limit	13 spores/m ³			13 spores/m ³			13 spores/m ³			13 spores/m ³		
Background	1			2			1			1		
Fragments	ND			ND			ND			ND		
Organism	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total
Alternaria												
Ascospores	1	13	100.0%	1	13	100.0%	1	13	100.0%	2	27	100.0%
Aspergillus Penicillium												
Basidiospores												
Bipolaris Drechslera												
Chaetomium												
Cladosporium												
Curvularia												
Epicoccum												
Fusarium												
Memnoniella												
Myxomycetes												
Pithomyces												
Stachybotrys												
Stemphylium												
Torula												
Ulocladium												
Cercospora												
Pestalotiopsis												
Total	1	13	100%	1	13	100%	1	13	100%	2	27	100%

Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality
------------------------	-----------------	-------------------------------	------------------------------------	-------------------



Collected: **May 18, 2019**

Received: **May 23, 2019**

Reported: **May 23, 2019**

Project Analyst:
Ramesh Poluri, PhD

P. Ramesh

Date:
05 - 23 - 2019

Reviewed By:
Steve Hayes, BSMT

Stephen N. Hayes

Date:
05 - 23 - 2019

Sample Number	29	HWHS/51819-29			30	HWHS/51819-30			31	HWHS/51819-31			32	HWHS/51819-32		
Sample Name	B213			A221			A216			A211						
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter						
Reporting Limit	13 spores/m ³			13 spores/m ³			13 spores/m ³			13 spores/m ³						
Background	2			2			1			1						
Fragments	ND			ND			ND			ND						
Organism	Raw Count	Count / m³	% of Total	Raw Count	Count / m³	% of Total	Raw Count	Count / m³	% of Total	Raw Count	Count / m³	% of Total				
Alternaria																
Ascospores	1	13	100.0%	1	13	50.0%	1	13	100.0%							
Aspergillus Penicillium																
Basidiospores				1	13	50.0%				1	13	100.0%				
Bipolaris Drechslera																
Chaetomium																
Cladosporium																
Curvularia																
Epicoccum																
Fusarium																
Memnoniella																
Myxomycetes																
Pithomyces																
Stachybotrys																
Stemphylium																
Torula																
Ulocladium																
Cercospora																
Pestalotiopsis																
Total	1	13	100%	2	26	100%	1	13	100%	1	13	100%				

Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality
------------------------	-----------------	-------------------------------	------------------------------------	-------------------



Collected: **May 18, 2019** Received: **May 23, 2019** Reported: **May 23, 2019**

Project Analyst: Ramesh Poluri, PhD *P. Ramesh* Date: **05 - 23 - 2019** Reviewed By: Steve Hayes, BSMT *Stephen N. Hayes* Date: **05 - 23 - 2019**

Sample Number	33	HWHS/51819-33			34	HWHS/51819-34			35	HWHS/51819-35			36	HWHS/51819-36		
Sample Name	A295			A201			A314			A308						
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter						
Reporting Limit	13 spores/m ³			13 spores/m ³			13 spores/m ³			13 spores/m ³						
Background	1			2			2			2						
Fragments	ND			ND			ND			ND						
Organism	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total				
Alternaria																
Ascospores	1	13	50.0%	2	27	100.0%	2	27	66.7%	1	13	100.0%				
Aspergillus Penicillium																
Basidiospores	1	13	50.0%				1	13	33.3%							
Bipolaris Drechslera																
Chaetomium																
Cladosporium																
Curvularia																
Epicoccum																
Fusarium																
Memnoniella																
Myxomycetes																
Pithomyces																
Stachybotrys																
Stemphylium																
Torula																
Ulocladium																
Cercospora																
Pestalotiopsis																
Total	2	26	100%	2	27	100%	3	40	100%	1	13	100%				

Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality
------------------------	-----------------	-------------------------------	------------------------------------	-------------------

Collected: **May 18, 2019**

Received: **May 23, 2019**

Reported: **May 23, 2019**



Project Analyst:
Ramesh Poluri, PhD

P. Ramesh

Date:
05 - 23 - 2019

Reviewed By:
Steve Hayes, BSMT

Stephen N. Hayes

Date:
05 - 23 - 2019

Sample Number	37	HWHS/51819-37			38	HWHS/51819-38			39	HWHS/51819-39			40	HWHS/51819-40		
Sample Name	A304			C305			C316			B305						
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter						
Reporting Limit	13 spores/m ³			13 spores/m ³			13 spores/m ³			13 spores/m ³						
Background	2			1			2			2						
Fragments	ND			ND			ND			ND						
Organism	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total				
Alternaria																
Ascospores	1	13	50.0%				1	13	100.0%	2	27	100.0%				
Aspergillus Penicillium																
Basidiospores	1	13	50.0%	1	13	100.0%										
Bipolaris Drechslera																
Chaetomium																
Cladosporium																
Curvularia																
Epicoccum																
Fusarium																
Memnoniella																
Myxomycetes																
Pithomyces																
Stachybotrys																
Stemphylium																
Torula																
Ulocladium																
Cercospora																
Pestalotiopsis																
Total	2	26	100%	1	13	100%	1	13	100%	2	27	100%				

Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality
------------------------	-----------------	-------------------------------	------------------------------------	-------------------



Collected: **May 18, 2019**

Received: **May 23, 2019**

Reported: **May 23, 2019**

Project Analyst:
Ramesh Poluri, PhD

P. Ramesh

Date:
05 - 23 - 2019

Reviewed By:
Steve Hayes, BSMT

Stephen N. Hayes

Date:
05 - 23 - 2019

Sample Number	41	HWHS/51819-41			42	HWHS/51819-42			43	HWHS/51819-43			44	HWHS/51819-44		
Sample Name	D303			B318			B312			B310						
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter						
Reporting Limit	13 spores/m ³			13 spores/m ³			13 spores/m ³			13 spores/m ³						
Background	2			2			1			2						
Fragments	ND			ND			ND			ND						
Organism	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total				
Alternaria																
Ascospores	1	13	50.0%	1	13	100.0%	1	13	100.0%	2	27	100.0%				
Aspergillus Penicillium																
Basidiospores	1	13	50.0%													
Bipolaris Drechslera																
Chaetomium																
Cladosporium																
Curvularia																
Epicoccum																
Fusarium																
Memnoniella																
Myxomycetes																
Pithomyces																
Stachybotrys																
Stemphylium																
Torula																
Ulocladium																
Cercospora																
Pestalotiopsis																
Total	2	26	100%	1	13	100%	1	13	100%	2	27	100%				

Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality
------------------------	-----------------	-------------------------------	------------------------------------	-------------------



Collected: **May 18, 2019**

Received: **May 23, 2019**

Reported: **May 23, 2019**

Project Analyst:
 Ramesh Poluri, PhD

P. Ramesh

Date:
05 - 23 - 2019

Reviewed By:
 Steve Hayes, BSMT

Stephen N. Hayes

Date:
05 - 23 - 2019

Spore Trap Information

Reporting Limit	The Reporting Limit is the lowest number of spores that can be detected based on the total volume of the sample collected and the percentage of the slide that is counted. At Hayes Microbial, 100% of the slide is read so the LOD is based solely on the total volume. Raw spore counts that exceed 500 spores will be estimated.										
Blanks	Results have not been corrected for field or laboratory blanks.										
Background	<p>The Background is the amount of debris that is present in the sample. This debris consists of skin cells, dirt, dust, pollen, drywall dust and other organic and non-organic matter. As the background density increases, the likelihood of spores, especially small spores such as those of <i>Aspergillus</i> and <i>Penicillium</i> may be obscured. The background is rated on a scale of 1 to 5 and each level is determined as follows:</p> <p>NBD: No background detected due to possible pump or cassette malfunction. Recollect sample. (Field Blanks will display NBD)</p> <p>1 : <5% of field occluded. No spores will be uncountable.</p> <p>2 : 5-25% of field occluded.</p> <p>3 : 25-75% of field occluded.</p> <p>4 : 75-90% of field occluded.</p> <p>5 : >90% of field occluded. Suggested recollection of sample.</p>										
Fragments	Fragments are small pieces of fungal mycelium or spores. They are not identifiable as to type and when present in very large numbers, may indicate the presence of mold amplification.										
Control Comparisons	There are no national standards for the numbers of fungal spores that may be present in the indoor environment. As a general rule and guideline that is widely accepted in the indoor air quality field, the numbers and types of spores that are present in the indoor environment should not exceed those that are present outdoors at any given time. There will always be some mold spores present in "normal" indoor environments. The purpose of sampling and counting spores is to help determine whether an abnormal condition exists within the indoor environment and if it does, to help pinpoint the area of contamination. Spore counts should not be used as the sole determining factor of mold contamination. There are many factors that can cause anomalies in the comparison of indoor and outdoor samples due to the dynamic nature of both of those environments.										
<table border="1"> <tr> <td style="background-color: #ADD8E6;">Water Damage Indicator</td> <td>Blue: These molds are commonly seen in conditions of prolonged water intrusion and usually indicate a problem.</td> </tr> <tr> <td style="background-color: #90EE90;">Common Allergen</td> <td>Green: Although all molds are potential allergens, these are the most common allergens that may be found indoors.</td> </tr> <tr> <td style="background-color: #FFDAB9;">Slightly Higher than Baseline</td> <td>Orange: The spore count is slightly higher than the outside count and may or may not indicate a source of contamination.</td> </tr> <tr> <td style="background-color: #FFB6C1;">Significantly Higher than Baseline</td> <td>Red: The spore count is significantly higher than the baseline count and probably indicates a source of contamination.</td> </tr> <tr> <td style="background-color: #DDA0DD;">Ratio Abnormality</td> <td>Violet: The types of spores found indoors should be similar to the ones that were identified in the baseline sample. Significant increases (more than 25%) in the ratio of a particular spore type may indicate the presence of abnormal levels of mold, even if the total number of spores of that type is lower in the indoor environment than it was outdoors.</td> </tr> </table>	Water Damage Indicator	Blue: These molds are commonly seen in conditions of prolonged water intrusion and usually indicate a problem.	Common Allergen	Green: Although all molds are potential allergens, these are the most common allergens that may be found indoors.	Slightly Higher than Baseline	Orange: The spore count is slightly higher than the outside count and may or may not indicate a source of contamination.	Significantly Higher than Baseline	Red: The spore count is significantly higher than the baseline count and probably indicates a source of contamination.	Ratio Abnormality	Violet: The types of spores found indoors should be similar to the ones that were identified in the baseline sample. Significant increases (more than 25%) in the ratio of a particular spore type may indicate the presence of abnormal levels of mold, even if the total number of spores of that type is lower in the indoor environment than it was outdoors.	
Water Damage Indicator	Blue: These molds are commonly seen in conditions of prolonged water intrusion and usually indicate a problem.										
Common Allergen	Green: Although all molds are potential allergens, these are the most common allergens that may be found indoors.										
Slightly Higher than Baseline	Orange: The spore count is slightly higher than the outside count and may or may not indicate a source of contamination.										
Significantly Higher than Baseline	Red: The spore count is significantly higher than the baseline count and probably indicates a source of contamination.										
Ratio Abnormality	Violet: The types of spores found indoors should be similar to the ones that were identified in the baseline sample. Significant increases (more than 25%) in the ratio of a particular spore type may indicate the presence of abnormal levels of mold, even if the total number of spores of that type is lower in the indoor environment than it was outdoors.										
Color Coding	Fungi that are present in indoor samples at levels lower than 200 per cubic meter are not color coded on the report, unless they are one of the water damage indicators.										

Organism Descriptions

Ascospores	Habitat: A large group consisting of more than 3000 species of fungi. Common plant pathogens and outdoor numbers become very high following rain. Most of the genera are indistinguishable by spore trap analysis and are combined on the report.
	Effects: Health affects are poorly studied, but many are likely to be allergenic.

Aspergillus Penicillium	Habitat: The most common fungi isolated from the environment. Very common in soil and on decaying plant material. Are able to grow well indoors on a wide variety of substrates.
	Effects: This group contains common allergens and many can cause hypersensitivity pneumonitis. They may cause extrinsic asthma, and many are opportunistic pathogens. Many species produce mycotoxins which may be associated with disease in humans and other animals. Toxin production is dependent on the species, the food source, competition with other organisms, and other environmental conditions.

Basidiospores	Habitat: A common group of Fungi that includes the mushrooms and bracket fungi. They are saprophytes and plant pathogens. In wet conditions they can cause structural damage to buildings.
	Effects: Common allergens and are also associated with hypersensitivity pneumonitis.

Cercospora	Habitat: Found on wood and decaying plant matter.
	Effects: Health effects are poorly studied.

Cladosporium	Habitat: One of the most common genera worldwide. Found in soil and plant debris and on the leaf surfaces of living plants. The outdoor numbers are lower in the winter and often relatively high in the summer, especially in high humidity. The outdoor numbers often spike in the late afternoon and evening. Indoors, it can be found growing on textiles, wood, sheetrock, moist window sills and in HVAC supply ducts.
	Effects: A common allergen, producing more than 10 allergenic antigens and a common cause of hypersensitivity pneumonitis.

Myxomycetes	Habitat: Found on decaying plant material and as a plant pathogen.
	Effects: Some allergenic properties reported, but generally pose no health concerns to humans.

Pestalotiopsis

Habitat: Found in soil and occasionally on plants. Some species can break down plastics.

Effects: No known health effects. Allergenic properties are poorly studied.



Company: Global Inc.
 Address: 1818 New York Ave NE
Washington, DC

10f2

N

SHIP: FEDEX - PAK 50
 DATE: 05-23-2019



Job Number: <u>19-015</u>	Job Name: <u>Henry Wise</u>	Mobile: <u>814-241-9005</u>	Email: <u>Lauren K@globalincusa.net</u>
Collector: <u>C. KESSLER</u>		Note:	
Date Collected: <u>5-18-19</u>			

Analysis Type	Analysis Description	Turnaround	Accepted Media Types	
Spore Trap	S	Identification & Enumeration of Fungal Spores	24 Hour	Air Cassettes, Impact Slides
	S+	Spore Trap Analysis with Dander, Fiber, and Pollen counts	24 Hour	Air Cassettes, Impact Slides
Direct ID	D	ID & Semi-Quantative Enumeration of spores and mycelium	24 Hour	Bio-Tape, Tape, Swab, Bulk, Agar Plate
	D+	Direct Analysis with Fully Quantitative spore count	24 Hour	Bio-Tape, Tape, Swab, Bulk, Agar Plate
Culture	C1	Identification & Enumeration of Mold only	7 Day	Air Plate, Agar Plate, Swab, Bulk
	C2	Identification & Enumeration of Bacteria only	4 Day	Air Plate, Agar Plate, Swab, Bulk
	C3	Identification & Enumeration of Mold and Bacteria	7 Day	Air Plate, Agar Plate, Swab, Bulk
	C5	Coliform Screen for Sewage Bacteria	2 Day	Agar Plate, Swab, Bulk
Particle	TPA	Total Particulate Analysis, ID & Count (Does Not Include Mold)	24 Hour	Air Cassettes, Impact Slides, Bio-Tape


#	Number	Sample	Analysis	Volume	Notes
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					

Released by: <u>[Signature]</u>	Date: <u>5-22-19</u>	Received By: <u>MG</u>	Date: <u>5-23-19</u>
---------------------------------	----------------------	------------------------	----------------------

2019
N



19020385



7752 8854 6875

Dr. Henry Wise High School

AP

Sample ID	Location	Analy	
HWHS/51819-01	Ambient	S	75
HWHS/51819-02	E130, Gym	S	75
HWHS/51819-03	E112, Dance Studio	S	75
HWHS/51819-04	C131, Locker Room	S	75
HWHS/51819-05	C121, School Store	S	75
HWHS/51819-06	D143, Classroom	S	75
HWHS/51819-07	A102, Classroom	S	75
HWHS/51819-08	A106, Classroom	S	75
HWHS/51819-09	A112, Classroom	S	75
HWHS/51819-10	B105, Classroom	S	75
HWHS/51819-11	B123, Classroom	S	75
HWHS/51819-12	B118, Classroom	S	75
HWHS/51819-13	D139, Office	S	75
HWHS/51819-14	F100, Cafeteria	S	75
HWHS/51819-15	D183, Classroom	S	75
HWHS/51819-16	G108, Classroom	S	75
HWHS/51819-17	G103, Black Box	S	75
HWHS/51819-18	D212	S	75
HWHS/51819-19	D217	S	75
HWHS/51819-20	C229	S	75
HWHS/51819-21	C226	S	75
HWHS/51819-22	C215	S	75
HWHS/51819-23	C209	S	75
HWHS/51819-24	B224	S	75
HWHS/51819-24	B207	S	75
HWHS/51819-26	D204	S	75
HWHS/51819-27	D201	S	75
HWHS/51819-28	B219	S	75
HWHS/51819-29	B213	S	75
HWHS/51819-30	A221	S	75
HWHS/51819-31	A216	S	75
HWHS/51819-32	A211	S	75
HWHS/51819-33	A295	S	75
HWHS/51819-34	A201	S	75
HWHS/51819-35	A314	S	75
HWHS/51819-36	A308	S	75
HWHS/51819-37	A304	S	75
HWHS/51819-38	C305	S	75
HWHS/51819-39	C316	S	75
HWHS/51819-40	B305	S	75
HWHS/51819-41	D303	S	75
HWHS/51819-42	B318	S	75
HWHS/51819-43	B312	S	75
HWHS/51819-44	B310	S	75

MG 5/23/19