



July 2, 2019

Mr. Alex Baylor, Environmental Specialist  
Environmental Safety Office  
Prince Georges County Public Schools  
Division of Supporting Services / Building Services  
13306 Old Marlboro Pike  
Upper Marlboro, MD 20772

via email: [alex.baylor@pgcps.org](mailto:alex.baylor@pgcps.org)

**RE: Indoor Air Quality (IAQ) and Mold Assessment Services  
J. Frank Dent Elementary School  
2700 Corning Avenue, Fort Washington, MD 20744  
Contract No.: IFB 022-19; Tidewater Project No.: 5419-003**

Dear Mr. Baylor:

Tidewater, Inc. (Tidewater) is pleased to present this Indoor Air Quality (IAQ) and Mold Assessment Report describing the results of the IAQ assessment and mold survey conducted by Tidewater at J. Frank Dent Elementary School located at 2700 Corning Avenue, Fort Washington, Maryland. This survey was conducted on May 16, 2019, by Tidewater's Project Manager and Certified Industrial Hygienist, Mr. Skanda Abeysekere MS, CIH, CSP, CHMM.

The scope of work for the IAQ assessment and mold survey included:

- Visual inspections of the following areas of the school: Health Room, Main Office, Multipurpose Room, Classroom 15, Library, Classroom 5, Classroom 9, Classroom 4, Classroom 17 and Lobby of J. Frank Dent Elementary School for evidence of potential indoor air quality problems (including suspect microbial growth, water damage, chemical use/ storage, drain traps, sources of allergens/ contaminants, etc.) that may contribute to indoor air quality problems;
- Comfort parameter air testing in these same areas using direct-read measurements for temperature (T), relative humidity (RH), carbon monoxide (CO), and carbon dioxide (CO<sub>2</sub>). Measurements were taken for comparison with guidelines established by the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) Standard 62.1–2016, Ventilation for Acceptable Indoor Air Quality, and The United States Environmental Protection Agency (US EPA) National Ambient Air Quality Standards (NAAQS.);
- Direct read measurements for particulate matter less than 10 microns (PM10) in these areas for comparison with guidelines established by the United States Environmental Protection Agency (US EPA.);
- Direct read measurements for Total Volatile Organic Compounds (TVOCs); and,
- Air sampling in these areas for total airborne fungal spore analysis using Allergenco-D cassettes affixed to a Buck BioAire™ Model B520 Bioaerosol Sampling Pump.



## **Visual Observation**

Tidewater's assessment included a visual inspection of representative areas of the school including the Health Room, Main Office, Multipurpose Room, Classroom 15, Library, Classroom 5, Classroom 9, Classroom 4, Classroom 17 and Lobby of J. Frank Dent Elementary School. The results of Tidewater's visual inspection are as follows:

### **Health Room**

The Health Room had two (2) occupants at the time of the inspection. The return air grill located on the ceiling was rusty; furthermore, the return air grill in the restroom contained excessive levels of dust. A wall-mounted fan coil unit was in the Health Room which was in operation at the time of the inspection. No signs of mold growth or past or ongoing water-intrusion problems were observed in the Health Room. Furthermore, no unusual odors were detected.

### **Main Office**

The main office was relatively clean; however, the ceiling mounted supply and return grills were rusty and contained excessive levels of dust. The supply and return air grills located in the principal's office and in the instructional room also contained excessive levels of dust.

### **Multi-Purpose Room**

Multipurpose Room was vacant at the time of the inspection. A large water-stain was observed in the center of the ceiling indicating signs of on-going or past water intrusion. Mild food odors were detected from the Multipurpose Room. All trash receptacles were empty and the general housekeeping appeared to be satisfactory. The return grills located on the perimeter walls of the Multipurpose Room were dusty. Multiple window-mounted air conditioning units supplied air to the Multipurpose Room.

### **Classroom 15**

Classroom 15 had around 20 students at the time of the inspection. The air supply grills of the ceiling mounted HVAC unit contained dust deposits. Furthermore, books were stored on top of the air supply grills of the wall-mounted fan coil unit hindering air flow. General housekeeping within the classroom can improve. No signs of mold growth or past or ongoing water-intrusion problems were observed. No unusual odors were detected within the classroom.

### **Library**

Library had around 14 students at the time of the inspection. Several window-mounted air conditioning units were in operation at the time of the inspection. The general air flow within the Library appeared to be good. No signs of mold growth or past or ongoing water-intrusion problems were observed. Furthermore, no unusual odors were detected.

### **Classroom 5**

Classroom 5 had around 14 students at the time of the inspection. The air supply grills of the ceiling were clean. The HVAC system was in operation and cold air was emitting from the fan coil unit. The general air flow was satisfactory. General housekeeping within the classroom



was good. No unusual odors were detected. No signs of mold growth or past or ongoing water-intrusion problems were observed.

### **Classroom 9**

Classroom 9 was vacant at the time of the inspection. The air supply grills of the ceiling were relatively clean. The fan coil unit was in operation and hot air was emitting from the fan coil unit at the time of the inspection. No unusual odors were detected. No signs of mold growth or past or ongoing water-intrusion problems were observed within Classroom 9.

### **Classroom 4**

Classroom 4 had around seven (7) students at the time of the inspection. The air supply grills of the ceiling were clean. The fan coil unit was in operation. General housekeeping within the classroom was good. No unusual odors were detected. Furthermore, no signs of mold growth or past or ongoing water-intrusion problems were observed.

### **Classroom 17**

Classroom 17 had over 20 students at the time of the inspection. The air supply grills of the ceiling were clean. The fan coil unit was in operation and cold air was emitting from the fan coil unit. However, the air flow appeared to be inadequate as the room appeared to be stuffy. General housekeeping within the classroom was good. No unusual odors were detected from Classroom 17. No signs of mold growth or past or ongoing water-intrusion problems were observed.

### **Lobby**

Numerous water-stained ceiling tiles were observed in the hallway above the courtyard exit door next to the remedial reading room.

### **Comfort Parameter Air Testing**

During the assessment, Tidewater recorded temperature, relative humidity, carbon dioxide (CO<sub>2</sub>), and carbon monoxide (CO) measurements in the above-mentioned locations of J. Frank Dent Elementary School using a TSI Q-Track Air Quality Meter (Model Number TSI Q-Track 7565, Serial Number 7565x0931002, Calibration Date: April 18, 2019.) Measurements were taken after allowing the instrument to become acclimated to the ambient temperature and relative humidity for approximately five (5) minutes. Measurements were taken over a 5-minute time period at each designated location and the average concentration was recorded. Samples were obtained for comparison with guidelines established by the American Society for Heating Refrigeration and Air Conditioning (ASHRAE) Standard 62.1 – 2016, Ventilation for Acceptable Indoor Air Quality.

A background sample was obtained in front of the main entrance to the school building for comparison to the interior readings. The results of the IAQ comfort parameter monitoring are provided in Table 1, in **Attachment A**.

According to the American Society for Heating, Refrigerating and Air Conditioning Engineers (ASHRAE) Standard 62.1 – 2016, the temperature range in summer months should be maintained between 73.0°F and 79.0°F for maximum occupant comfort. The ASHRAE



guideline for temperature for winter months is between 68.0°F and 74.5°F. The indoor temperature levels within the assessed areas on May 16, 2019 ranged between 66.7°F and 72.6°F, and the background temperature outside the building was 64.0°F. The temperature levels recorded within the majority of the classrooms were within the temperature levels typically observed during the spring-summer transitional period. The temperature level in the Health Room was marginally below the lower temperature guideline of 68.0°F recommended for winter months; however, this is not of concern as the Health Room was vacant at the time of the inspection. Indoor temperature levels tend to fluctuate throughout the work day based on the number of occupants present within the occupied areas. The temperature level in the Health Room will increase when it is occupied to capacity.

Per the same guideline, a maximum recommended relative humidity level of 65.0% is recommended to reduce the likelihood of condensation on cold surfaces. Relative humidity levels within the assessed areas on May 16, 2019 ranged between 43.7% and 57.2%. The background relative humidity level outside the building was 66.3%. The relative humidity levels in all areas assessed were below the ASHRAE recommended maximum relative humidity guideline of 65.0%.

ASHRAE Standard 62.1 – 2016 recommends that indoor CO<sub>2</sub> levels not exceed 700 ppm above the outdoor background CO<sub>2</sub> level. The CO<sub>2</sub> levels in the assessed areas on May 16, 2019 ranged between 636 ppm to 1,558 ppm. The background CO<sub>2</sub> level outside the building was 532 ppm. The CO<sub>2</sub> levels within all interior locations assessed apart from Classroom 17, did not exceed 700 ppm above the outdoor background CO<sub>2</sub> level of 431 ppm. The CO<sub>2</sub> level in Classroom 17 exceeded 700 ppm above the outdoor background CO<sub>2</sub> level of 431 ppm. The air exchange rates in Classroom 17 needs to be increased.

The CO levels in all areas assessed within J. Frank Dent Elementary School were below the maximum guideline of 9 ppm recommended by the Indoor Air Quality Association (IAQA) for CO in occupied indoor environments.

### **Particulate Matter Less than 10 Microns (PM 10)**

Tidewater conducted air sampling for respirable dust particulates using a TSI® DUST TRAK DRX™ Aerosol Monitor (Serial Number 8534170101, Calibrated Date: March 1, 2019.) The TSI® DUST TRAK DRX™ Aerosol Monitor was equipped with a PM10 (10 µm) respirable impactor. Measurements were taken after allowing the device to become acclimated to the ambient temperature and relative humidity for five (5) minutes. Measurements were taken over a 5-minute time period at each designated location and the average concentration was recorded. Samples were taken for comparison with guidelines established by the EPA NAAQS.

Tidewater also obtained a background sample from outside the main entrance of the school building for comparison to the interior readings. The results of the particulate matter sampling are provided in Table 2, in **Attachment A**.

Based on the EPA National Ambient Air Quality Standard (NAAQS) for Particulate Matter, Final Rule (January 15, 2013), the 24-hour primary and secondary exposure standard for particulate matter less than 10 microns (PM10) is 150.0 micrograms per cubic meter of air (µg/m<sup>3</sup>) or 0.150 milligrams per cubic meter of air (mg/m<sup>3</sup>.) The results of the PM10 analysis indicate that the



average PM10 dust concentration recorded in all areas assessed in J. Frank Dent Elementary School ranged between 0.012 mg/m<sup>3</sup> and 0.040 mg/m<sup>3</sup>. The average PM10 dust concentration in the background sample obtained in front of the main entrance was 0.012 mg/m<sup>3</sup>.

The results of the PM10 monitoring indicate that the PM10 dust concentrations all areas assessed were below the EPA 24-hour primary and secondary NAAQS of 0.150 mg/m<sup>3</sup>.

### **Total Volatile Organic Compound (TVOC) Air Testing**

Tidewater obtained direct read measurements for Total Volatile Organic Compounds (TVOCs) using a Mini-RAE 2000 Hand Held VOC meter (Model Number MINIRAE 2000, Serial Number 110-010833, Calibration Date April 9, 2019.) Measurements were taken after allowing the device to become acclimated to the ambient temperature and relative humidity for five (5) minutes. Measurements were taken over a 5-minute time period at each sampling location and the average concentration was recorded for comparison with threshold limits recommended for typical occupied indoor environments.

A background sample was also obtained outdoors in front of the main entrance of the school building for comparison to the indoor readings. The results of the particulate matter sampling are provided in Table 3, in **Attachment A**.

There are no OSHA published guidelines for TVOCs. However, in general, the indoor air quality TVOC threshold for typical indoor occupied environments should not exceed 1,000 ppb (1.0 ppm) isobutylene units. The TVOC concentrations recorded in all assessed areas in J. Frank Dent Elementary School were below the recommend threshold level of 1.0 ppm.

### **Spore Trap Bioaerosol Sampling**

On May 16, 2019, Tidewater collected a total of 10 spore trap air samples using Allegenco-D cassettes to characterize potential airborne fungal spores within select areas of J. Frank Dent Elementary School. A background sample was also collected outside the main entrance to the school building for comparison purposes.

Tidewater obtained the spore trap samples using Allergenco-D cassettes affixed to a Buck BioAire™ Bioaerosol Sampling Pump (Pump Model Number B520 and Serial Number B153043, Calibration Date: February 6, 2019) calibrated to a flow rate of 15.0 Liters per minute. Each sample was run for a period of five (5) minutes at each sample location to collect a total sample volume of 75.0 liters of air.

Once collected, the samples were transported to EMSL Analytical Laboratory (EMSL) located in Beltsville, Maryland for analysis. The samples were transported following rigorous chain-of-custody guidelines to ensure proper handling and delivery of the samples. EMSL is accredited in the American Industrial Hygiene Association (AIHA) Environmental Microbiology Laboratory Accreditation Program (EMLAP) and is a successful participant in AIHA's Environmental Microbiology Proficiency Analytical Testing (EMPAT) program (Laboratory Number 102891.)

The samples were analyzed via light microscopy at the standardized magnification of 600X. This technique does not allow for the differentiation between *Aspergillus* and *Penicillium* spores because they are morphologically identical. Additionally, the technique does not allow for cultivation, or the identification of spores to the species level, except in a few cases.



There are no universally accepted federal or State of Maryland standards for acceptable airborne concentrations of bioaerosols in an indoor occupational environment. In general, airborne concentrations indoors should be less than that found in the outdoor air with similar species composition. Indoor spore counts significantly greater than those detected outdoors, or the presence of large numbers of different types of spores indoors that are not found outdoors, may indicate contamination and potential indoor air quality problems.

The total mold spore counts in all samples obtained on May 16, 2019 ranged between 90 and 2,990 spores per cubic meter (spores/m<sup>3</sup>.) The total mold spore concentration in the outdoors (background) sample was 15,060 spores/m<sup>3</sup>. The total mold spore concentrations in all interior locations sampled were significantly below the outdoors (background) total mold spore concentration. Additionally, the fungal species observed in most interior samples were consistent with those observed in the background reference samples.

The concentration of species of the genus *Aspergillus/Penicillium* in sample JEDES-10 collected from the lobby (700 spores/m<sup>3</sup>) was higher than the concentration detected in the background sample BG-1 (200 spores/m<sup>3</sup>.) *Aspergillus/ Penicillium* are the most common mold species that are detected in indoor air samples. Most of the hundreds of sub-species are allergenic with only a few that are toxic. This group of species will grow with only the humidity in the air as its water source.

The summary of the results for the spore trap sampling are provided in Table 4 in **Attachment A**. The laboratory analytical results, including speciation and chain of custody forms for the spore trap samples are included in **Attachment B**.

## **Conclusions**

Based on this IAQ and mold assessment survey, Tidewater offers the following conclusions:

- Tidewater's visual inspection of the Health Room, Main Office, Multipurpose Room, Classroom 15, Library, Classroom 5, Classroom 9, Classroom 4, Classroom 17 and Lobby of J. Frank Dent Elementary School did not reveal any visible evidence of standing water, active water intrusion or visible mold growth on the walls, floors or ceiling in any of areas inspected. However, water-stained ceiling tiles were observed in the Multipurpose Room and in the hallway above the courtyard exit door next to the Remedial Reading Room.
- The return air grills and supply air grills located in the Health Room, Main Office including the Instructional Research Room and Principal's Office, and Classroom 15 were dirty and contained excessive levels of grime/ dust. General housekeeping in all classrooms can be improved;
- The Temperature, Relative humidity and CO readings recorded within the assessed areas of J. Frank Dent Elementary School were all within industry standards and guidelines;
- The CO<sub>2</sub> level in classroom 17 exceeded 700 ppm above the outdoor background CO<sub>2</sub> level of 431 ppm;



- Particulate matter sampling results indicated that the concentration of particulate matter less than 10 microns (PM10) in all areas assessed were below the EPA 24-hour primary and secondary NAAQS of 0.150 mg/m<sup>3</sup>;
- The TVOC readings recorded in all areas assessed within J. Frank Dent Elementary School during this assessment were below the recommend threshold level of 1.0 ppm;
- The mold spore concentrations in all indoor locations sampled were significantly below the outdoors (background) total mold spore concentration and the fungal species composition were consistent with those observed in the background sample. However, the concentration of species of the genus *Aspergillus/Penicillium* in sample JEDES-10 collected from the lobby was higher than the concentration detected in the background sample potentially indicating some minor indoor contamination.

### **Recommendations**

Based on the results of our visual inspection, Tidewater proposes the following:

- Investigate above the water-stained ceiling tiles in the Multipurpose Room and in the hallway above the courtyard exit door next to the Remedial Reading Room for any ongoing water leaks and surface mold formations. If any leaks are detected, repair them immediately. If surface mold contamination is observed, appropriate steps should be taken to remediate and sanitize the affected areas;
- Abate the water-stained ceiling tiles in the above-mentioned areas. Ensure that the perimeters of the ceiling grids are cleaned with a 10% bleach solution to eliminate exiting fungal spores prior to installing new ceiling tiles;
- Clean all return air grills and air supply grills in the Health Room, Main Office including the Instructional Research Room and Principal's Office, and Classroom 15 with a 10% bleach solution to eliminate grime buildup and potential mold spores;
- Ensure that all cleaning activities are conducted after hours when the classrooms are vacant to minimize exposure to occupants;
- Maintain good housekeeping practices in all common areas and classrooms. All common area and classrooms floors should be broom cleaned at the end of each day. Furthermore, all horizontal surfaces including desk tops, furniture, window sills and suspended light fixtures should be cleaned on a routine basis to prevent the accumulation of dust;
- Ensure the Heating Ventilation and Air Conditioning (HVAC) System supplying air to all common areas and classrooms is properly balanced per design requirements and current room use/occupancy in order to ensure adequate ventilation throughout the classrooms;
- Ensure that the ventilation systems are turned on in all classrooms and are operating at all times when the classrooms are occupied to provide sufficient air flow and ventilation to the classrooms. Consider running pedestal fans when the classrooms are fully occupied if the general air circulation is inadequate;



- Increase the air exchange rates to Classroom 17; and
- Ensure that the air supply vent of the fan coil unit in Classroom 15 is left unobstructed to ensure adequate air supply into the classroom.

**Qualifications**

Tidewater has endeavored to investigate existing conditions in representative areas of J. Frank Dent Elementary School located at 2700 Corning Avenue, Fort Washington, Maryland as they pertain to indoor air quality and mold contamination. Our conclusions and recommendations are based on the observations made on the day of our assessment, laboratory data from the time of the assessment, and information provided by both our Client and the area occupants. Actual conditions vary from day to day throughout the year.

Tidewater appreciates the opportunity to provide Industrial Hygiene consulting services for Prince Georges County Public Schools. Please contact us should any questions arise concerning this report or if we may be of further assistance.

Sincerely,  
**Tidewater, Inc.**

Skanda Abeyesekere, MS, CIH, CSP, CHMM  
Project Manager

Jonathan N. Schatz, MS  
Manager, IH Services

SA/JNS

- Attachments: **Attachment A – Summary of Comfort Parameters, Total (Nuisance) Dust, TVOC and Non-Viable Spore Trap Sampling**  
**Attachment B – Laboratory Reports for Non-Viable Spore Trap Sampling**  
**Attachment C – Calibration Certificates**  
**Attachment D – Qualifications**  
**Attachment E – Floor Plan with Sampling Locations**





**TIDEWATER** INC

ENGINEERS / SCIENTISTS / PROGRAM MANAGERS

## **Attachment A**

### **Summary of Comfort Parameters, Total (Nuisance) Dust, TVOC and Non-Viable Spore Trap Sampling**



<b>Table 1: Indoor Air Quality Comfort Parameters J. Frank Dent Elementary School</b>				
<b>Location</b>	<b>Temperature (°F)</b>	<b>Carbon Dioxide (ppm)</b>	<b>Relative Humidity (%)</b>	<b>Carbon Monoxide (ppm)</b>
<b>May 16, 2019</b>				
Health Room	<b>66.7</b>	645	53.1	0.0
Main Office	69.0	673	50.2	0.0
Multipurpose Room	69.7	636	48.0	0.0
Classroom 15	71.0	941	50.5	0.0
Library	71.7	706	45.6	0.0
Classroom 5	70.6	765	49.7	0.0
Classroom 9	72.6	647	43.7	0.0
Classroom 4	70.8	669	47.6	0.0
Classroom 17	70.0	<b>1,558</b>	57.2	0.0
Lobby	70.6	645	52.0	0.0
Background	64.0	532	66.3	0.0

\*Numbers highlighted in red indicates locations in which temperature, carbon dioxide or relative humidity levels were either above or below the guidelines recommended by the American Society for Heating Refrigeration and Air Conditioning (ASHRAE) Standard 62.1 – 2016.



<b>Table 2: Particulate Matter Less than 10 Microns (PM10) J. Frank Dent Elementary School</b>	
<b>Location</b>	<b>Particulate Matter (PM10)</b>
	<b>Concentration (mg/m<sup>3</sup>)</b>
<b>May 16, 2019</b>	
Health Room	0.030
Main Office	0.040
Multipurpose Room	0.020
Classroom 15	0.025
Library	0.018
Classroom 5	0.020
Classroom 9	0.012
Classroom 4	0.022
Classroom 17	0.018
Lobby	0.025
Background (Outdoors)	0.012



<b>Table 3: Total Volatile Organic Compounds (TVOCs) J. Frank Dent Elementary School</b>	
<b>Location</b>	<b>Concentration (ppm)</b>
<b>May 16, 2019</b>	
Health Room	0.0
Main Office	0.0
Multipurpose Room	0.0
Classroom 15	0.0
Library	0.0
Classroom 5	0.0
Classroom 9	0.0
Classroom 4	0.0
Classroom 17	0.0
Lobby	0.0
Background (Outdoors)	0.0



<b>Table 4: Spore Trap Sampling Results J. Frank Dent Elementary School</b>			
<b>May 16, 2019</b>			
<b>Sample Number</b>	<b>Sample Location</b>	<b>Sample Volume (L)</b>	<b>Total Fungi Concentration (Counts/m<sup>3</sup>)</b>
JFDES-1	Health Room	75.0	2,990
JFDES-2	Main Office	75.0	2,200
JFDES-3	Multipurpose Room	75.0	1,850
JFDES-4	Classroom 15	75.0	800
JFDES-5	Library	75.0	90
JFDES-6	Classroom 5	75.0	1,330
JFDES-7	Classroom 9	75.0	200
JFDES-8	Classroom 4	75.0	850
JFDES-9	Classroom 17	75.0	1,390
JFDES-10	Lobby	75.0	2,590
BG-1	Background (Outdoors)	75.0	15,060

\* Numbers highlighted in red indicates locations where the concentrations of mold spores exceeded the concentration of mold spores detected in the background sample.



**TIDEWATER** INC

ENGINEERS / SCIENTISTS / PROGRAM MANAGERS

## **Attachment B**

# **Laboratory Reports for Non-Viable Spore Trap Mold Sampling**



# EMSL Analytical, Inc.

528 Mineola Avenue Carle Place, NY 11514  
 Phone/Fax: (516) 997-7251 / (516) 997-7528  
<http://www.EMSL.com> / [carleplacelab@emsl.com](mailto:carleplacelab@emsl.com)

Order ID: 061909477  
 Customer ID: TIDE50  
 Customer PO:  
 Project ID:

**Attn:** Skanda Abeyeskere  
 Tidewater, Inc.  
 6625 Selnick Drive  
 Suite A  
 Elkridge, MD 21075

Phone: (410) 540-8700  
 Fax: (410) 997-8713  
 Collected: 05/16/2019  
 Received: 05/18/2019  
 Analyzed: 05/21/2019

**Proj:** PGCPs J. Frank Dent ES, MD 5419-003

**Test Report: Allergenco-D™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)**

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	061909477-0001 JEDES-1 75 Heath Room			061909477-0002 JEDES-2 75 Main Office			061909477-0003 JEDES-3 75 Cafeteria		
Spore Types	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	1	40	1.8	-	-	-
Ascospores	3	100	3.3	5	200	9.1	-	-	-
Aspergillus/Penicillium	-	-	-	-	-	-	1	40	2.2
Basidiospores	62	2700	90.3	43	1900	86.4	40	1700	91.9
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	3	100	3.3	1	40	1.8	2	90	4.9
Curvularia	-	-	-	1*	10*	0.5	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	2	90	3	1*	10*	0.5	1*	10*	0.5
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Oidium	-	-	-	-	-	-	-	-	-
Triadelphia	-	-	-	-	-	-	1*	10*	0.5
<b>Total Fungi</b>	<b>70</b>	<b>2990</b>	<b>100</b>	<b>52</b>	<b>2200</b>	<b>100</b>	<b>45</b>	<b>1850</b>	<b>100</b>
Hyphal Fragment	-	-	-	-	-	-	1*	10*	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	2	-	-	2	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	2	-	-	2	-	-	2	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Jeffrey Lau, Microbiology Laboratory Manager  
 or Other Approved Signatory

No discernable field blank was submitted with this group of samples.

Samples received in good condition unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "\*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. The report reflects the samples as received. When the information supplied by the customer can affect the validity of the result, it will be noted on the report.

Initial report from: 05/22/2019 12:22:17

For Information on the fungi listed in this report please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

528 Mineola Avenue Carle Place, NY 11514  
Phone/Fax: (516) 997-7251 / (516) 997-7528  
<http://www.EMSL.com> / [carleplacelab@emsl.com](mailto:carleplacelab@emsl.com)

Order ID: 061909477  
Customer ID: TIDE50  
Customer PO:  
Project ID:

**Attn:** Skanda Abeyeskere  
Tidewater, Inc.  
6625 Selnick Drive  
Suite A  
Elkridge, MD 21075

**Phone:** (410) 540-8700  
**Fax:** (410) 997-8713  
**Collected:** 05/16/2019  
**Received:** 05/18/2019  
**Analyzed:** 05/21/2019

**Proj:** PGCPs J. Frank Dent ES, MD 5419-003

### Test Report: Allergenco-D™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	061909477-0004			061909477-0005			061909477-0006		
Client Sample ID:	JEDES-4			JEDES-5			JEDES-6		
Volume (L):	75			75			75		
Sample Location:	Classroom 15			Library			Classroom 5		
Spore Types	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	5	200	15
Aspergillus/Penicillium	2	90	11.3	-	-	-	2	90	6.8
Basidiospores	15	660	82.5	2	90	100	24	1000	75.2
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	-	-	-	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	1	40	5	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	1*	10*	1.3	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Oidium	-	-	-	-	-	-	1	40	3
Triadelphia	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>19</b>	<b>800</b>	<b>100</b>	<b>2</b>	<b>90</b>	<b>100</b>	<b>32</b>	<b>1330</b>	<b>100</b>
Hyphal Fragment	3*	40*	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	2*	30*	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	2	-	-	2	-	-	2	-
Fibrous Particulate (1-4)	-	2	-	-	2	-	-	1	-
Background (1-5)	-	2	-	-	2	-	-	2	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Jeffrey Lau, Microbiology Laboratory Manager  
or Other Approved Signatory

No discernable field blank was submitted with this group of samples.

Samples received in good condition unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "\*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. The report reflects the samples as received. When the information supplied by the customer can affect the validity of the result, it will be noted on the report.

Initial report from: 05/22/2019 12:22:17

For Information on the fungi listed in this report please visit the Resources section at [www.emsl.com](http://www.emsl.com)





# EMSL Analytical, Inc.

528 Mineola Avenue Carle Place, NY 11514  
 Phone/Fax: (516) 997-7251 / (516) 997-7528  
<http://www.EMSL.com> / [carleplacelab@emsl.com](mailto:carleplacelab@emsl.com)

Order ID: 061909477  
 Customer ID: TIDE50  
 Customer PO:  
 Project ID:

**Attn:** Skanda Abeyeskere  
 Tidewater, Inc.  
 6625 Selnick Drive  
 Suite A  
 Elkridge, MD 21075

Phone: (410) 540-8700  
 Fax: (410) 997-8713  
 Collected: 05/16/2019  
 Received: 05/18/2019  
 Analyzed: 05/21/2019

**Proj:** PGCPs J. Frank Dent ES, MD 5419-003

**Test Report: Allergenco-D™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)**

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	061909477-0007 JEDES-7 75 Classroom 9			061909477-0008 JEDES-8 75 Classroom 4			061909477-0009 JEDES-9 75 Classroom 17		
Spore Types	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	1	40	4.7	2	90	6.5
Aspergillus/Penicillium	-	-	-	4	200	23.5	1	40	2.9
Basidiospores	5	200	100	13	570	67.1	21	920	66.2
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	1	40	4.7	7	300	21.6
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	1	40	2.9
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Oidium	-	-	-	-	-	-	-	-	-
Triadelphia	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>5</b>	<b>200</b>	<b>100</b>	<b>19</b>	<b>850</b>	<b>100</b>	<b>32</b>	<b>1390</b>	<b>100</b>
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	1	40	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	2	-	-	2	-	-	2	-
Fibrous Particulate (1-4)	-	2	-	-	1	-	-	2	-
Background (1-5)	-	2	-	-	2	-	-	2	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Jeffrey Lau, Microbiology Laboratory Manager  
 or Other Approved Signatory

No discernable field blank was submitted with this group of samples.

Samples received in good condition unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "\*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. The report reflects the samples as received. When the information supplied by the customer can affect the validity of the result, it will be noted on the report.

Initial report from: 05/22/2019 12:22:17

For Information on the fungi listed in this report please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

528 Mineola Avenue Carle Place, NY 11514  
 Phone/Fax: (516) 997-7251 / (516) 997-7528  
<http://www.EMSL.com> / [carleplacelab@emsl.com](mailto:carleplacelab@emsl.com)

Order ID: 061909477  
 Customer ID: TIDE50  
 Customer PO:  
 Project ID:

**Attn:** Skanda Abeyeskere  
 Tidewater, Inc.  
 6625 Selnick Drive  
 Suite A  
 Elkridge, MD 21075

**Phone:** (410) 540-8700  
**Fax:** (410) 997-8713  
**Collected:** 05/16/2019  
**Received:** 05/18/2019  
**Analyzed:** 05/21/2019

**Proj:** PGCPs J. Frank Dent ES, MD 5419-003

**Test Report: Allergenco-D™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)**

Lab Sample Number:	061909477-0010			061909477-0011			
Client Sample ID:	JEDES-10			BG-1			
Volume (L):	75			75			
Sample Location:	Lobby			Background			
Spore Types	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total	
Alternaria (Ulocladium)	-	-	-	-	-	-	-
Ascospores	2	90	3.5	21	920	6.1	-
Aspergillus/Penicillium	16	700	27	5	200	1.3	-
Basidiospores	36	1600	61.8	319	13900	92.3	-
Bipolaris++	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-
Cladosporium	4	200	7.7	1	40	0.3	-
Curvularia	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-
Oidium	-	-	-	-	-	-	-
Triadelphia	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>58</b>	<b>2590</b>	<b>100</b>	<b>346</b>	<b>15060</b>	<b>100</b>	-
Hyphal Fragment	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-
Pollen	-	-	-	2	90	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	2	-	-	1	-	-
Fibrous Particulate (1-4)	-	2	-	-	1	-	-
Background (1-5)	-	2	-	-	1	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Jeffrey Lau, Microbiology Laboratory Manager  
 or Other Approved Signatory

No discernable field blank was submitted with this group of samples.

Samples received in good condition unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "\*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. The report reflects the samples as received. When the information supplied by the customer can affect the validity of the result, it will be noted on the report.

Initial report from: 05/22/2019 12:22:17

For Information on the fungi listed in this report please visit the Resources section at [www.emsl.com](http://www.emsl.com)

# Microbiology Chain of Custody

EMSL Order Number (Lab Use Only):

061909477

PHONE:  
FAX:

Company: Tidewater Inc.		EMSL-Bill to: <input type="checkbox"/> Different <input type="checkbox"/> Same <small>If Bill to is Different note instructions in Comments**</small>	
Street: 6625 Slenick Drive, Suite A		<i>Third Party Billing requires written authorization from third party</i>	
City: Elkridge	State/Province: Maryland	Zip/Postal Code:	Country:
Report To (Name): Skanda Abeyesekere		Telephone #:	
Email Address: skanda@tideh2o.net		Fax #:	Purchase Order:
Project Name/Number: PGPCS J. Frank Dent ES	Please Provide Results: <input type="checkbox"/> FAX <input type="checkbox"/> E-mail <input type="checkbox"/> Mail		
U.S. State Samples Taken: MD 5419-003	Connecticut Samples: <input type="checkbox"/> Commercial <input type="checkbox"/> Residential		

**Turnaround Time (TAT) Options\* - Please Check**

3 Hour  6 Hour  24 Hour  48 Hour  72 Hour  96 Hour  1 Week  2 Week

\*Analysis completed in accordance with EMSL's Terms and Conditions located in the Analytical Price Guide. TATs are subject to methodology requirements

**Non Culturable Air Samples (Spore Traps) - Test Codes**

- |                   |                   |                    |                     |                   |
|-------------------|-------------------|--------------------|---------------------|-------------------|
| • M001 Air-O-Cell | • M173 Allegro M2 | • M004 Allergenco  | • M032 Allergenco-D | • M172 Versa Trap |
| • M049 BioSIS     | • M003 Burkard    | • M043 Cyclcx      | • M002 Cyclcx-d     |                   |
| • M030 Micro 5    | • M174 MoldSnap   | • M176 Relle Smart | • M130 Via-Cell     |                   |

**Other Microbiology Test Codes**

- |  |   |  |
|--|---|--|
| • M041 Fungal Direct Examination                 | • M014 Endotoxin Analysis                               | • M029 Enterococci                                     |
| • M005 Viable Fungi ID and Count                 | • M015 Heterotrophic Plate Count                        | • M019 Fecal Coliform                                  |
| • M006 Viable Fungi ID and Count (Speciation)    | • M180 Real Time Q-PCR-ERMI 36                          | • M133 MRSA Analysis                                   |
| • M007 Culturable Fungi                          | • Panel   | • M028 <i>Cryptococcus neoformans</i> Detection        |
| • M008 Culturable Fungi (Speciation)             | • M018 Total Coliform (Membrane Filtration)             | • M120 <i>Histoplasma capsulatum</i> Detection         |
| • M009 Gram Stain Culturable Bacteria            | • M020 Fecal <i>Streptococcus</i> (Membrane Filtration) | • M033-39 Allergen Testing                             |
| • M010 Bacterial Count and ID - 3 Most Prominent | • M210-215 <i>Legionella</i> Detection                  | • M044 Group-Allergen (Cat, Dog, Cockroach, Dustmites) |
| • M011 Bacterial Count and ID - 5 Most Prominent | • M026 Recreational Water Screen                        | • Other See Analytical Price Guide                     |
| • M013 Sewage Contamination in Buildings         | • M027 Mycotoxin Analysis                               |  |

Preservation Method (Water):

Name of Sampler: <b>SKANDA ABEYESEKERE</b>	Signature of Sampler:
--	-----------------------

Sample #	Sample Location	Sample Type	Test Code	Volume/Area	Date/Time Collected
Example: A1	Kitchen	Air	M001	75L	1/1/12 4:00 PM
JFDES-1	Heath Room	AIR	M032	75.0L	05/16/19
JFDES-2	main office	↓	↓	↓	↓
JFDES-3	Multi Cafeteria				
JFDES-4	CLASSROOM 15				
JFDES-5	Library				
JFDES-6	CLASSROOM 15				
JFDES-7	CLASSROOM 9				
JFDES-8	CLASSROOM 4				
JFDES-9	CLASSROOM 17				

Client Sample # (s): 11	Total # of Samples: 11
Relinquished (Client):	Date: 05/16/19 Time: 12:00 PM
Received (Client):  Fed Ex	Date: 5/17/19 Time: 10:15 AM
Comments:	

Rec'd 5/18/19 @ 11:53 AM

5/21/19





**TIDEWATER** INC

**ENGINEERS / SCIENTISTS / PROGRAM MANAGERS**

**Attachment C**

**Calibration Certificates**



### IAQ Meter Calibration Certificate

<b>Cal Standard</b>	<b>Lot #</b>	<b>Expiration</b>
	18-6508	4/18/2020

<b>Carbon Monoxide Gas</b>	<b>Reading ppm</b>	<b>Acceptable Range</b>
35 ppm ▼	35.0	(32 - 38) ▼

<b>Carbon Dioxide Gas</b>	<b>Reading ppm</b>	<b>Acceptable Range</b>
1000 ppm ▼	1008.0	(950 - 1050) ▼

<b>Model</b>	TSI Q-Trak 7565 ▼
<b>S/N</b>	7565x0931002
<b>Barcode</b>	u59038x
<b>Order #</b>	398188

Calibrated By Bryce Spontak ▼

Date of Calibration 05/16/19

All calibrations performed by FEI conform to manufacturer's specifications. Please report any issues within 24 hours of receiving equipment.

All calibration gas used is traceable to NIST. Additional documentation is available upon request.




# CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA  
 Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 <http://www.tsi.com>

Environment Conditions			Model	<b>8534</b>
Temperature	76.6 (24.8)	°F (°C)	Serial Number	<b>8534170101</b>
Relative Humidity	24	%RH		
Barometric Pressure	29.14 (986.8)	inHg (hPa)		

- |  |  |
|--|--|
| <input type="checkbox"/> As Left             | <input type="checkbox"/> In Tolerance                |
| <input checked="" type="checkbox"/> As Found | <input checked="" type="checkbox"/> Out of Tolerance |



FLOW AND PRESSURE VERIFICATION				SYSTEM DTII01-02			
Parameter	Standard	Measured	Allowable Range	Parameter	Standard	Measured	Allowable Range
Flow lpm	3.0	3.0	2.85 ~ 3.15	Pressure kPa	98.6	98.6	93.71 ~ 103.57

Pump run time: 25 Hours, Pump voltage: 433 Bits

*TSI Incorporated does hereby certify that all materials, components, and workmanship used in the manufacture of this equipment are in strict accordance with the applicable specifications agreed upon by TSI and the customer and with all published specifications. All performance and acceptance tests required under this contract were successfully conducted according to required specifications. There is no NIST standard for optical mass measurements. Calibration of this instrument performed by TSI has been done using emery oil and has been nominally adjusted to respirable mass per standard ISO 12103-1, A1 test dust (Arizona dust). Our calibration ratio is greater than 1.2:1*

Measurement Variable	System ID	Last Cal.	Cal. Due	Measurement Variable	System ID	Last Cal.	Cal. Due
Temp/Humidity	E005409	10-19-17	10-31-18	Temp/Humidity	E005410	10-19-17	10-31-18
DC Voltage	E003314	05-03-17	05-31-18	DC Voltage	E003315	05-03-17	05-31-18
Photometer	E003319	01-09-18	07-31-18	Microbalance	M001324	11-02-16	11-30-18
1 um PSL	679755	n/a	n/a	3 um PSL	180387	n/a	n/a
10 um PSL	167947	n/a	n/a	Pressure	E003511	10-02-17	10-31-18
Flowmeter	E002471	04-20-17	04-30-18				

\_\_\_\_\_  
 Verified

March 1, 2018  
 \_\_\_\_\_  
 Date



# INSTRUMENT CALIBRATION REPORT

Pine Environmental Services, LLC.

## Tidewater MD

**Instrument ID** 110-010833  
**Description** MINIRAE 2000  
**Calibrated** 4/9/2019

**Manufacturer** Rae Systems  
**Model Number** MINIRAE 2000  
**Serial Number** 110-010833  
**Location** Maryland  
**Department** CATHY MOORE

**Frequency** 6 Months  
**Status** Pass  
**Temp** 24  
**Humidity** 39

### Calibration Specifications

**Group #** 1  
**Group Name** ISOBUTYLENE  
**Stated Accy** Pct of Reading

**Range Acc %** 0.0000  
**Reading Acc %** 3.0000  
**Plus/Minus** 0.00

<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>Fnd As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
100.00 / 100.00	ppm	100.00	ppm	92.80	101.00	1.00%	Pass

### Test Instruments Used During the Calibration

(As Of Cal Entry Date)

<u>Test Instrument ID</u>	<u>Description</u>	<u>Manufacturer</u>	<u>Model Number</u>	<u>Serial Number / Lot Number</u>	<u>Last Cal Date</u>	<u>Next Cal Date / Expiration Date</u>
MD ISO 100PPM FBI-248-100-12	MD ISO 100PPM	Pine Environmental Services, Inc.		34LS-248-100	5/23/2022	
MD ZERO AIR FBI-1-25	ZERO AIR Oxygen 20.9%VOL, Nitrogen Balance	Pine Environmental Services, Inc.	31844	FBI-1-25		

### Notes about this calibration

**Calibration Result** Calibration Successful  
**Who Calibrated** Ryan Armstrong

Pine Environmental Services, LLC. hereby certifies that this instrument is calibrated and functions to meet the manufacturer's specifications using NIST traceable standards, or is derived from accepted values of physical constants.



# Certificate of Conformance

Buck BioAire™

Buck BioSlide™

Serial number: B153043 Date Issued: 2-6-19

## Flow Calibration

The instrument listed above is in conformance with factory specifications and the flow is set to nominal using a BUCK Calibrator which is N.I.S.T. traceable to A. P. Buck, Inc. Calibration Procedure APB-1, Ver. 6.2.

**QA APPROVAL BY:** Thomas J. Gorenover

Information contained in this document should not be reproduced in any form without the written consent of A.P. Buck Inc. It is for reference only and cannot be used as a form of endorsement by any private or governmental regulatory body.

A.P. BUCK, INC.  
7101 Presidents Drive, Suite 110  
Orlando, FL 32809  
Phone: 407-851-8602 • Fax: 407-851-8910

**BUCK**  
A.P. BUCK, INC.

COCR-004 REV-01 3/3/2006




**TIDEWATER** INC

**ENGINEERS / SCIENTISTS / PROGRAM MANAGERS**

**Attachment D**

**Qualifications**



**american board of industrial hygiene®**

organized to improve the practice of industrial hygiene  
proclaims that

*Skandakumar Harshanath Abeyesekere*

having met all requirements of  
education, experience and examination, and  
ongoing maintenance,  
is hereby certified in the

**COMPREHENSIVE PRACTICE  
of  
INDUSTRIAL HYGIENE**

and has the right to use the designations

**CERTIFIED INDUSTRIAL HYGIENIST**


**CIH**

Certificate Number	9928 CP
Awarded:	May 11, 2011
Expiration Date:	December 1, 2021



*Susan Ripple*  
Chair, ABIH

*William K. Oliver*  
Chief Executive Officer, ABIH



# BOARD OF CERTIFIED SAFETY PROFESSIONALS

affirms that

## Skandakumar Abeyesekere

Has applied for, met qualifications, and passed required examination(s) and is hereby authorized to use the designation

### Certified Safety Professional® in Comprehensive Practice

So long as this certificate is not suspended or revoked and the certificant renews this authorization annually and meets Continuance of Certification requirements.

Board of Examiners in witness whereof we have here unto set our hands and affixed the Seal of the Board this 7th Day of April, 2008



<i>Paul S Adams</i>	President
<i>Linda Japp</i>	Secretary
20110	CSP No.



THIS CERTIFIES THAT

*Skandakumar Abeyeskere*

HAS SUCCESSFULLY MET ALL THE REQUIREMENTS OF EDUCATION, EXPERIENCE AND EXAMINATION, AND IS HEREBY DESIGNATED A

**CERTIFIED HAZARDOUS MATERIALS MANAGER  
CHMM**



May 13, 2016

DATE OF CERTIFICATION

19053

CREDENTIAL NUMBER

May 31, 2021

CERTIFICATION EXPIRES

*M. Patricia Buley*  
ACTING EXECUTIVE DIRECTOR

VALID SO LONG AS THIS CREDENTIAL IS RENEWED ACCORDING TO SCHEDULE AND IS NOT OTHERWISE REVOKED.



Accredited by the American National Standards Institute and the Council of Engineering and Scientific Specialty Boards







**TIDEWATER** INC

ENGINEERS / SCIENTISTS / PROGRAM MANAGERS

## **Attachment E**

### **Floor Plan with Sampling Locations**



	<b>Attachment C</b> <b>J. Frank Dent Elementary School</b> <b>Floor Plan with Sampling Locations</b>	<p>General Notes</p> <p>Scale: N/A</p> <p>Project #: 5419-003 Date: May 16, 2019</p> <p>▲ Sample Location</p>
---	--	---