



4221 Forbes Boulevard · Suite 250
Lanham, Maryland 20706
T: 202.558.7487 | <http://atiinc.com/>

June 19, 2019

Prince George's County Public Schools
13300 Old Marlboro Pike
Upper Marlboro, Maryland 20772
Attention: Mr. Alex Baylor

RE: Indoor Air Quality Screening, Robert Goddard Montessori School
IFB: 022-19
ATI Project Number: ATI19-687

Dear Mr. Baylor:

Prince George's County Public Schools requested that ATI, Inc., conduct a proactive indoor air quality (IAQ) screening at Robert Goddard Montessori School. The IAQ screening was conducted on May 30, 2019. Its key findings are enclosed in the Executive Summary on page three, and the official laboratory report for total fungal spore trap sampling is enclosed in Appendix A.

Thank you for the opportunity to provide Industrial Hygiene services for Prince George's County Public Schools. If you have any questions regarding this report, please contact us at (202) 643-4283.

Sincerely,
ATI, INC.

Courtney E. McCall
Project Manager

Sarath Seneviratne
CIH, CSP, CHMM

Indoor Air Quality Screening Report



Prince George's County Public Schools
Robert Goddard Montessori School
9850 Good Luck Road
Seabrook, Maryland 20706

Prepared for:

Prince George's County Public Schools
13300 Old Marlboro Pike
Upper Marlboro, Maryland 20772

June 19, 2019

Submitted by:

The logo for ATI, consisting of the lowercase letters "ati" in a bold, blue, serif font.

ATI Job # 19-687

Intentionally Blank

Table of Contents

1. Executive Summary and Key Findings 3

2. Assessment Methods..... 3

3. Visual Observations 4

4. Thermal Environmental Conditions for Human Occupancy 5

 4.1 Temperature..... 5

 4.2 Relative Humidity 6

 4.3 Carbon Dioxide 6

 4.4 Carbon Monoxide..... 7

5. Total Fungal Air Sampling Results..... 8

6. Summary of Findings..... 9

Table 1: Visual Observations and Sampling Locations 4

Table 2: Temperature Measurements..... 5

Table 3: Relative Humidity Measurements 6

Table 4: Carbon Dioxide Measurements 7

Table 5: Carbon Monoxide Measurements 7

Appendix A: Laboratory Report and Chain of Custody
Appendix B: Instrument Calibration Records



Abbreviations and Acronyms

AHU	Air-Handling Unit
AIHA	American Industrial Hygiene Association
ASHRAE	American Society of Heating, Refrigerating and Air-Conditioning Engineers
ASTM	American Society for Testing and Materials
CO	Carbon Monoxide
CO₂	Carbon Dioxide
EMLAP	Environmental Microbiology Laboratory Accreditation Program
HVAC	Heating, Ventilating, And Air-Conditioning
IAQ	Indoor Air Quality
NIST	National Institute for Standards and Technology
NVLAP	National Voluntary Laboratory Accreditation Program
RH	Relative Humidity

Abbreviations involving scientific volume and measurements involving media or water sampling

Counts/m³	Mold spores per cubic meter of air
LPM	Liters Per Minute
NTE	Not to exceed
°F	degree Fahrenheit
PPM	Parts Per Million

1. Executive Summary and Key Findings

ATI conducted a proactive Indoor Air Quality (IAQ) screening on May 30, 2019, at Robert Goddard Montessori School, located at 9850 Good Luck Road, Seabrook, MD 20706.

The screening included a visual assessment of randomly selected classrooms and other frequently occupied spaces, such as the main office and classrooms for potential IAQ contributors and pathways. As part of the screening, ATI collected direct reading measurements for comfort parameters, including temperature, relative humidity, carbon dioxide, and carbon monoxide. Also, ATI collected total fungal air samples on spore trap cassettes for microbiological analysis.

The following is a summary of the key findings from this screening:

1. Two tested locations were cooler than the ASHRAE guidelines for summer temperatures, 73°F and 79°F.
2. Relative humidity measurements were within ASHRAE guidelines, < 65%.
3. Three tested spaces exceeded the recommended ASHRAE limit for carbon dioxide, which was 978 parts per million (PPM) for the day.
4. Carbon monoxide was not detected throughout the tested spaces.
5. Total spore concentrations detected outdoors were 43,930 counts/m³, and no indoor location had total counts that met or exceeded this concentration, which is favorable. Cladosporium was slightly elevated over the outdoor sample in Rooms 107 and 117. Room 107 also had a plant present that likely contributed to the findings because Cladosporium spores can often be found in potting soil. These slight elevations in Cladosporium do not pose a concern. Slight elevations of Aspergillus/Penicillium indoors are not remarkable.

2. Assessment Methods

Ms. Mikal Frater of ATI, Inc. conducted a visual assessment and air sampling on May 30, 2019. Sampled rooms were randomly selected and accounted for approximately 10% of classrooms or a minimum of five samples. Visual observations were made at the time the samples were collected. ATI references the American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) *Standard 62.1 – 2016* and *ASHRAE Standard 55 – 2017* when providing IAQ services to clients. ASHRAE is an industry leader on energy efficiency and indoor air quality.

All measurements and air samples were collected between three-six feet from floor elevation, which represents the breathing zone, and away from air-supply and return diffusers. Real-time direct readings for temperature, relative humidity, carbon dioxide (CO₂), and carbon monoxide (CO), were obtained with a calibrated TSI Q-Trak 7575-X Meter and attached 982 Probe.

Total fungal air samples were collected with a Buck BioAire High-Volume Sampling Pump on Zefon Air-O-Cell spore-trap cassettes at a flow rate of 15 liters per minute for five minutes, for a sample volume of 75 liters. The samples were analyzed by direct microscopic examination (identifies and counts both viable and non-viable spores, which is then considered “total fungal”), via the American Society for Testing and Materials (ASTM) Standard D7391-09 by EMSL Analytical, Inc., (EMSL) located in Beltsville, MD.

EMSL participates in the National Institute of Standards and Technology’s (NIST’s) National Voluntary Laboratory Accreditation Program (NVLAP) for general laboratory performance and management and the American Industrial Hygiene Association (AIHA) Environmental Microbial Laboratory Accreditation Program (EMLAP, Certificate Number 102891).

Instrument calibration records are included in Appendix B of this report.

3. Visual Observations

Table 1: Visual Observations and Sampling Locations

Sample Location	Observations
Outside	<ul style="list-style-type: none"> • No traffic – foot or vehicle. • Partly cloudy skies, light winds. • Parking lot is surrounded by trees/grass.
Main Office	<ul style="list-style-type: none"> • One large diffuser. • Plants on cabinet and tabletop. • Four occupants in area during sampling. • Oscillating fan in room – OFF. • Light foot traffic. • Printer/fax is 15-20 ft. from sampling. • Unit along baseboard of room – heat? • Space is approximately 470 ft.²
Room 107	<ul style="list-style-type: none"> • One air return. • Many plants in area. • Friedrich A/C – older model. • History of leak from upstairs sink (time period: 5 years ago – 2 years ago). Leak is localized. • Light brown stained ceiling tiles where leak took place. • No hot water in room. • Staff concerns of mold. There has been a history of mildew on sink pipes. Not seen. • Space is approximately 1,280 ft.²
Room 117	<ul style="list-style-type: none"> • One air return. • One occupant in area during sampling. • Air smells/feels stuffy. • Door to adjacent classroom open. • Friedrich A/C – OFF • No stained ceiling tiles or visible growth. • Space is approximately 1,280 ft.²
Room 217	<ul style="list-style-type: none"> • One air return. • One old wall unit with a light dirt load. • Friedrich A/C older model – OFF. • Light brown stained ceiling tile, indicative of a past leak. • Cleaning products and air freshener scattered around room.

Sample Location	Observations
	<ul style="list-style-type: none"> • 25 occupants in area during sampling. • Space is approximately 780 ft.²
Room 207	<ul style="list-style-type: none"> • Four air diffusers. • Space is approximately 1,218 ft.² • Cluttered room. • Two occupants in area during sampling. • Sitting water in sink. • A/C on and felt throughout the room. Friedrich older model A/C.

4. Thermal Environmental Conditions for Human Occupancy

ASHRAE Standard 55-2017, *Thermal Environmental Conditions for Human Occupancy*, addresses thermal comfort in an office environment, which means that an employee wearing a normal amount of clothing feels neither too cold nor too warm. This standard discusses thermal comfort within the context of air temperature, humidity, and air movement and provides recommended ranges for temperature and humidity that are intended to satisfy most building occupants. The recommended ASHRAE ranges are referenced below by each comfort parameter.

4.1 Temperature

The ASHRAE standard establishes a winter comfort range of between 68°F and 75°F and a summer range of between 73°F and 79°F. The temperature measurements obtained during the May 30, 2019, screening are summarized in Table 2. As indicated by the data in the table, temperatures in the school averaged between 70.7 – 78.1°F, with two locations, Rooms 107 and 207, falling slightly below the ASHRAE recommended summer comfort range.

Table 2: Temperature Measurements

Sample Location	May 30, 2019 °F			ASHRAE Standard °F
	Min	Max	Average	
Outside	88.4	88.6	88.5	N/A
Indoors				
Main Office	77.5	78.7	78.1	73 – 79
Room 107	72.6	72.8	72.7	73 – 79
Room 117	75.1	75.3	75.2	73 – 79
Room 217	75.7	75.9	75.8	73 – 79
Room 207	70.4	71.0	70.7	73 – 79

4.2 Relative Humidity

Relative humidity is a key factor for mold growth. Mold has the potential of growing on suitable surfaces with humidity levels above 65%. ASHRAE *Standard 62.1-2016, Ventilation for Acceptable Indoor Air Quality*, recommends a maximum indoor relative humidity of 65% to prevent condensation of moisture on surfaces. Relative humidity below 30% may result in drying of the mucous membranes and skin. Relative humidity measurements are summarized in Table 3. As indicated by the data in the table, relative humidity measurements averaged between 41.0% and 57.1%, below the ASHRAE maximum recommendation of 65% relative humidity.

Table 3: Relative Humidity Measurements

Sample Location	May 30, 2019 (%)			ASHRAE Standard (% RH)
	Min	Max	Average	
Outside	42.5	44.3	13.4	N/A
Inside				
Main Office	39.8	41.6	42.05	< 65
Room 107	45.2	48.8	47.0	< 65
Room 117	56.6	57.6	57.1	< 65
Room 217	40.9	41.1	41.0	< 65
Room 207	45.6	47.0	46.3	< 65

4.3 Carbon Dioxide

Carbon dioxide measurements within an occupied building are a standard method used to gauge the efficiency of ventilation systems. Carbon dioxide is a by-product of human respiration and does not pose an acute health hazard alone. Elevated concentrations may suggest that insufficient fresh air is being supplied to an occupied space and/or that the ventilation system does not provide a sufficient rate of air exchange.

Research has indicated that buildings with adequately operating ventilation systems are able to remove odors generated by activities in an indoor office environment efficiently. ASHRAE *Standard 62.1-2016* states that comfort (odor) criteria with respect to human bioeffluents are likely to be satisfied if the ventilation results indoor carbon dioxide concentrations are less than 700 parts per million (ppm) above the outdoor air concentration.

Carbon dioxide measurements are summarized in Table 4. On the day of the screening, the average outdoor carbon dioxide concentration obtained was 278 ppm, which calculates to a maximum indoor concentration of 978 ppm (700 + 278). The carbon dioxide levels inside the school ranged from the average minimum detected, 394 ppm to 1,841.5 ppm, the average maximum detected, with three locations, Rooms 107, 117 and 207, exceeding the ASHRAE maximum recommended concentration of 978 ppm.

Table 4: Carbon Dioxide Measurements

Sample Location	May 30, 2019 Concentration (parts per million)			ASHRAE Standard (ppm)
	Min	Max	Average	
Outside	278	278	278	N/A
Inside				
Main Office	394	394	394	978
Room 107	1,640	1,652	1,646	978
Room 117	1,687	1,699	1,693	978
Room 217	509	511	510	978
Room 207	1,838	1,845	1,841.5	978

4.4 Carbon Monoxide

Carbon monoxide is a colorless and odorless gas produced by the incomplete combustion of carbon containing fuels. Oil, gasoline, diesel fuels, wood, coke, and coal are the major sources of carbon monoxide. ASHRAE recommends that carbon monoxide not exceed nine ppm indoors. As indicated by the data in Table 5, carbon monoxide was not detected throughout the school.

Table 5: Carbon Monoxide Measurements

Sample Location	May 30, 2019 Concentration (parts per million)			ASHRAE Standard (ppm)
	Min	Max	Average	
Outside	0	0	0	N/A
Inside				
Main Office	0	0	0	< 9
Room 107	0	0	0	< 9
Room 117	0	0	0	< 9
Room 217	0	0	0	< 9
Room 207	0	0	0	< 9

5. Total Fungal Air Sampling Results

Mold needs a food source, moisture, proper temperature and humidity, and at times, a source of light, to grow in an environment. Air infiltration through building entrances and exits, open windows and loading docks, and foot traffic into buildings, including the HVAC system all serve as primary pathways that can carry fungi indoors. Water leaks and humid conditions inside of buildings provide the moisture that fosters mold growth. The May 30, 2019 mold screening sampled air using spore trap cassettes in randomly selected classrooms and other areas throughout the facility. These cassettes collect both viable spores, those capable of producing more fungal colonies, and non-viable spores, which cannot reproduce. Based upon recognized industry practices, indoor mold concentrations are compared with those detected outdoors, which are also known as ambient or baseline samples.

In normal circumstances, the diversity of spores identified indoors and outdoors should be similar with some exceptions. The high concentration of one or two species of fungal spores identified indoors and the absence of the same species outdoors can indicate a moisture problem with the potential to degrade the air quality. Fungi species present indoors are typically found at levels ranging from approximately 10-50% of their levels in the outdoor air, reflecting the filtering by the building's HVAC system.

The official laboratory report with spore trap samples collected on May 30, 2019, is presented in Appendix A. Total spore concentrations detected outdoors were 43,930 counts/m³, and no indoor location had total counts that met or exceeded this concentration.

Ascospores, Basidiospores and Cladosporium had the highest concentrations. These three spore types are commonly found indoors. Each are known to cause allergies yet are not associated with water damaged materials in buildings. Ascospores and Basidiospores were not detected higher indoors than in the outdoor sample. Cladosporium was slightly elevated over the outdoor sample in Rooms 107 and 117. Room 107 also had a plant present, and Cladosporium spores can often be found in potting soil. These slight elevations in Cladosporium do not pose a concern.

Aspergillus/Penicillium, which is also known to cause allergies, was detected indoors in two locations in rather low concentrations that exceeded detection levels outdoors. These concentrations are not remarkable and do not pose a concern.

6. Summary of Findings

Two locations fell below the ASHRAE summer temperature guidelines, between 73-79°F. Relative humidity measurements were within ASHRAE guidelines, <65%. Three tested locations exceeded the ASHRAE limit for carbon dioxide, which was 978 parts per million (PPM). Carbon monoxide was not detected throughout the tested spaces.

Total spore concentrations detected outdoors were 43,930 counts/m³, and no indoor location had total counts that met or exceeded this concentration, which is favorable. Cladosporium was slightly elevated over the outdoor sample in Rooms 107 and 117. Room 107 also had a plant present that likely contributed to the findings because Cladosporium spores can often be found in potting soil. These slight elevations in Cladosporium do not pose a concern. Slight elevations of Aspergillus/Penicillium indoors are not remarkable.

We appreciate the opportunity to provide these IAQ testing services for you. If you have any questions, please contact us at (202) 643-4283.

Sincerely,
ATI, INC.



Courtney E. McCall
Project Manager



Sarath Seneviratne
CIH, CSP, CHMM

**Appendix A:
Laboratory Report and Chain of Custody**



EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

<http://www.EMSL.com> / beltsvillelab@emsl.com

EMSL Order: 191906416

Customer ID: ATII25A

Customer PO:

Project ID:

Attn: Courtney McCall

ATI

4221 Forbes Blvd

Suite 250

Lanham, MD 20706

Project: 19-687-PGCPs-ROBERT GODDARD MONTOSSORI

Phone: (202) 832-1433

Fax:

Collected: 05/30/2019

Received: 05/30/2019

Analyzed: 06/06/2019

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location	191906416-0001 19-687-01 75 OUTSIDE PARKING LOT			191906416-0002 19-687-02 FIELD BLANK			191906416-0003 19-687-03 75 MAIN OFFICE		
Spore Types	Raw Count	Count/m ³	% of Total	Raw Count	Count/m ³	% of Total	Raw Count	Count/m ³	% of Total
Alternaria (Ulocladium)	1*	10*	0	-	-	-	-	-	-
Ascospores	90	3900	8.9	-	-	-	2	90	20.5
Aspergillus/Penicillium	1	40	0.1	-	-	-	-	-	-
Basidiospores	886	38700	88.1	-	-	-	7	300	68.2
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	25	1100	2.5	-	-	-	1	40	9.1
Curvularia	1*	10*	0	-	-	-	-	-	-
Epicoccum	2	90	0.2	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	1	40	0.1	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	1*	10*	2.3
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Arthrimum	-	-	-	-	-	-	-	-	-
Bispora	-	-	-	-	-	-	-	-	-
Gonatotryum	1	40	0.1	-	-	-	-	-	-
Total Fungi	1008	43930	100	-	No Trace	-	11	440	100
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	1	40	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	0	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	0*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	-	-	-	4	-
Fibrous Particulate (1-4)	-	1	-	-	-	-	-	1	-
Background (1-5)	-	2	-	-	-	-	-	2	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Stefanie Schneider, Microbiology Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. *** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC --EMLAP Accredited #102891

Initial report from: 06/06/2019 14:19:27

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

<http://www.EMSL.com> / beltsvillelab@emsl.com

EMSL Order: 191906416

Customer ID: ATII25A

Customer PO:

Project ID:

Attn: Courtney McCall

ATI

4221 Forbes Blvd

Suite 250

Lanham, MD 20706

Project: 19-687-PGCPs-ROBERT GODDARD MONTOSSORI

Phone: (202) 832-1433

Fax:

Collected: 05/30/2019

Received: 05/30/2019

Analyzed: 06/06/2019

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location	191906416-0004 19-687-04 75 ROOM 107			191906416-0005 19-687-05 75 ROOM 117			191906416-0006 19-687-06 75 ROOM 217		
	Spore Types	Raw Count	Count/m ³	% of Total	Raw Count	Count/m ³	% of Total	Raw Count	Count/m ³
Alternaria (Ulocladium)	1	40	1.7	-	-	-	1	40	1.4
Ascospores	4	200	8.4	11	480	22.5	5	200	7.1
Aspergillus/Penicillium	4	200	8.4	1	40	1.9	2	90	3.2
Basidiospores	6	300	12.6	8	300	14.1	54	2400	84.8
Bipolaris++	1*	10*	0.4	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	33	1400	58.6	29	1300	61	3	100	3.5
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	4	200	8.4	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	1*	10*	0.5	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Arthrinium	-	-	-	-	-	-	-	-	-
Bispora	1	40	1.7	-	-	-	-	-	-
Gonatobotryum	-	-	-	-	-	-	-	-	-
Total Fungi	54	2390	100	50	2130	100	65	2830	100
Hyphal Fragment	3	100	-	2	90	-	-	-	-
Insect Fragment	-	-	-	-	-	-	1	40	-
Pollen	2	90	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	4	-	-	2	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	2	-	-	2	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Stefanie Schneider, Microbiology Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. *** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC --EMLAP Accredited #102891

Initial report from: 06/06/2019 14:19:27

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

<http://www.EMSL.com> / beltsvillelab@emsl.com

EMSL Order: 191906416

Customer ID: ATII25A

Customer PO:

Project ID:

Attn: Courtney McCall

ATI

4221 Forbes Blvd

Suite 250

Lanham, MD 20706

Project: 19-687-PGCPs-ROBERT GODDARD MONTOSSORI

Phone: (202) 832-1433

Fax:

Collected: 05/30/2019

Received: 05/30/2019

Analyzed: 06/06/2019

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	191906416-0007				
Client Sample ID:	19-687-07				
Volume (L):	75				
Sample Location	ROOM 207				
Spore Types	Raw Count	Count/m ³	% of Total		
Alternaria (Ulocladium)	4	200	8.7	-	-
Ascospores	1	40	1.7	-	-
Aspergillus/Penicillium	2	90	3.9	-	-
Basidiospores	7	300	13.1	-	-
Bipolaris++	1	40	1.7	-	-
Chaetomium	-	-	-	-	-
Cladosporium	24	1000	43.7	-	-
Curvularia	5	200	8.7	-	-
Epicoccum	1	40	1.7	-	-
Fusarium	-	-	-	-	-
Ganoderma	-	-	-	-	-
Myxomycetes++	6	300	13.1	-	-
Pithomyces++	-	-	-	-	-
Rust	1	40	1.7	-	-
Scopulariopsis/Microascus	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-
Zygomycetes	-	-	-	-	-
Arthrinium	1	40	1.7	-	-
Bispora	-	-	-	-	-
Gonatobotryum	-	-	-	-	-
Total Fungi	53	2290	100	-	-
Hyphal Fragment	7	300	-	-	-
Insect Fragment	-	-	-	-	-
Pollen	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	-
Analyt. Sensitivity 300x	-	13*	-	-	-
Skin Fragments (1-4)	-	4	-	-	-
Fibrous Particulate (1-4)	-	2	-	-	-
Background (1-5)	-	3	-	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Stefanie Schneider, Microbiology Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. *** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC --EMLAP Accredited #102891

Initial report from: 06/06/2019 14:19:27

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

Microbiology Chain of Custody
EMSL Order Number (Lab Use Only):

191906416

EMSL ANALYTICAL, INC
200 ROUTE 130 NORTH
CINNAMINSON, NJ 08077
PHONE: (800) 220-3675
FAX: (856) 786-0262

Company Name: ATI, Inc			EMSL-Bill to: <input type="checkbox"/> Same <input type="checkbox"/> Different If Bill to is Different note instructions in Comments				
Street: 4221 Rumsey Road, Suite 250			Third Party Billing requires written authorization from third party.				
City: Lanham	State/Province: MD	Zip/Postal Code: 20706	Country:				
Report To (Name): Courtney McCall / Mikal Frater			Telephone #: 202-558-7489				
Email Address: Courtney@atiinc.com & Mikal@atiinc.com			Fax #:		Purchase Order:		
Project Name/Number: 19-687- PGCPS - Robert Goddard Montosson			Please Provide Results: <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email				
U.S. State Samples Taken:		Project Zip Code:		Connecticut Samples: <input checked="" type="checkbox"/> Commercial <input type="checkbox"/> Residential			
Sterile, Sodium Thiosulfate Preserved Bottle Used: <input type="checkbox"/> Biocide Used in Source (specify): <input type="checkbox"/>							
Public Water Supply Samples: <input type="checkbox"/> Note: All results may automatically be reported to DOH if required by state.							
Turnaround Time (TAT) Options - Please Check							
<input type="checkbox"/> 3 Hour	<input type="checkbox"/> 6 Hour	<input type="checkbox"/> 24 Hour	<input type="checkbox"/> 48 Hour	<input type="checkbox"/> 72 Hour	<input type="checkbox"/> 96 Hour	<input checked="" type="checkbox"/> 1 Week <input type="checkbox"/> 2 Week	
Microbiology Test Codes							
M001 Air-O-Cell	M174 MoldSnap	M012 Pseudomonas aeruginosa (P/A***)	M115 Sewage Screen - Water (P/A***)				
M030 Micro 5	M032 Allergenco-D	M024 Pseudomonas aeruginosa (MFT*)	M116 Sewage Screen - Water (MPN**)				
M041 Fungal Direct Examination		M015 Heterotrophic Plate Count	M117 Sewage Screen - Swab (P/A***)				
M169 Pollen ID & Enumeration		M017 Total Coliform & E. coli (Colilert P/A***)	M103 Sewage Screen - Swab (MFT*)				
M280 Dust Characterization Level-1		M018 Total Coliform & E. coli (MFT*)	M133 Methicillin-resistant Staph. aureus (MRSA)				
M281 Dust Characterization Level-2		M114 Total Coliform & E. coli Enumeration (Colilert MPN**)	M031 Rapid-growing non-TB Mycobacteria Detection & Enumeration				
M005 Viable Fungi- Air Samples (Genus ID & Count)		M019 Fecal Coliform (MFT*)	M014 Endotoxin Analysis				
M006 Viable Fungi- Air Samples (Includes Penicillium, Aspergillus, Cladosporium, Stachybotrys Species ID & Count)		M020 Fecal Streptococcus (MFT*)	M044 Group Allergen (Cat, Dog, Cockroach, Dust Mite)				
M007 Culturable fungi - Surface Samples (Genus ID & Count)		M029 Enterococci (MFT*)	Other See Analytical Price Guide				
M008 Culturable fungi - Surface Samples (Includes Penicillium, Aspergillus, Cladosporium, Stachybotrys Species ID & Count)		M129 Enterococci (Enterolert P/A***)	Legionella Analysis Please use EMSL Legionella COC				
M009 Bacteria Culture Gram Stain & Count		M180 Real Time qPCR-ERMI 36 Panel					
M010 Bacteria Count & ID - 3 Most Prominent		M025 Sewage Screen -Water (MFT*)					
M011 Bacteria Count & ID - 5 Most Prominent							
Name of Sampler: Mikal Frater			Signature of Sampler: <i>Mikal Frater</i>				
Sample #	Sample Location/Description	Sample Type	Potable/ NonPotable (Only for Waters)	Test Code	Volume/ Area	Date/Time Collected	Temperature (°C) (Lab Use Only)
Example A1	Kitchen Sink/Tap	Water	<input checked="" type="checkbox"/> P <input type="checkbox"/> NP	M017	100 mL	9/1/13 4:00 PM	
19-687-01	Outside Parking Lot	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-30-19 - 12:10	
19-687-02	Field Blank	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-30-19 -	
19-687-03	Main Office	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-30-19 - 12:20	
19-687-04	Room 107	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-30-19 - 12:49	
19-687-05	Room 117	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-30-19 - 12:59	
Client Sample # (s): - 7		Total # of Samples: 7		Samples Received Chilled? Yes / No (Lab Use Only)			
Relinquished (Client):			Date: 5-30-19		Time:		
Received (Lab): <i>Hallim Kamara</i>			Date: <i>6/4/19</i>		Time: <i>4:30 PM</i>		
Comments/Special Instructions: <i>walkin</i>							<i>5/30/19</i>

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this chain of custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

**Appendix B:
Instrument Calibration Records**

Certificate of Calibration

() Buck™ BioAire Pump Calibration Rotameter

() Buck™ BioSlide Pump Calibration Rotameter

Serial number: R14057

Date Calibrated: 1/22/19

Calibration Due Date: 1/22/20

Flow Calibration

This is to certify that the rotameter listed above has been calibrated using a Buck Primary calibrator listed below which is calibrated according to A.P. Buck, Inc. calibration procedure APB-1, Ver. 6.2 and is traceable to the National Institute of Standards & Technology (N.I.S.T). A.P. Buck guarantees the accuracy of the rotameter to be within $\pm 5\%$ of the actual flow rate.

AMBIENT CONDITIONS: Temperature $74 \pm 3^{\circ}$ F Relative Humidity $50 \pm 10\%$

Description	MFR.	Model	Serial #
Primary Calibrator	A.P. Buck Inc.	M30B	<input type="checkbox"/> A40020 <input checked="" type="checkbox"/> A40021

QA Approval By: 

Information contained in this document should not be reproduced in any form without the written consent of A.P. Buck, Inc. It is for reference only and cannot be used as a form of endorsement by any private or governmental regulatory body.

A.P. BUCK, INC.
7101 Presidents Drive, Suite 110
Orlando, FL 32809
Phone: 407-851-8602
Fax: 407-851-8910

BUCK
A.P. BUCK, INC.



INSTRUMENT CALIBRATION REPORT

Pine Environmental Services LLC

798 Cromwell Park Dr.
Suite R & S
Glen Burnie, MD 21061

Pine Environmental Services, Inc.

Instrument ID 27136
Description TSI 982 Probe
Calibrated 5/28/2019 12:36:30PM

Manufacturer Tsi
Model Number 982
Serial Number/ Lot Number p13220024
Location Maryland
Department
State Certified
Status Pass
Temp °C 22
Humidity % 53

Calibration Specifications

Group # 1				Range Acc % 0.0000			
Group Name CO				Reading Acc % 3.0000			
Stated Accy Pct of Reading				Plus/Minus 0.0			
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>Fnd As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
100.0 / 100.0	PPM	100.0	PPM	108.0	100.0	0.00%	Pass
Group # 2				Range Acc % 0.0000			
Group Name CO2				Reading Acc % 3.0000			
Stated Accy Pct of Reading				Plus/Minus 0			
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>Fnd As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
1000 / 1000	PPM	1000	PPM	982	1,000	0.00%	Pass

Test Instruments Used During the Calibration

<u>Test Standard ID</u>	<u>Description</u>	<u>Manufacturer</u>	<u>Model Number</u>	<u>Serial Number / Lot Number</u>	<u>(As Of Cal Entry Date)</u>	
					<u>Last Cal Date /</u>	<u>Next Cal Date /</u>
					<u>Opened Date</u>	<u>Expiration Date</u>
MD 2GAS CO 100PPM/CO2 1000PPM	MD 2GAS CO 100PPM/CO2 1000PPM - LBI-375-2	Pine Environmental Services, Inc.	31657	LBI-375-2		11/21/2022
MD ZERO AIR FBI-1-25	MD ZERO AIR	Pine Environmental Services, Inc.	34LS-1	FBI-1-25		

Notes about this calibration

Calibration Result Calibration Successful
Who Calibrated Ryan Armstrong

INSTRUMENT CALIBRATION REPORT



Pine Environmental Services LLC

798 Cromwell Park Dr.
Suite R & S
Glen Burnie, MD 21061

Pine Environmental Services, Inc.

Instrument ID 27136
Description TSI 982 Probe
Calibrated 5/28/2019 12:36:30PM

All instruments are calibrated by Pine Environmental Services LLC according to the manufacturer's specifications, but it is the customer's responsibility to calibrate and maintain this unit in accordance with the manufacturer's specifications and/or the customer's own specific needs.

Notify Pine Environmental Services LLC of any defect within 24 hours of receipt of equipment
Please call 800-301-9663 for Technical Assistance

INSTRUMENT CALIBRATION REPORT



Advanced Labs, Inc.

Pine Environmental Services, Inc

Instrument ID 27136
 Description TSI 982 Probe
 Calibrated 12/12/2018

Manufacturer TSI
 Model Number 982
 Serial Number P13220024
 Location New Jersey
 Temp 71

Classification
 Status pass
 Frequency Yearly EOM
 Department Lab
 Humidity 22

Calibration Specifications

Group # 1							
Group Name Carbon Dioxide							
Stated Accy Pct of Reading							
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>End As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
0.00 / 0.00	ppm	0.00	ppm	0.00	0.00	0.00%	Pass
1000.00 / 1000.00	ppm	1000.00	ppm	1,009.00	1,002.00	0.20%	Pass
				Range Acc %	0.0000		
				Reading Acc %	3.0000		
				Plus/Minus	0.00		
Group # 2							
Group Name Carbon Monoxide							
Stated Accy Pct of Reading							
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>End As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
0.00 / 0.00	ppm	0.00	ppm	4.60	0.00	0.00%	Pass
100.00 / 100.00	ppm	100.00	ppm	96.00	100.10	0.10%	Pass
				Range Acc %	0.0000		
				Reading Acc %	3.0000		
				Plus/Minus	0.00		
Group # 3							
Group Name Relative Humidity							
Stated Accy Pct of Reading							
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>End As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
50.00 / 30.80	%	30.80	%	31.00	30.80	0.00%	Pass
				Range Acc %	0.0000		
				Reading Acc %	3.0000		
				Plus/Minus	0.00		
Group # 4							
Group Name Temperature							
Stated Accy Plus / Minus							
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>End As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
65.00 / 72.30	°F	72.30	°F	69.80	72.30	0.00%	Pass

Test Instruments Used During the Calibration

<u>Test Instrument ID</u>	<u>Description</u>	<u>Manufacturer</u>	<u>Serial Number</u>	<u>(As Of Cal Entry Date)</u>	
				<u>Last Cal Date</u>	<u>Next Cal Date</u>
CO/CO2_34LS-375	100 ppm CO, 1000 ppm CO2	Calgaz	MAO-375-1		6/9/2019
MICHELL DM-509-TX-01	Relative Humidity Meter	Michell	273296	9/17/2018	9/17/2019
NITROGEN ZERO_AIR_105	Nitrogen 99.999% Zero Grade Air THC <1.0 PPM	Liquid Technology	7727-37-9	6/1/2016	6/1/2019
L-1		Liquid Technology	KAP-A-10	10/1/2015	10/20/2019

INSTRUMENT CALIBRATION REPORT



Advanced Labs, Inc.

Pine Environmental Services, Inc

Instrument ID 27136
Description TSI 982 Probe
Calibrated 12/12/2018

Notes about this calibration

Calibration Result Calibration Successful
Who Calibrated Kevin Cole

Advanced Labs, Inc. hereby certifies that this instrument is calibrated and functions to meet the manufacture's specifications using NIST traceable standards, or is derived from accepted values of physical constants.

INSTRUMENT CALIBRATION REPORT



Advanced Labs, Inc.

Pine Environmental Services, Inc

Instrument ID R20401
 Description TSI 7575 -X Q-Trak
 Calibrated 8/22/2018

Manufacturer TSI
 Model Number 7575-X
 Serial Number 7575X1130009
 Location New Jersey
 Temp 77

Classification
 Status pass
 Frequency Yearly EOM
 Department Lab
 Humidity 41

Calibration Specifications

Group # 1				Range Acc % 0.0000			
Group Name Barometric Pressure				Reading Acc % 3.0000			
Stated Accy Pct of Reading				Plus/Minus 0.000			
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>End As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
30.000 / 29.610	inHg	29.610	inHg	29.620	29.610	0.00%	Pass

Test Instruments Used During the Calibration

<u>Test Instrument ID</u>	<u>Description</u>	<u>Manufacturer</u>	<u>Serial Number</u>	<u>(As Of Cal Entry Date)</u>	
				<u>Last Cal Date</u>	<u>Next Cal Date</u>
OMEGA HX93AC/DP25- E	Omega HX93AC/DP25-E	Omega Engineering	1010368 035025 035026	9/15/2016	9/15/2018
OMEGA PX02K1-16A5T /DP25-E-A	Omega PX02K1-16A5T/DP25-E-A	Omega Engineering	168377/8375030	9/15/2016	9/15/2018
OMEGA WT4401-D	Omega WT4401-D	Omega Engineering	101105	9/15/2016	9/15/2018

Notes about this calibration

Calibration Result Calibration Successful
 Who Calibrated Kevin Cole

Advanced Labs, Inc. hereby certifies that this instrument is calibrated and functions to meet the manufacture's specifications using NIST traceable standards, or is derived from accepted values of physical constants.

INSTRUMENT CALIBRATION REPORT



Pine Environmental Services LLC

798 Cromwell Park Dr.
Suite R & S
Glen Burnie, MD 21061

Pine Environmental Services, Inc.

Instrument ID R20401
Description TSI 7575 Q-Trak
Calibrated 5/28/2019 12:35:31PM

Manufacturer Tsi
Model Number 7575
Serial Number/ Lot Number 7575X1130009
Location Maryland
Department

State Certified
Status Pass
Temp °C 22
Humidity % 53

Calibration Specifications

Group # 1
Group Name Functional Test
Test Performed: Yes **As Found Result:** Pass **As Left Result:** Pass

Test Instruments Used During the Calibration

<u>Test Standard ID</u>	<u>Description</u>	<u>Manufacturer</u>	<u>Model Number</u>	<u>Serial Number / Lot Number</u>	<u>(As Of Cal Entry Date)</u> <u>Next Cal Date /</u> <u>Last Cal Date/ Expiration Date</u> <u>Opened Date</u>
-------------------------	--------------------	---------------------	---------------------	-----------------------------------	--

Notes about this calibration

Calibration Result Calibration Successful
Who Calibrated Ryan Armstrong

All instruments are calibrated by Pine Environmental Services LLC according to the manufacturer's specifications, but it is the customer's responsibility to calibrate and maintain this unit in accordance with the manufacturer's specifications and/or the customer's own specific needs.

Notify Pine Environmental Services LLC of any defect within 24 hours of receipt of equipment
Please call 800-301-9663 for Technical Assistance