



Architecture | Engineering | Construction

9220 Rumsey Road, Suite 100, Columbia, MD 21045  
T: 410.992.3424 | F: 410.992.1837

December 17, 2020

Prince George's County Public Schools  
13300 Old Marlboro Pike  
Upper Marlboro, Maryland 20772  
Attention: Mr. Alex Baylor

RE: Indoor Air Quality Assessment, Cherokee Lane Elementary School  
IFB: 022-19  
ATI Project Number: 20-706

Dear Mr. Baylor:

Prince George's County Public Schools requested that ATI, Inc., conduct a proactive indoor air quality (IAQ) assessment at Cherokee Lane Elementary School on December 9, 2020. The assessment key findings are enclosed in the Executive Summary on page three, and the official laboratory report for total fungal spore trap sampling is enclosed in Appendix A.

Thank you for the opportunity to provide Industrial Hygiene services for Prince George's County Public Schools. If you have any questions regarding this report, please contact us at (202) 643-4283.

Sincerely,  
**ATI, INC.**

---

Courtney E. McCall  
Project Manager

---

Nate Burgei, CIH, CSP  
Certified Industrial Hygienist

# Indoor Air Quality Assessment Report

Prince George's County Public Schools  
Cherokee Lane Elementary School  
9000 25<sup>th</sup> Ave.  
Adelphi, MD 20783

Prepared for:

Prince George's County Public Schools  
13300 Old Marlboro Pike  
Upper Marlboro, Maryland 20772

**December 17, 2020**

Submitted by:



ATI Job # 20-706

## Table of Contents

|   |   |
|---|---|
| Table of Contents.....                                      | 1 |
| 1 Executive Summary .....                                   | 1 |
| 2 Assessment Methods.....                                   | 1 |
| 3 Visual Observations .....                                 | 2 |
| 4 Thermal Environmental Conditions for Human Occupancy..... | 3 |
| 4.1 Temperature.....  | 3 |
| 4.2 Relative Humidity.....                                  | 3 |
| 4.3 Carbon Dioxide.....                                     | 4 |
| 4.4 Carbon Monoxide.....                                    | 5 |
| 5 Total Fungal Air Sampling Results .....                   | 5 |
| 6 Summary of Findings .....                                 | 6 |

## List of Tables

|  |   |
|--|---|
| Table 1: Visual Observations and Sampling Locations..... | 2 |
| Table 2: Temperature .....                               | 3 |
| Table 3: Relative Humidity .....                         | 4 |
| Table 4: Carbon Dioxide .....                            | 4 |
| Table 5: Carbon Monoxide.....                            | 5 |

## Appendices

- Appendix A: Laboratory Report and Chain of Custody
- Appendix B: Instrument Calibration Records

### Abbreviations and Acronyms

|                       |   |
|-----------------------|---|
| <b>AHU</b>            | Air-Handling Unit   |
| <b>AIHA</b>           | American Industrial Hygiene Association                                   |
| <b>ASHRAE</b>         | American Society of Heating, Refrigerating and Air-Conditioning Engineers |
| <b>ASTM</b>           | American Society for Testing and Materials                                |
| <b>CO</b>             | Carbon Monoxide   |
| <b>CO<sub>2</sub></b> | Carbon Dioxide  |
| <b>EMLAP</b>          | Environmental Microbiology Laboratory Accreditation Program               |
| <b>HVAC</b>           | Heating, Ventilating, And Air-Conditioning                                |
| <b>IAQ</b>            | Indoor Air Quality  |
| <b>NIST</b>           | National Institute for Standards and Technology                           |
| <b>NVLAP</b>          | National Voluntary Laboratory Accreditation Program                       |
| <b>RH</b>             | Relative Humidity   |
| <b>Rev.</b>           | Revision  |

#### **Abbreviations involving scientific volume and measurements involving media or water sampling**

|                             |                                    |
|-----------------------------|------------------------------------|
| <b>Counts/m<sup>3</sup></b> | Mold spores per cubic meter of air |
| <b>LPM</b>                  | Liters Per Minute                  |
| <b>NTE</b>                  | Not to exceed                      |
| <b>°F</b>                   | degree Fahrenheit                  |
| <b>PPM</b>                  | Parts Per Million                  |

## 1 Executive Summary

---

ATI conducted a proactive Indoor Air Quality (IAQ) assessment on December 9, 2020, at Cherokee Lane Elementary School, located at 9000 25th Ave, Adelphi, MD 20783.

The assessment included a visual assessment of randomly selected classrooms and other frequently occupied spaces, such as the cafeteria, the main office, and classrooms, for potential IAQ contributors and pathways. As part of the assessment, ATI measured common IAQ comfort parameters, including temperature, relative humidity, carbon dioxide, and carbon monoxide. Also, ATI collected total fungal air samples on spore trap cassettes for microbiological analysis.

The following is a summary of the key findings from this assessment:

1. Two of the tested spaces had a temperature greater than the ASHRAE recommended winter range of 68-75°F.
2. The relative humidity in all tested spaces was less than the ASHRAE guidelines of <65%, yet was also  $\leq 30\%$ , which can cause occupant discomfort.
3. Carbon dioxide concentrations in all tested spaces were less than the ASHRAE limit for carbon dioxide, which was 1,116 parts per million (PPM).
4. Carbon monoxide concentrations were less than the IAQ meter's detection limit throughout the tested spaces.
5. The fungal spore trap results do not suggest indoor spore amplification in the assessed spaces and are not considered unusual.

## 2 Assessment Methods

---

Sama Wanigasundara of ATI, Inc. conducted a visual assessment and air sampling on December 9, 2020. Sampled rooms were randomly selected and accounted for approximately 10% of classrooms or a minimum of five samples. Mr. Wanigasundara documented visual observations at the time he collected the air samples. ATI references the American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) *Standard 62.1 – 2016* and ASHRAE *Standard 55 – 2017* when providing IAQ services to clients. ASHRAE is an industry leader on energy efficiency and indoor air quality.

All measurements and air samples were collected between three-six feet from floor elevation, which represents a typical adult breathing zone, and away from air-supply and return diffusers. Real-time direct readings for temperature, relative humidity, carbon dioxide (CO<sub>2</sub>), and carbon monoxide (CO), were obtained with a calibrated TSI Q-Trak 7575-X Meter and attached 982 Probe.

Total fungal air samples were collected with a Buck BioAire High-Volume Sampling Pump on Zefon Air-O-Cell spore-trap cassettes at a flow rate of 15 liters per minute for five minutes, for a sample volume of 75 liters. EMSL Analytical, Inc. of Plymouth Meeting, PA, analyzed the samples using direct microscopic examination per ASTM D7391-09, which counts both viable and non-viable mold spores and particulates, which combined yields *total fungal* results. EMSL participates in the National Institute of Standards and Technology's (NIST) National Voluntary Laboratory Accreditation Program (NVLAP) for general laboratory performance and management, and the American Industrial Hygiene Association (AIHA) for Environmental Microbial Laboratory Accreditation Program (EMLAP). The EMSL laboratory reports are included in Appendix A.

3 Visual Observations

Table 1 lists the areas, conditions, observations, and other pertinent details related to this IAQ assessment. On the date of the sampling event, few occupants were present in the school because of the COVID-19 global pandemic.

**Table 1: Visual Observations and Sampling Locations**

| Sample Location             | Observations   |
|-----------------------------|--|
| Parking Lot – Outdoors      | <ul style="list-style-type: none"> <li>• Scattered clouds, mostly clear skies</li> <li>• Light foot and vehicle traffic observed</li> </ul>  |
| Main Office                 | <ul style="list-style-type: none"> <li>• Three occupants in the area during sampling</li> <li>• No odors, stained ceiling tiles, or visible mold growth observed</li> <li>• Door to corridor OPEN during sampling</li> <li>• Room splits into three adjoining office spaces</li> <li>• One air return in this space</li> <li>• Two air diffusers in the space</li> <li>• No dust accumulation in this space</li> <li>• Space is approximately 324 ft.<sup>2</sup></li> </ul> |
| Cafeteria/Multipurpose Room | <ul style="list-style-type: none"> <li>• No odors, stained ceiling tiles, or visible mold growth observed</li> <li>• No occupants in area during sampling</li> <li>• No dust accumulation</li> <li>• Three air returns in this space</li> <li>• Four air diffusers in this space</li> <li>• Space is approximately 2,275 ft.<sup>2</sup></li> </ul>  |
| Media Center                | <ul style="list-style-type: none"> <li>• No occupants in the area during sampling</li> <li>• No dust accumulation in this space</li> <li>• Two air return in this space</li> <li>• One air diffuser in this space</li> <li>• Space is approximately 924 ft.<sup>2</sup></li> </ul>   |
| Room 5                      | <ul style="list-style-type: none"> <li>• No odors, stained ceiling tiles, or visible mold growth observed</li> <li>• No occupants in the area during sampling</li> <li>• Wall unit ON during sampling</li> <li>• One air return in this space</li> <li>• No dust accumulation in this space</li> <li>• Space is approximately 968 ft.<sup>2</sup></li> </ul>   |
| Room 11                     | <ul style="list-style-type: none"> <li>• No occupants in the area during sampling</li> <li>• No odors, stained ceiling tiles, or visible mold growth observed</li> <li>• No dust accumulation in this space</li> <li>• One air return in this space</li> <li>• One air diffuser in this space</li> <li>• Space is approximately 864 ft.<sup>2</sup></li> </ul>   |
| Room 20                     | <ul style="list-style-type: none"> <li>• No odors, stained ceiling tiles, or visible mold growth observed</li> <li>• Wall unit OFF during sampling</li> <li>• No visible air return in this space</li> <li>• One air diffuser in this space</li> <li>• No occupants in area during sampling</li> <li>• Space is approximately 754 ft.<sup>2</sup></li> </ul>   |

## 4 Thermal Environmental Conditions for Human Occupancy

ASHRAE *Standard 55-2017, Thermal Environmental Conditions for Human Occupancy*, addresses thermal comfort in an office environment, which means that an employee wearing a normal amount of clothing feels neither too cold nor too warm. This standard discusses thermal comfort within the context of air temperature, humidity, and air movement and provides recommended ranges for temperature and humidity that are intended to satisfy 80% of occupants. The recommended ASHRAE ranges are referenced below by each comfort parameter.

### 4.1 Temperature

The ASHRAE standard establishes a winter comfort range of between 68°F and 75°F and a summer range of between 73°F and 79°F. The temperature measured during the December 9, 2020, assessment are summarized in Table 2. As indicated by the data in the table, temperatures in the school averaged between 73°F and 76°F, with two locations reporting greater than the ASHRAE recommended winter range.

**Table 2: Temperature**

| Sample Location | 12/09/2020<br>°F |     |         | ASHRAE<br>Standard<br>°F |
|-----------------|------------------|-----|---------|--------------------------|
|                 | Min              | Max | Average |                          |
| Outdoors        | 55               | 57  | 56      | N/A                      |
| <b>Indoors</b>  |                  |     |         |                          |
| Main Office     | 75               | 76  | 76      | 68-75°F                  |
| Cafe/MPR        | 76               | 76  | 76      | 68-75°F                  |
| Media Center    | 75               | 75  | 75      | 68-75°F                  |
| Room 5          | 75               | 75  | 75      | 68-75°F                  |
| Room 11         | 73               | 73  | 73      | 68-75°F                  |
| Room 20         | 74               | 75  | 75      | 68-75°F                  |

### 4.2 Relative Humidity

Relative humidity is a key factor for mold growth. Mold has the potential of growing on suitable surfaces with humidity levels above 65%. ASHRAE *Standard 62.1-2016, Ventilation for Acceptable Indoor Air Quality*, recommends a maximum indoor relative humidity of 65% to prevent condensation of moisture on surfaces. Relative humidity below 30% may result in drying of the mucous membranes and skin. Relative humidity is summarized in Table 3. As indicated by the data in the table, relative humidity averaged between 18% and 30% with all tested locations reporting less than the ASHRAE maximum recommendation of 65% relative humidity, yet also at or below 30% relative humidity.

Table 3: Relative Humidity

| Sample Location | 12/09/2020<br>(% RH) |     |         | ASHRAE<br>Standard<br>(% RH) |
|-----------------|----------------------|-----|---------|------------------------------|
|                 | Min                  | Max | Average |                              |
| Outdoors        | 20                   | 21  | 21      | N/A                          |
| <b>Indoors</b>  |                      |     |         |                              |
| Main Office     | 18                   | 18  | 18      | < 65                         |
| Cafe/MPR        | 28                   | 29  | 29      | < 65                         |
| Media Center    | 21                   | 22  | 22      | < 65                         |
| Room 5          | 22                   | 22  | 22      | < 65                         |
| Room 11         | 29                   | 30  | 30      | < 65                         |
| Room 20         | 21                   | 21  | 21      | < 65                         |

### 4.3 Carbon Dioxide

Carbon dioxide measurements within an occupied building are a standard method used to gauge the efficiency of ventilation systems. Carbon dioxide is a by-product of human respiration and does not pose an acute health hazard alone. Elevated concentrations may suggest that insufficient fresh air is being supplied to an occupied space and/or that the ventilation system does not provide a sufficient rate of air exchange.

Research has indicated that buildings with adequately operating ventilation systems are able to remove odors generated by activities in an indoor office environment efficiently. ASHRAE *Standard 62.1-2016* states that comfort (odor) criteria with respect to human bioeffluents are likely to be satisfied if the ventilation results indoor carbon dioxide concentrations are less than 700 parts per million (ppm) above the outdoor air concentration. Typically, outdoor levels of carbon dioxide range from 300-450 ppm, with the higher range typically found in urban areas during peak rush hour.

Carbon dioxide measurements are summarized in Table 4. On the day of the assessment, the average outdoor carbon dioxide concentration obtained was 389 ppm, which calculates to a maximum indoor concentration of 1,116 ppm (700 + 416). All tested locations indoors were less than the recommended maximum for the day of the assessment.

Table 4: Carbon Dioxide

| Sample Location | 12/9/2020<br>Concentration (parts per million) |     |         | ASHRAE<br>Standard<br>(ppm)<br>NTE |
|-----------------|--|-----|---------|------------------------------------|
|                 | Min  | Max | Average |                                    |
| Outdoors        | 413  | 418 | 416     | N/A                                |
| <b>Indoors</b>  |  |     |         |                                    |
| Main Office     | 460  | 468 | 464     | 1,116                              |
| Cafe/MPR        | 477  | 479 | 478     | 1,116                              |
| Media Center    | 515  | 534 | 525     | 1,116                              |
| Room 5          | 468  | 474 | 471     | 1,116                              |
| Room 11         | 487  | 492 | 490     | 1,116                              |
| Room 20         | 501  | 522 | 512     | 1,116                              |



**4.4 Carbon Monoxide**

Carbon monoxide is a colorless and odorless gas produced by the incomplete combustion of carbon containing fuels. Oil, gasoline, diesel fuels, wood, coke, and coal are the major sources of carbon monoxide. ASHRAE recommends that carbon monoxide not exceed nine ppm indoors over an eight-hour time-weighted average. ATI measured carbon monoxide concentrations using a TSI Q-Trak model number 7575-X with an attached IAQ probe (model number 982). The instrument’s carbon monoxide sensor has an error range of ± 3% of the reading or three (3) ppm, whichever is greater. As indicated by the data in Table 5, carbon monoxide concentrations were less than the Q-Trak’s detection limit throughout the school.

**Table 5: Carbon Monoxide**

| Sample Location | 12/09/2020<br>Concentration (parts per million) |     |         | ASHRAE<br>Standard<br>(ppm) |
|-----------------|---|-----|---------|-----------------------------|
|                 | Min   | Max | Average |                             |
| Outdoors        | <3  | <3  | <3      | N/A                         |
| Main Office     | <3  | <3  | <3      | < 9                         |
| Cafe/MPR        | <3  | <3  | <3      | < 9                         |
| Media Center    | <3  | <3  | <3      | < 9                         |
| Room 5          | <3  | <3  | <3      | < 9                         |
| Room 11         | <3  | <3  | <3      | < 9                         |
| Room 20         | <3  | <3  | <3      | < 9                         |

**5 Total Fungal Air Sampling Results**

Mold is carried indoors through building entrances, open windows, loading docks, foot traffic into buildings, and the HVAC system. To thrive indoors, mold requires a food source, proper temperature and humidity to foster its growth.

The December 9, 2020 mold assessment sampled air using spore trap cassettes in randomly selected classrooms and other areas throughout the facility. These cassettes collect both viable spores, those capable of producing more fungal colonies, and non-viable spores, which cannot reproduce. Based upon recognized industry practices, indoor mold concentrations are compared with those detected outdoors, which are also known as ambient or baseline samples.

In normal circumstances, the diversity of spores identified indoors and outdoors should be similar with some exceptions. The high concentration of one or two species of fungal spores identified indoors and the absence of the same species outdoors can indicate a moisture problem with the potential to degrade the air quality. Fungi species present indoors are typically found at levels ranging from approximately 10-50% of their levels in the outdoor air, reflecting the filtering by the building’s HVAC system.

The findings indicated that the indoor concentrations were favorable compared to the outdoor concentrations. The total ambient spore count was 1,060 counts/m<sup>3</sup>, and total concentrations in each tested space did not exceed the ambient concentration. The highest indoor spore concentration was 400 counts/m<sup>3</sup> of basidiospores in Room 20. Basidiospores are commonly associated with outdoor origin, so any basidiospores detected indoors were likely introduced into the space via unfiltered outdoor air. Basidiospores are commonly detected indoors, are known to cause allergies, yet are not associated with water damaged materials in buildings.

Low concentrations of *Aspergillus/Penicillium* were detected but did not exceed 200 counts/m<sup>3</sup> in the tested spaces. Trace amounts of *Myxomycetes*, *Polythrincium*, *Curvularia* and others were detected in low concentrations that did not exceed 100 counts/m<sup>3</sup>. The mold spore concentrations are typical for an occupied space and do not suggest active or unusual mold presence.

The official laboratory report with spore trap samples collected on December 9, 2020, is presented in Appendix A.

## 6 Summary of Findings

---

1. Two of the tested spaces had a temperature greater than the ASHRAE recommended winter range of 68-75°F.
2. The relative humidity in all tested spaces was less than the ASHRAE guidelines of <65%, yet was also ≤30%, which can cause occupant discomfort.
3. Carbon dioxide concentrations in all tested spaces were less than the ASHRAE limit for carbon dioxide, which was 1,116 parts per million (PPM).
4. Carbon monoxide concentrations were less than the IAQ meter's detection limit throughout the tested spaces.
5. The fungal spore trap results do not suggest indoor spore amplification in the assessed spaces and are not considered unusual.

We appreciate the opportunity to provide these IAQ testing services for you. If you have any questions, please contact us at (202) 643-4283.

Best,  
**ATI, INC.**



---

Courtney E. McCall  
Project Manager



---

Nate Burgei, CIH, CSP  
Certified Industrial Hygienist

**Appendix A: Laboratory Report and Chain of Custody**



# EMSL Analytical, Inc.

5221 Militia Hill Road Plymouth Meeting, PA 19462  
Tel/Fax: (610) 828-3102 / (610) 828-3122  
<http://www.EMSL.com> / [plymouthmeetinglab@emsl.com](mailto:plymouthmeetinglab@emsl.com)

**EMSL Order:** 182004046  
**Customer ID:** ATII25A  
**Customer PO:**  
**Project ID:**

**Attention:** Courtney McCall  
ATI  
4221 Forbes Blvd  
Suite 250  
Lanham, MD 20706  
**Project:** Cherokee Lane ES 20-706

**Phone:** (202) 832-1433  
**Fax:**  
**Collected Date:** 12/09/2020  
**Received Date:** 12/10/2020 03:57 PM  
**Analyzed Date:** 12/16/2020

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

| Lab Sample Number:        | 182004046-0001   |                      |            | 182004046-0002 |                      |            | 182004046-0003 |                      |            |
|---------------------------|------------------|----------------------|------------|----------------|----------------------|------------|----------------|----------------------|------------|
| Client Sample ID:         | 3106-0771        |                      |            | 3105-8862      |                      |            | 3106-0593      |                      |            |
| Volume (L):               | 75               |                      |            | 75             |                      |            | 75             |                      |            |
| Sample Location:          | Outside Exterior |                      |            | Room 20        |                      |            | Main Office    |                      |            |
| Spore Types               | Raw Count        | Count/M <sup>3</sup> | % of Total | Raw Count      | Count/M <sup>3</sup> | % of Total | Raw Count      | Count/M <sup>3</sup> | % of Total |
| Alternaria (Ulocladium)   | -                | -                    | -          | -              | -                    | -          | -              | -                    | -          |
| Ascospores                | 33*              | 430*                 | 40.6       | 1*             | 10*                  | 1.5        | -              | -                    | -          |
| Aspergillus/Penicillium   | -                | -                    | -          | -              | -                    | -          | -              | -                    | -          |
| Basidiospores             | 14               | 590                  | 55.7       | 9              | 400                  | 61.5       | 3              | 100                  | 52.6       |
| Bipolaris++               | -                | -                    | -          | -              | -                    | -          | -              | -                    | -          |
| Chaetomium                | -                | -                    | -          | -              | -                    | -          | -              | -                    | -          |
| Cladosporium              | -                | -                    | -          | 5              | 200                  | 30.8       | 1              | 40                   | 21.1       |
| Curvularia                | -                | -                    | -          | -              | -                    | -          | -              | -                    | -          |
| Epicoccum                 | -                | -                    | -          | -              | -                    | -          | -              | -                    | -          |
| Fusarium                  | -                | -                    | -          | -              | -                    | -          | -              | -                    | -          |
| Ganoderma                 | -                | -                    | -          | -              | -                    | -          | -              | -                    | -          |
| Myxomycetes++             | 1                | 40                   | 3.8        | 1*             | 10*                  | 1.5        | 1              | 40                   | 21.1       |
| Pithomyces++              | -                | -                    | -          | -              | -                    | -          | -              | -                    | -          |
| Rust                      | -                | -                    | -          | -              | -                    | -          | -              | -                    | -          |
| Scopulariopsis/Microascus | -                | -                    | -          | -              | -                    | -          | -              | -                    | -          |
| Stachybotrys/Memnoniella  | -                | -                    | -          | -              | -                    | -          | -              | -                    | -          |
| Unidentifiable Spores     | -                | -                    | -          | -              | -                    | -          | -              | -                    | -          |
| Zygomycetes               | -                | -                    | -          | -              | -                    | -          | -              | -                    | -          |
| Arthrinium                | -                | -                    | -          | -              | -                    | -          | 1*             | 10*                  | 5.3        |
| Polythrincium             | -                | -                    | -          | 2*             | 30*                  | 4.6        | -              | -                    | -          |
| Pyricularia               | -                | -                    | -          | -              | -                    | -          | -              | -                    | -          |
| <b>Total Fungi</b>        | <b>48</b>        | <b>1060</b>          | <b>100</b> | <b>18</b>      | <b>650</b>           | <b>100</b> | <b>6</b>       | <b>190</b>           | <b>100</b> |
| Hyphal Fragment           | 1*               | 10*                  | -          | -              | -                    | -          | -              | -                    | -          |
| Insect Fragment           | -                | -                    | -          | -              | -                    | -          | -              | -                    | -          |
| Pollen                    | -                | -                    | -          | -              | -                    | -          | -              | -                    | -          |
| Analyt. Sensitivity 600x  | -                | 42                   | -          | -              | 42                   | -          | -              | 42                   | -          |
| Analyt. Sensitivity 300x  | -                | 13*                  | -          | -              | 13*                  | -          | -              | 13*                  | -          |
| Skin Fragments (1-4)      | -                | 1                    | -          | -              | 2                    | -          | -              | 1                    | -          |
| Fibrous Particulate (1-4) | -                | 1                    | -          | -              | 1                    | -          | -              | 1                    | -          |
| Background (1-5)          | -                | 1                    | -          | -              | 1                    | -          | -              | 1                    | -          |

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kevin Ream, Laboratory Manager  
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "\*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.  
Samples analyzed by EMSL Analytical, Inc. Plymouth Meeting, PA AIHA-LAP, LLC-EMLAP Accredited #178659

Initial report from: 12/17/2020 10:04 AM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

5221 Militia Hill Road Plymouth Meeting, PA 19462  
Tel/Fax: (610) 828-3102 / (610) 828-3122  
<http://www.EMSL.com> / [plymouthmeetinglab@emsl.com](mailto:plymouthmeetinglab@emsl.com)

**EMSL Order:** 182004046  
**Customer ID:** ATII25A  
**Customer PO:**  
**Project ID:**

**Attention:** Courtney McCall  
ATI  
4221 Forbes Blvd  
Suite 250  
Lanham, MD 20706  
**Project:** Cherokee Lane ES 20-706

**Phone:** (202) 832-1433  
**Fax:**  
**Collected Date:** 12/09/2020  
**Received Date:** 12/10/2020 03:57 PM  
**Analyzed Date:** 12/16/2020

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

| Lab Sample Number:<br>Client Sample ID:<br>Volume (L):<br>Sample Location: | 182004046-0004<br>3106-0596<br>75<br>MPR |            |            | 182004046-0005<br>3106-0572<br>75<br>Media Center |            |            | 182004046-0006<br>3106-0543<br>75<br>Room 5 |            |            |
|--|--|------------|------------|---|------------|------------|---|------------|------------|
|  | Spore Types                              | Raw Count  | Count/M³   | % of Total  | Raw Count  | Count/M³   | % of Total                                  | Raw Count  | Count/M³   |
| Alternaria (Ulocladium)  | 1  | 40         | 10.3       | 1*  | 10*        | 4.3        | -   | -          | -          |
| Ascospores   | -  | -          | -          | -   | -          | -          | 1*  | 10*        | 2.9        |
| Aspergillus/Penicillium  | 4  | 200        | 51.3       | 3   | 100        | 43.5       | 3   | 100        | 28.6       |
| Basidiospores  | 3  | 100        | 25.6       | 2   | 80         | 34.8       | 5   | 200        | 57.1       |
| Bipolaris++  | -  | -          | -          | -   | -          | -          | -   | -          | -          |
| Chaetomium   | -  | -          | -          | -   | -          | -          | -   | -          | -          |
| Cladosporium   | -  | -          | -          | -   | -          | -          | -   | -          | -          |
| Curvularia   | 1  | 40         | 10.3       | -   | -          | -          | -   | -          | -          |
| Epicoccum  | -  | -          | -          | -   | -          | -          | -   | -          | -          |
| Fusarium   | -  | -          | -          | -   | -          | -          | -   | -          | -          |
| Ganoderma  | -  | -          | -          | -   | -          | -          | -   | -          | -          |
| Myxomycetes++  | -  | -          | -          | -   | -          | -          | 1   | 40         | 11.4       |
| Pithomyces++   | 1*                                       | 10*        | 2.6        | -   | -          | -          | -   | -          | -          |
| Rust   | -  | -          | -          | -   | -          | -          | -   | -          | -          |
| Scopulariopsis/Microascus  | -  | -          | -          | -   | -          | -          | -   | -          | -          |
| Stachybotrys/Memnoniella   | -  | -          | -          | -   | -          | -          | -   | -          | -          |
| Unidentifiable Spores  | -  | -          | -          | -   | -          | -          | -   | -          | -          |
| Zygomycetes  | -  | -          | -          | -   | -          | -          | -   | -          | -          |
| Arthrinium   | -  | -          | -          | -   | -          | -          | -   | -          | -          |
| Polythrincium  | -  | -          | -          | -   | -          | -          | -   | -          | -          |
| Pyricularia  | -  | -          | -          | 1   | 40         | 17.4       | -   | -          | -          |
| <b>Total Fungi</b>   | <b>10</b>                                | <b>390</b> | <b>100</b> | <b>7</b>  | <b>230</b> | <b>100</b> | <b>10</b>                                   | <b>350</b> | <b>100</b> |
| Hyphal Fragment  | -  | -          | -          | 2   | 80         | -          | -   | -          | -          |
| Insect Fragment  | -  | -          | -          | 1*  | 10*        | -          | 1   | 40         | -          |
| Pollen   | -  | -          | -          | -   | -          | -          | -   | -          | -          |
| Analyt. Sensitivity 600x   | -  | 42         | -          | -   | 42         | -          | -   | 42         | -          |
| Analyt. Sensitivity 300x   | -  | 13*        | -          | -   | 13*        | -          | -   | 13*        | -          |
| Skin Fragments (1-4)   | -  | 2          | -          | -   | 2          | -          | -   | 2          | -          |
| Fibrous Particulate (1-4)  | -  | 1          | -          | -   | 1          | -          | -   | 1          | -          |
| Background (1-5)   | -  | 1          | -          | -   | 1          | -          | -   | 1          | -          |

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kevin Ream, Laboratory Manager  
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "\*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.  
Samples analyzed by EMSL Analytical, Inc. Plymouth Meeting, PA AIHA-LAP, LLC-EMLAP Accredited #178659

Initial report from: 12/17/2020 10:04 AM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

5221 Militia Hill Road Plymouth Meeting, PA 19462  
Tel/Fax: (610) 828-3102 / (610) 828-3122  
<http://www.EMSL.com> / [plymouthmeetinglab@emsl.com](mailto:plymouthmeetinglab@emsl.com)

**EMSL Order:** 182004046  
**Customer ID:** ATII25A  
**Customer PO:**  
**Project ID:**

**Attention:** Courtney McCall  
ATI  
4221 Forbes Blvd  
Suite 250  
Lanham, MD 20706  
**Project:** Cherokee Lane ES 20-706

**Phone:** (202) 832-1433  
**Fax:**  
**Collected Date:** 12/09/2020  
**Received Date:** 12/10/2020 03:57 PM  
**Analyzed Date:** 12/16/2020

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

| Lab Sample Number:        | 182004046-0007 |            |            | 182004046-0008 |                 |            |
|---------------------------|----------------|------------|------------|----------------|-----------------|------------|
| Client Sample ID:         | 3106-8863      |            |            | 3106-0694      |                 |            |
| Volume (L):               | 75             |            |            |                |                 |            |
| Sample Location:          | Room 11        |            |            | Field Blank    |                 |            |
| Spore Types               | Raw Count      | Count/M³   | % of Total | Raw Count      | Count/M³        | % of Total |
| Alternaria (Ulocladium)   | -              | -          | -          | -              | -               | -          |
| Ascospores                | -              | -          | -          | -              | -               | -          |
| Aspergillus/Penicillium   | -              | -          | -          | -              | -               | -          |
| Basidiospores             | 1              | 40         | 25         | -              | -               | -          |
| Bipolaris++               | -              | -          | -          | -              | -               | -          |
| Chaetomium                | -              | -          | -          | -              | -               | -          |
| Cladosporium              | 2              | 80         | 50         | -              | -               | -          |
| Curvularia                | -              | -          | -          | -              | -               | -          |
| Epicoccum                 | -              | -          | -          | -              | -               | -          |
| Fusarium                  | -              | -          | -          | -              | -               | -          |
| Ganoderma                 | -              | -          | -          | -              | -               | -          |
| Myxomycetes++             | 1              | 40         | 25         | -              | -               | -          |
| Pithomyces++              | -              | -          | -          | -              | -               | -          |
| Rust                      | -              | -          | -          | -              | -               | -          |
| Scopulariopsis/Microascus | -              | -          | -          | -              | -               | -          |
| Stachybotrys/Memnoniella  | -              | -          | -          | -              | -               | -          |
| Unidentifiable Spores     | -              | -          | -          | -              | -               | -          |
| Zygomycetes               | -              | -          | -          | -              | -               | -          |
| Arthrinium                | -              | -          | -          | -              | -               | -          |
| Polythrincium             | -              | -          | -          | -              | -               | -          |
| Pyricularia               | -              | -          | -          | -              | -               | -          |
| <b>Total Fungi</b>        | <b>4</b>       | <b>160</b> | <b>100</b> | -              | <b>No Trace</b> | -          |
| Hyphal Fragment           | -              | -          | -          | -              | -               | -          |
| Insect Fragment           | -              | -          | -          | -              | -               | -          |
| Pollen                    | -              | -          | -          | -              | -               | -          |
| Analyt. Sensitivity 600x  | -              | 42         | -          | -              | 0               | -          |
| Analyt. Sensitivity 300x  | -              | 13*        | -          | -              | 0*              | -          |
| Skin Fragments (1-4)      | -              | 2          | -          | -              | -               | -          |
| Fibrous Particulate (1-4) | -              | 1          | -          | -              | -               | -          |
| Background (1-5)          | -              | 1          | -          | -              | -               | -          |

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kevin Ream, Laboratory Manager  
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "\*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.

Samples analyzed by EMSL Analytical, Inc. Plymouth Meeting, PA AIHA-LAP, LLC-EMLAP Accredited #178659

Initial report from: 12/17/2020 10:04 AM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# Microbiology Chain of Custody

EMSL Order Number (Lab Use Only)

**182004046**

EMSL ANALYTICAL, INC.  
200 ROUTE 130 NORTH  
CINNAMINSON, NJ 08077

PHONE: (800) 220-3675  
FAX: (856) 786-0262

EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING

|  |                           |  |                     |
|--|---------------------------|--|---------------------|
| Company: <b>ATI INC</b>  |                           | EMSL-Bill to: <input checked="" type="checkbox"/> Same <input type="checkbox"/> Different<br>If Bill to is Different note instructions in Comments** |                     |
| Street: <b>4221 Forbes Blvd Suite 250</b>                        |                           | Third Party Billing requires written authorization from third party  |                     |
| City: <b>Lanham</b>  | State/Province: <b>MD</b> | Zip/Postal Code: <b>20706</b>  | Country: <b>USA</b> |
| Report To (Name): <b>Courtney McCall</b>                         |                           | Telephone #: <b>703-399-5423</b>   |                     |
| Email Address: <b>courtney@atiinc.com, samappriya@atiinc.com</b> |                           | Fax #: <b>202-905-0335</b>   | Purchase Order:     |
| Project Name/Number: <b>Cherokee Lane ES 20-706</b>              |                           | Please Provide Results: <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Fax                          |                     |
| U.S. State Samples Taken:  |                           | Connecticut Samples: <input type="checkbox"/> Commercial <input type="checkbox"/> Residential  |                     |

**Turnaround Time (TAT) Options\* - Please Check**

3 Hour  
  6 Hour  
  24 Hour  
  48 Hour  
  72 Hour  
  96 Hour  
  1 Week  
  2 Week

\*Analysis completed in accordance with EMSL's Terms and Conditions located in the Analytical Price Guide. TATs are subject to methodology requirements

**Non Culturable Air Samples (Spore Traps) - Test Codes**

|                   |                   |                    |                     |                   |
|-------------------|-------------------|--------------------|---------------------|-------------------|
| • M001 Air-O-Cell | • M173 Allegro M2 | • M004 Allergenco  | • M032 Allergenco-D | • M172 Versa Trap |
| • M049 BioSIS     | • M003 Burkard    | • M043 Cyclex      | • M002 Cyclex-d     |                   |
| • M030 Micro 5    | • M174 MoldSnap   | • M176 Relle Smart | • M130 Via-Cell     |                   |

**Other Microbiology Test Codes**

|   |  |  |
|---|--|--|
| <ul style="list-style-type: none"> <li>• M041 Fungal Direct Examination</li> <li>• M005 Viable Fungi ID and Count</li> <li>• M006 Viable Fungi ID and Count (Speciation)</li> <li>• M007 Culturable Fungi</li> <li>• M008 Culturable Fungi (Speciation)</li> <li>• M009 Gram Stain Culturable Bacteria</li> <li>• M010 Bacterial Count and ID - 3 Most Prominent</li> <li>• M011 Bacterial Count and ID - 5 Most Prominent</li> <li>• M013 Sewage Contamination in Buildings</li> </ul> | <ul style="list-style-type: none"> <li>• M014 Endotoxin Analysis</li> <li>• M015 Heterotrophic Plate Count</li> <li>• M180 Real Time Q-PCR-ERMI 36 Panel</li> <li>• M018 Total Coliform (Membrane Filtration)</li> <li>• M020 Fecal Streptococcus (Membrane Filtration)</li> <li>• M210-215 Legionella Detection</li> <li>• M026 Recreational Water Screen</li> <li>• M027 Mycotoxin Analysis</li> </ul> | <ul style="list-style-type: none"> <li>• M029 Enterococci</li> <li>• M019 Fecal Coliform</li> <li>• M133 MRSA Analysis</li> <li>• M028 Cryptococcus neoformans Detection</li> <li>• M120 Histoplasma capsulatum Detection</li> <li>• M033-39 Allergen Testing</li> <li>• M044 Group Allergen (Cat, Dog, Cockroach, Dustmites)</li> <li>• Other See Analytical Price Guide</li> </ul> |
|---|--|--|

**Preservation Method (Water):**

Name of Sampler: **Don Samappriya Wanigasundara**

Signature of Sampler: *[Signature]*

| Sample #           | Sample Location  | Sample Type | Test Code   | Volume/Area | Date/Time Collected  |
|--------------------|------------------|-------------|-------------|-------------|----------------------|
| <b>Example: A1</b> | <b>Kitchen</b>   | <b>Air</b>  | <b>M001</b> | <b>75L</b>  | <b>11/12 4:00 PM</b> |
| 3106-0771          | Outside Exterior | Air         | M001        | 75L         | 12/09/20 01:55PM     |
| 3105-8862          | Room 20          | Air         | M001        | 75L         | 12/09/20 01:10PM     |
| 3106-0593          | Main Office      | Air         | M001        | 75L         | 12/09/20 01:40PM     |
| 3106-0596          | MPR              | Air         | M001        | 75L         | 12/09/20 0100PM      |
| 3106-0572          | Media Center     | Air         | M001        | 75L         | 12/09/20 12:55PM     |
| 3106-0543          | Room 5           | Air         | M001        | 75L         | 12/09/20 01:25PM     |
| 3105-8863          | Room 11          | Air         | M001        | 75L         | 12/09/20 12:30PM     |
| 3106-0694          | Fild Blank       | Air         | Moo1        | -           | 12/09/20             |
|                    |                  | Air         | Moo1        |             |                      |

Client Sample # (s): **-** Total # of Samples: **10**

Relinquished (Client): *[Signature]* Date: **12/10/20** Time: **12:30 PM**

Received (Client): Date: Time:

Comments:

RECEIVED  
EMSL ANALYTICAL,  
BELTSVILLE, MD  
PT. 10  
2020 DEC 10 P 3 57

182004046



## EMSL Analytical, Inc.

### Sample Transfer Form

|   |                         |                                 |   |
|---|-------------------------|---------------------------------|---|
| <b>Receiving Lab:</b>   | EMSL- BELTSVILLE        | <b>Phone Number:</b>            | 3019375700  |
|   |                         | <b>Fax Number:</b>              | 3019375701  |
| <b>Relinquished to:</b>   | EMSL-                   | <b>Phone Number:</b>            | 8002203675  |
|   |                         | <b>Fax Number:</b>              | 8567860262  |
| <b>Does new lab hold equivalent or additional accreditation? *</b>  |                         |                                 | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| <b>EMSL Customer ID # (if known):</b>   | ATI125A                 |                                 |   |
| <b>Client Name:</b>   | ATI INC                 |                                 |   |
| <b>Client Project:</b>  | CHEROKEE LANE ES 20-706 |                                 |   |
| <b>Tests to be Performed:</b>   | MOLD                    |                                 |   |
| <b>Date Received:</b>   | 12/10/20                |                                 |   |
| <b>Date Relinquished:</b>   | 12/14/20                |                                 |   |
| <b>Date Due:</b>  | 1 WEEK - DUE 12/17      |                                 |   |
| <b>Special Instructions:</b><br>(e.g. Work Order # , required qualifications, project specific procedures/modifications)  |                         |                                 |   |
| <b>Relinquished by (Signature):</b>   | <b>Date:</b>            | <b>Received by (Signature):</b> | <b>Date:</b>  |
|   | 12/14/20                |                                 | 12-15-20  |
| <b>Relinquished by (Signature):</b>   | <b>Date:</b>            | <b>Received by (Signature):</b> | <b>Date:</b>  |
|   |                         |                                 |   |
| <b>Customer Agreement-</b> Please sign form and send to the receiving laboratory. By signing below, you agree to permit the above named receiving lab to transfer samples to a separate EMSL lab with equivalent qualifications* for analysis. The final report will be issued from the analyzing laboratory. Ensure any requirements are listed in special instructions. |                         |                                 |   |
| <b>Name (please print):</b>   | <b>Signature:</b>       | <b>Agent of:</b>                | <b>Date:</b>  |
|   |                         |                                 |   |
| <i>If this is a recurring project or sample type that may require samples to be relinquished on a regular basis, a Standing Agreement form must be completed.</i>   |                         |                                 |   |

\* Receiving and analyzing labs shall be aware of required qualifications of project prior to transfer of samples.

Note: If customer has been notified and approved this transfer verbally or by e-mail, the receiving lab must sign for the customer above. EMSL employee filling out form on behalf of customer shall print name of person to whom they spoke, date agreement was received, and then sign under Signature.



**Appendix B: Instrument Calibration Records**

# Certificate of Calibration

- (✓) Buck™ BioAire Pump Calibration Rotameter  
( ) Buck™ BioSlide Pump Calibration Rotameter

Serial number: R14535

Date Calibrated: 12/27/19

Calibration Due Date: 12/27/20

## Flow Calibration

This is to certify that the rotameter listed above has been calibrated using a Buck Primary calibrator listed below which is calibrated according to A.P. Buck, Inc. calibration procedure APB-1, Ver. 6.2 and is traceable to the National Institute of Standards & Technology (N.I.S.T). A.P. Buck guarantees the accuracy of the rotameter to be within  $\pm 5\%$  of the actual flow rate.

AMBIENT CONDITIONS: Temperature  $74\pm 3^{\circ}$  F Relative Humidity  $50\pm 10\%$

| Description        | MFR.           | Model | Serial #  |
|--------------------|----------------|-------|---|
| Primary Calibrator | A.P. Buck Inc. | M30B  | <input type="checkbox"/> A40020<br><input checked="" type="checkbox"/> A40021 |

QA Approval By: Moroni Went

Information contained in this document should not be reproduced in any form without the written consent of A.P. Buck, Inc. It is for reference only and cannot be used as a form of endorsement by any private or governmental regulatory body.

A.P. BUCK, INC.  
7101 Presidents Drive, Suite 110  
Orlando, FL 32809  
Phone: 407-851-8602  
Fax: 407-851-8910

**BUCK**  
A.P. BUCK, INC.









# CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA  
Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 <http://www.tsi.com>

| ENVIRONMENT CONDITIONS |               |            |  | MODEL         | 982       |
|------------------------|---------------|------------|--|---------------|-----------|
| TEMPERATURE            | 71.33 (21.9)  | °F (°C)    |  | SERIAL NUMBER | P17100006 |
| RELATIVE HUMIDITY      | 53.9          | %RH        |  |               |           |
| BAROMETRIC PRESSURE    | 28.81 (975.6) | inHg (hPa) |  |               |           |

AS LEFT  
 AS FOUND

IN TOLERANCE  
 OUT OF TOLERANCE

## - CALIBRATION VERIFICATION RESULTS -

| TEMPERATURE VERIFICATION |            |            |                      | SYSTEM T-101 |              |              |                         | Unit: °F (°C) |
|--------------------------|------------|------------|----------------------|--------------|--------------|--------------|-------------------------|---------------|
| #                        | STANDARD   | MEASURED   | ALLOWABLE RANGE      | #            | STANDARD     | MEASURED     | ALLOWABLE RANGE         |               |
| 1                        | 32.0 (0.0) | 32.6 (0.3) | 31.0-33.0 (-0.5-0.6) | 2            | 139.8 (59.9) | 140.6 (60.3) | 138.8-140.8 (59.4-60.5) |               |

| HUMIDITY VERIFICATION |          |          |                 | SYSTEM H-102 |          |          |                 | Unit: %RH |
|-----------------------|----------|----------|-----------------|--------------|----------|----------|-----------------|-----------|
| #                     | STANDARD | MEASURED | ALLOWABLE RANGE | #            | STANDARD | MEASURED | ALLOWABLE RANGE |           |
| 1                     | 10.0     | 10.5     | 7.0-13.0        | 4            | 70.0     | 69.6     | 67.0-73.0       |           |
| 2                     | 30.0     | 30.4     | 27.0-33.0       | 5            | 90.0     | 88.9     | 87.0-93.0       |           |
| 3                     | 50.0     | 50.4     | 47.0-53.0       |              |          |          |                 |           |

| CO <sub>2</sub> GAS VERIFICATION |          |          |                 | SYSTEM G-101 |          |          |                 | Unit: ppm |
|----------------------------------|----------|----------|-----------------|--------------|----------|----------|-----------------|-----------|
| #                                | STANDARD | MEASURED | ALLOWABLE RANGE | #            | STANDARD | MEASURED | ALLOWABLE RANGE |           |
| 1                                | 0        | 0        | 0-50            | 4            | 3020     | 3025     | 2929-3110       |           |
| 2                                | 504      | 501      | 454-554         | 5            | 5037     | 5026     | 4886-5188       |           |
| 3                                | 1008     | 1027     | 958-1058        |              |          |          |                 |           |

| CO GAS VERIFICATION |          |          |                 | SYSTEM G-101 |          |          |                 | Unit: ppm |
|---------------------|----------|----------|-----------------|--------------|----------|----------|-----------------|-----------|
| #                   | STANDARD | MEASURED | ALLOWABLE RANGE | #            | STANDARD | MEASURED | ALLOWABLE RANGE |           |
| 1                   | 35       | 36       | 32-38           | 2            | 101      | 100      | 98-104          |           |

TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data) and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO-9001:2015.

| Measurement Variable | System ID | Last Cal. | Cal. Due |
|----------------------|-----------|-----------|----------|
| Temperature          | E010657   | 02-14-20  | 02-28-21 |
| Temperature          | E010655   | 01-21-20  | 01-31-21 |
| 5000 CO <sub>2</sub> | T-0660    | 07-15-20  | 07-15-28 |
| N <sub>2</sub>       | CT308798  | 06-28-20  | 06-28-28 |
| Flow                 | E003341   | 09-03-19  | 09-30-20 |
| Flow                 | E003525   | 01-06-20  | 01-31-21 |
| 2000 C4H8            | EB0054467 | 08-13-19  | 08-12-22 |

| Measurement Variable | System ID | Last Cal. | Cal. Due |
|----------------------|-----------|-----------|----------|
| Temperature          | E010658   | 02-14-20  | 02-28-21 |
| Humidity             | E003539   | 08-21-20  | 02-28-21 |
| 200 CO               | 149848    | 03-24-20  | 03-24-28 |
| Air                  | T608955   | 06-17-20  | 06-17-28 |
| Flow                 | E003980   | 04-22-20  | 04-30-21 |
| Flow                 | E003342   | 09-03-19  | 09-30-20 |
| 100 C4H8             | CC507339  | 03-24-20  | 03-24-28 |

Baw Yang

CALIBRATED

August 31, 2020

DATE

Doc. ID: CERT\_GEN\_WCC





# CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA  
 Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 http://www.tsi.com

|                        |               |            |               |                     |
|------------------------|---------------|------------|---------------|---------------------|
| ENVIRONMENT CONDITIONS |               |            | MODEL         | <b>7575-X</b>       |
| TEMPERATURE            | 71.33 (21.9)  | °F (°C)    | SERIAL NUMBER | <b>7575X1711004</b> |
| RELATIVE HUMIDITY      | 53.9          | %RH        |               |                     |
| BAROMETRIC PRESSURE    | 28.81 (975.6) | inHg (hPa) |               |                     |

|   |  |
|---|--|
| <input checked="" type="checkbox"/> AS LEFT | <input checked="" type="checkbox"/> IN TOLERANCE |
| <input type="checkbox"/> AS FOUND           | <input type="checkbox"/> OUT OF TOLERANCE        |

### - CALIBRATION VERIFICATION RESULTS -

| THERMO COUPLE |             |             |                       | SYSTEM PRESSURE01-02 |          |          | Unit: °F (°C)   |
|---------------|-------------|-------------|-----------------------|----------------------|----------|----------|-----------------|
| #             | STANDARD    | MEASURED    | ALLOWABLE RANGE       | #                    | STANDARD | MEASURED | ALLOWABLE RANGE |
| 1             | 70.9 (21.6) | 71.1 (21.7) | 68.9-72.9 (20.5-22.7) |                      |          |          |                 |

| BAROMETRIC PRESSURE |               |               |                           | SYSTEM PRESSURE01-02 |          |          | Unit: inHg (hPa) |
|---------------------|---------------|---------------|---------------------------|----------------------|----------|----------|------------------|
| #                   | STANDARD      | MEASURED      | ALLOWABLE RANGE           | #                    | STANDARD | MEASURED | ALLOWABLE RANGE  |
| 1                   | 28.82 (976.0) | 28.82 (976.0) | 28.24-29.40 (956.3-995.6) |                      |          |          |                  |

*TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data) and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO-9001:2015.*

| <u>Measurement Variable</u> | <u>System ID</u> | <u>Last Cal.</u> | <u>Cal. Due</u> |  | <u>Measurement Variable</u> | <u>System ID</u> | <u>Last Cal.</u> | <u>Cal. Due</u> |
|-----------------------------|------------------|------------------|-----------------|--|-----------------------------|------------------|------------------|-----------------|
| Temperature                 | E004626          | 02-14-20         | 02-28-21        |  | Pressure                    | E005254          | 10-10-19         | 10-31-20        |
| Pressure                    | E003982          | 07-21-20         | 01-31-21        |  | DC Voltage                  | E003493          | 06-17-20         | 06-30-21        |

Za Dues

CALIBRATED

August 31, 2020

DATE

Doc. ID: CERT\_GEN\_WCC





# CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA  
Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 http://www.tsi.com

|                        |               |            |               |              |
|------------------------|---------------|------------|---------------|--------------|
| ENVIRONMENT CONDITIONS |               |            | MODEL         | 7575-X       |
| TEMPERATURE            | 71.24 (21.8)  | °F (°C)    | SERIAL NUMBER | 7575X1711004 |
| RELATIVE HUMIDITY      | 54.8          | %RH        |               |              |
| BAROMETRIC PRESSURE    | 28.74 (973.2) | inHg (hPa) |               |              |

- |  |  |
|--|--|
| <input type="checkbox"/> AS LEFT             | <input checked="" type="checkbox"/> IN TOLERANCE |
| <input checked="" type="checkbox"/> AS FOUND | <input type="checkbox"/> OUT OF TOLERANCE        |

## - CALIBRATION VERIFICATION RESULTS -

| THERMO COUPLE |             |             | SYSTEM PRESSURE01-02  |   |          | Unit: °F (°C) |                 |
|---------------|-------------|-------------|-----------------------|---|----------|---------------|-----------------|
| #             | STANDARD    | MEASURED    | ALLOWABLE RANGE       | # | STANDARD | MEASURED      | ALLOWABLE RANGE |
| 1             | 70.8 (21.6) | 70.5 (21.4) | 68.8-72.8 (20.4-22.7) |   |          |               |                 |

| BAROMETRIC PRESSURE |               |               | SYSTEM PRESSURE01-02      |   |          | Unit: inHg (hPa) |                 |
|---------------------|---------------|---------------|---------------------------|---|----------|------------------|-----------------|
| #                   | STANDARD      | MEASURED      | ALLOWABLE RANGE           | # | STANDARD | MEASURED         | ALLOWABLE RANGE |
| 1                   | 28.75 (973.6) | 28.84 (976.6) | 28.17-29.33 (953.9-993.2) |   |          |                  |                 |

TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data) and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO-9001:2015.

| Measurement Variable | System ID | Last Cal. | Cal. Due | Measurement Variable | System ID | Last Cal. | Cal. Due |
|----------------------|-----------|-----------|----------|----------------------|-----------|-----------|----------|
| Temperature          | E004626   | 02-14-20  | 02-28-21 | Pressure             | E005254   | 10-10-19  | 10-31-20 |
| Pressure             | E003982   | 07-21-20  | 01-31-21 | DC Voltage           | E003493   | 06-17-20  | 06-30-21 |

VERIFIED

August 31, 2020

DATE

Doc. ID: CERT\_GEN\_WCC