

March 7, 2021

Mr. Alex Baylor  
Environmental Specialist  
Environmental Safety Office  
Prince George's County Public Schools  
Division of Supporting Services / Building Services  
13306 Old Marlboro Pike  
Upper Marlboro, MD 20772

via email: [alex.baylor@pgcps.org](mailto:alex.baylor@pgcps.org)

**RE: Indoor Air Quality (IAQ) and Mold Assessment Services  
Prince George's County Public Schools (PGCPS) – Cooper Lane Elementary School  
3817 Cooper Lane, Landover Hills, Maryland 20784  
Contract No.: IFB 022-19: Indoor Air Quality Services at Various Locations  
Tidewater Project No.: 5419-029**

Dear Mr. Baylor:

Tidewater, Inc. (Tidewater) is pleased to present this final report regarding the results of the Indoor Air Quality (IAQ) and Mold Assessment Services conducted by Tidewater at Cooper Lane Elementary School located at 3817 Cooper Lane in Landover Hills, Maryland. Tidewater's Project Manager and Certified Industrial Hygienist, Mr. Skanda Abeyesekere MS, CIH, CSP, CHMM, conducted these services on November 19, 2020. Re-sampling of areas with elevated mold concentrations were conducted on March 2, 2021.

The scope of work for the IAQ assessment and mold survey included:

- The following typical occupied areas of the school chosen at the industrial hygienist's discretion for inspection and sampling: Main Office, Library, Classroom 10, Classroom 5, Classroom 2, Classroom 14, Classroom 17, Classroom 25, Health Unit and Multipurpose Room. These areas were inspected for evidence of potential indoor air quality problems (including suspect microbial growth, water damage, chemical use/ storage, drain traps, sources of allergens/ contaminants, etc.) that may contribute to indoor air quality problems;
- Direct read measurements for temperature (T), relative humidity (RH), carbon dioxide (CO<sub>2</sub>), and carbon monoxide (CO) in the above locations for comparison with standards established by the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) Standard 62.1–2019, *Ventilation for Acceptable Indoor Air Quality*, and The United States Environmental Protection Agency (US EPA) National Ambient Air Quality Standards (NAAQS);
- Direct read measurements for Particulate Matter less than 10 microns (PM<sub>10</sub>) in the above locations for comparison with standards established by the US EPA NAAQS Final Action (December 7, 2020); and
- Air sampling for microbial spores in the above locations for total airborne fungal spore analysis.



## **Visual Observation**

Due to the on-going COVID-19 pandemic, the school building was occupied by limited number of staff and no students were present at the time of the survey. As a result, the majority of the classrooms and other common areas inspected were vacant. Tidewater's assessment included a visual inspection of the following areas of Cooper Lane Elementary School chosen at the Industrial hygienist's discretion. The results of Tidewater's visual inspection are as follows:

### **Main Office**

The Main Office appeared to be clean and well maintained. Housekeeping appeared to be satisfactory. No signs of ongoing water-intrusion problems were observed and no odors were detected. One (1) wall-mounted fan coil unit was in operation and was emitting warm air at the time of the inspection. One (1) window-mounted air conditioning unit was also observed.

### **Library**

Two (2) window-mounted air conditioning units were observed in the Library. None of these units were not in operation at the time of the inspection. Multiple wall-mounted fan coil units were in operation and were emitting warm air at the time of the inspection. No signs of ongoing water-intrusion problems were observed in the library and no odors were detected. The library appeared to be well maintained and organized.

### **Classroom 10**

A wall-mounted fan coil unit was in operation and was emitting warm air at the time of the inspection. No signs of mold growth or past or ongoing water-intrusion problems were observed in Classroom 10. Furthermore, no notable odors were detected. The ceiling-mounted air supply vents appeared to have dust accumulations and rust buildup. The classroom appeared to be clean.

### **Classroom 5**

One (1) window-mounted air conditioning unit and multiple wall-mounted fan coil units were observed in the classroom. The wall-mounted fan coil units were in operation and were emitting warm air at the time of the inspection. No signs of ongoing water-intrusion problems were observed in the classroom and no odors were detected. The ceiling-mounted air supply vents appeared to have dust accumulations and rust buildup.

### **Classroom 14**

Two (2) window-mounted air conditioning units were installed in the classroom. The front panel of one of these units was dismantled and appeared to be broken. Multiple wall-mounted fan coil units were in operation and were emitting warm air at the time of the inspection. No signs of ongoing water-intrusion problems were observed in the classroom and no odors were detected. The ceiling-mounted air supply vents appeared to have dust accumulations and rust buildup.

### **Classroom 17**

One (1) window-mounted air conditioning unit and multiple wall-mounted fan coil unit were observed in the classroom. The wall-mounted fan coil unit were in operation and were emitting warm air at the time of the inspection. The ceiling-mounted air supply vents appeared to have dust accumulations and rust buildup. The wall-mounted air supply grills appeared to be clean.

No signs of ongoing water-intrusion problems were observed. Furthermore, no odors were detected.

### **Classroom 25**

Two (2) floor-mounted air conditioning units were operating and were emitting warm air at the time of the inspection. No signs of ongoing water-intrusion problems were observed in the classroom and no odors were detected. The classroom appeared to be clean and organized.

### **Classroom 2**

A window-mounted air conditioning unit and multiple wall-mounted fan coil units were observed in the classroom. The wall-mounted fan coil units were in operation and were emitting warm air at the time of the inspection. The supply grills of the window-mounted air conditioning unit appeared to be dusty. The ceiling-mounted air supply vents appeared to have dust accumulations and rust buildup. The wall-mounted air supply grills also appeared to be dusty. No signs of ongoing water-intrusion problems were observed in the classroom and no odors were detected.

### **Health Unit**

One (1) window-mounted air conditioning unit was observed in the health unit and was labelled “out of order”. The fan coil unit was not in operation at the time of the inspection. No signs of ongoing water-intrusion problems were observed in the health unit and no odors were detected.

### **Multipurpose Room**

Six (6) ceiling-mounted exhaust fans were in operation at the time of the inspection. The multipurpose room was also equipped with four (4) window-mounted air conditioning units which were not in operation at the time of the inspection. No signs of ongoing water-intrusion problems were observed in the multipurpose room and no odors were detected. The ceiling-mounted air supply grills appeared to have dust accumulations and rust buildup.

### **Comfort Parameter Air Testing**

During the assessment, Tidewater obtained temperature (T), relative humidity (RH), carbon dioxide (CO<sub>2</sub>), and carbon monoxide (CO) measurements within select locations of the school using a TSI VelociCalc Indoor Air Quality instrument (Model Number 9565-X, Serial Number 9565X 1945 002, Calibration Date: November 8, 2019.) Measurements were taken after allowing the instrument to become acclimated to the ambient temperature and relative humidity for approximately five (5) minutes. Measurements were taken over a 5-minute time period at each designated location and the average concentration was recorded. Samples were obtained for comparison with standards established by the American Society for Heating Refrigeration and Air Conditioning (ASHRAE) Standard 62.1 – 2019, *Ventilation for Acceptable Indoor Air Quality*. Tidewater also obtained a background sample outdoors in front of the main entrance of the school building for comparison to the interior readings. The results of the IAQ comfort parameter monitoring are provided in Table 1, in **Attachment A**.

According to the American Society for Heating, Refrigerating and Air Conditioning Engineers (ASHRAE) Standard 62.1 – 2019, *Ventilation for Acceptable Indoor Air Quality*, the temperature range in summer months should be maintained between 73.0°F and 79.0°F for maximum occupant comfort. The ASHRAE standard for temperature for winter months is between 68.0°F and 74.5°F. The indoor temperature levels within the assessed areas on November 19, 2020



ranged between 57.8°F and 73.1°F. The background temperature outside the building was 52.1°F. The temperature levels recorded within most areas monitored were within temperature levels typically observed during the fall-winter transitional period. The temperature levels recorded within classroom 25, health unit and the multipurpose room were below the ASHRAE lower temperature standard of 68.0°F recommended for winter months. These areas were vacant at the time of the inspection. Indoor temperature levels tend to fluctuate throughout the work day based on the number of occupants present within the individual work spaces. The temperature level in these areas are likely to be within ASHRAE standards when they are re-occupied.

Per the same ASHRAE standard, a maximum recommended relative humidity level of 65.0% or below is recommended to reduce the likelihood of condensation on cold surfaces. Relative humidity levels within the assessed areas on November 19, 2020 ranged between 20.8% and 42.4%. The background relative humidity level outside the building was 28.9%. The relative humidity levels in all areas assessed were below the ASHRAE recommended maximum relative humidity standard of 65.0%.

ASHRAE Standard 62.1 – 2019 recommends that indoor CO<sub>2</sub> levels not exceed 700 ppm above the outdoor background CO<sub>2</sub> level. The CO<sub>2</sub> levels in the assessed areas on November 19, 2020 ranged between 447 ppm to 578 ppm. The background CO<sub>2</sub> level outside the building was 440 ppm. The CO<sub>2</sub> levels within all interior locations assessed did not exceed 700 ppm above the outdoor background CO<sub>2</sub> level of 440 ppm.

The CO levels in all areas assessed on November 19, 2020 were below the maximum standard of 9.0 ppm recommended by the Indoor Air Quality Association (IAQA) for CO in occupied indoor environments.

### **Particulate Matter Less Than 10 microns (PM10)**

During the assessment, Tidewater obtained particulate matter less than 10 microns (PM10) dust particulate measurements within select locations of the school using a TSI® DUST TRAK II™ Aerosol Monitor (Model 8534, Serial Number 8534170101.) Measurements were taken after allowing the device to become acclimated to the ambient temperature and relative humidity for five (5) minutes. Measurements were taken over a 5-minute time period at each sampling location and the average concentration was recorded for comparison with standards established by the US EPA NAAQS Final Action (December 7, 2020.)

Tidewater also obtained a background sample outdoors in front of the main entrance of the school building for comparison to the interior readings.

The results of the particulate matter sampling are provided in Table 2, in **Attachment A**.

Based on the EPA NAAQS for Particulate Matter, Final Action (December 7, 2020), the 24-hour primary and secondary exposure standard for particulate matter less than 10 microns (PM10) is 150.0 micrograms per cubic meter of air ( $\mu\text{g}/\text{m}^3$ ) or 0.150 milligrams per cubic meter of air ( $\text{mg}/\text{m}^3$ .) The results of the PM10 analysis indicate that the average PM10 dust concentrations in all assessed areas ranged between 0.071  $\text{mg}/\text{m}^3$  and 0.083  $\text{mg}/\text{m}^3$ . The average PM10 dust concentration in the background sample obtained in front of the main entrance was 0.074  $\text{mg}/\text{m}^3$ . The PM10 concentrations all areas assessed were below the EPA 24-hour primary and secondary NAAQS of 0.150  $\text{mg}/\text{m}^3$ .

### **Spore Trap Bioaerosol Sampling**

Tidewater collected spore trap air samples from select locations within the school chosen by the Industrial hygienist's discretion to characterize air quality for total airborne total fungal spores. The samples were collected from the same locations where the comfort parameters were recorded. Tidewater obtained the spore trap samples using Allergenco-D cassettes affixed to a Buck BioAire™ Bioaerosol Sampling Pump (Pump Model Number B520 and Serial Number B153043) calibrated to a flow rate of 15.0 Liters per minute. Each sample was run for a period of five (5) minutes at each sample location to collect a total sample volume of 75.0 liters of air. Tidewater also obtained a background sample outdoors in front of the main entrance of the school building for comparison to the interior readings.

Once collected, the samples were transported to EMSL Analytical Laboratory (EMSL) located in Beltsville, Maryland for analysis via a standard turn-around time. The samples were transported following rigorous chain-of-custody guidelines to ensure proper handling and delivery of the samples. EMSL is accredited in the American Industrial Hygiene Association (AIHA) Environmental Microbiology Laboratory Accreditation Program (EMLAP) and is a successful participant in AIHA's Environmental Microbiology Proficiency Analytical Testing (EMPAT) program (Laboratory Number 102891.) The samples were analyzed via light microscopy at the standardized magnification of 600X. This technique does not allow for the differentiation between *Aspergillus* and *Penicillium* spores because they are morphologically identical. Additionally, the technique does not allow for cultivation, or the identification of spores to the species level, except in a few cases.

There are no universally accepted federal or State of Maryland standards for acceptable airborne concentrations of bioaerosols in an indoor occupational environment. In general, indoor airborne concentrations should be less than that found in the outdoor air, with similar species composition. Indoor spore counts significantly greater than those outdoors, or the presence of large numbers of different types of spores indoors that are not found outdoors, may indicate contamination and potential indoor air quality problems.

The total mold spore counts in all assessed areas of the school ranged between 710 spores/m<sup>3</sup> and 51,670 spores/m<sup>3</sup>. The mold spore concentrations in the background sample obtained outdoors was 1,070 spores/m<sup>3</sup>. The total mold spore concentrations in the indoor samples obtained from Classroom 5 (sample # CLES-3), Classroom 14 (sample # CLES-6), Classroom 25 (sample # CLES-8) and the Multi-purpose room (sample # CLES-10) were between 1 and 2.5 times higher than the total mold spore concentration detected in the background sample (sample # CLES-BG.) Although the total mold spore concentrations in the above locations were higher than the total mold spore concentration in the background sample, the species composition of these samples were somewhat similar to the species composition of the background sample.

However, the total mold concentration in Classroom 17 (sample # CLES-7) was significantly (over 48 times) higher than the total mold spore concentration detected in the background sample. Furthermore, the concentration of *Aspergillus/ Penicillium* species detected in Classroom 17 (sample # CLES-7) was 51,500 spores/m<sup>3</sup>. No *Aspergillus/ Penicillium* spores were detected in the background sample (CLES-BG.) The significantly high concentration of *Aspergillus/ Penicillium* species detected in sample # CLES-7 indicates the presence of a potential indoor source(s) of mold in Classroom 17.



*Aspergillus/ Penicillium* are the most common mold species that are detected in indoor air samples. Most of the hundreds of sub-species are allergenic with only a few that are toxic. This group of species will grow with only the humidity in the air as its water source.

These areas were re-sampled on March 2, 2021 following cleanup activities. The results indicated that the total mold spore concentrations and the concentration of *Aspergillus/ Penicillium* spores in Classroom 17 and Classroom 25 were below the background concentration.

The summary of the results for the spore trap sampling are provided in Table 3 in **Attachment A**. The laboratory analytical results, including speciation and chain of custody forms for the spore trap samples are included in **Attachment B**.

## **CONCLUSIONS**

- During the visual inspections conducted within typically occupied areas of the school, chosen by the Industrial hygienist's discretion, the follow issues were identified:
  - Classrooms 10, 5, 14, 17, 2 and Multipurpose Room: The ceiling-mounted air supply vents appeared to have dust accumulations and rust buildup.
  - Classroom 2: The supply grills of the window-mounted air conditioning unit appeared to have dust deposits. Accumulated dust was also observed on the air supply grills mounted on the wall of the classroom.
  - Classroom 14: The front panel of one of the window-mounted air conditioning unit was dismantled and appeared to be broken.
  - Health Unit: The window-mounted air conditioning unit was non-functional.
- Temperature levels recorded within all interior locations assessed, except in classroom 25, health unit and the multipurpose room were within the temperature levels typically observed during the fall-winter transitional period. The temperature levels in these locations were below the ASHRAE lower temperature standard of 68.0°F for winter months.
- The Relative humidity, CO<sub>2</sub>, CO readings and particulate matter less than 10 microns (PM10) recorded within the assessed areas were within industry standards and guidelines;
- The total mold spore concentrations in all interior locations assessed were below the background sample concentration and were also consistent with those observed in the background sample. The results do not indicate elevated levels of airborne total fungal spores in the interior locations sampled.

## **RECOMMENDATIONS**

Based on the results of our visual inspection, Tidewater proposes the following:

- Clean the ceiling-mounted air supply vents in Classrooms 10, 5, 14, 17, 2 and Multipurpose Room with a commercially available (EPA approved) disinfectant on a routine basis to remove dust deposits. If possible, also use a commercially available (EPA approved) rust remover to remove rust buildup from the supply vents;





- Clean the air supply grills of the window-mounted air conditioning unit and the air supply grills mounted on the walls of classroom 2 on a routine basis with a commercially available (EPA approved) disinfectant to remove dust deposits.
- The dismantled widow-mounted air-conditioning unit in Classroom 14 should be removed or replaced;
- The non-functional window-mounted air conditioning unit in the health unit should be repaired or replaced.
- Maintain good housekeeping practices in all common areas and classrooms. All common area and classrooms floors should be broom cleaned at the end of each day once the school re-opens for students. Furthermore, all horizontal surfaces including desktops, furniture, window sills, and light fixtures should be cleaned on a routine basis to prevent the accumulation of dust;
- Ensure the Heating Ventilation and Air Conditioning (HVAC) System supplying air to all common areas and classrooms is properly balanced per design requirements and are turned on and are operating at all times to ensure adequate ventilation throughout the classrooms before the school re-opens.

**Qualifications**

Tidewater has endeavored to investigate existing conditions in select areas of Cooper Lane Elementary School located at 3817 Cooper Lane in Landover Hills, Maryland as they pertain to indoor air quality and mold contamination. Our conclusions and recommendations are based on the observations made on the day of our assessment, laboratory data from the time of the assessment, and information provided by both our Client and the area occupants. Actual conditions vary from day to day throughout the year.

Tidewater appreciates the opportunity to provide Industrial Hygiene consulting services for Prince Georges County Public Schools. Please contact us should any questions arise concerning this report or if we may be of further assistance.

Sincerely,

*Tidewater, Inc.*

Skanda Abeyesekere, MS, CIH, CSP, CHMM  
Project Manager

Jonathan N. Schatz, MS  
Manager, IH Services

SA/JNS

Attachments: **Attachment A – Summary of Comfort Parameters, PM10 Particulate Dust, and Microbial Results**

**Attachment B – Laboratory Reports and Chain of Custody Forms**

**Attachment C – Instrument Calibration Certificates**

**Attachment D – Relevant Certifications**

**Attachment E – Floor Plan with Sampling Locations**



**APPENDIX A**

**COMFORT PARAMETERS, PM10 PARTICULATE DUST, AND  
MICROBIAL RESULTS**





<b>Table 1: Indoor Air Quality Comfort Parameters Cooper Lane Elementary School</b>				
<b>Location</b>	<b>Temperature (°F)</b>	<b>Carbon Dioxide (ppm)</b>	<b>Relative Humidity (%)</b>	<b>Carbon Monoxide (ppm)</b>
<b>November 19, 2020</b>				
Main Office	68.2	29.3	578	0.4
Library	71.5	28.4	546	0.4
Classroom 10	72.5	21.3	501	0.3
Classroom 5	73.1	23.1	564	0.2
Classroom 14	70.1	24.0	498	0.0
Classroom 17	69.7	25.4	506	0.1
Classroom 25	57.8*	42.4	519	0.0
Classroom 2	72.0	20.8	471	0.0
Health Unit	67.8	26.7	476	0.0
Multi-purpose Room	66.7	20.8	447	0.0
Background (Outdoors)	52.1	28.9	440	0.0

\*Highlighted Areas indicate locations in which temperature levels were below the American Society for Heating Refrigeration and Air Conditioning (ASHRAE) Standard 62.1 – 2019 recommended standards for winter months.



<b>Table 2: Particulate Matter Less than 10 Microns (PM10) Cooper Lane Elementary School</b>	
<b>Location</b>	<b>Particulate Matter (PM10)</b>
	<b>Concentration (mg/m<sup>3</sup>)</b>
<b>November 19, 2020</b>	
Main Office	0.083
Library	0.071
Classroom 10	0.073
Classroom 5	0.074
Classroom 14	0.074
Classroom 17	0.074
Classroom 25	0.071
Classroom 2	0.080
Health Unit	0.073
Multipurpose Room	0.075
Background (Outdoors)	0.074



<b>Table 3: Spore Trap Sampling Results Cooper Lane Elementary School</b>			
<b>November 19, 2020</b>			
<b>Sample Number</b>	<b>Sample Location</b>	<b>Sample Volume (L)</b>	<b>Total Fungi Concentration (Counts/m<sup>3</sup>)</b>
CLES-1	Main Office	75.0	830
CLES -2	Library	75.0	990
CLES-3	Classroom 5	75.0	<b>1,240</b>
CLES-4	Classroom 10	75.0	850
CLES-5	Classroom 2	75.0	710
CLES-6	Classroom 14	75.0	<b>1,160</b>
CLES-7	Classroom 17	75.0	<b>51,670</b>
CLES-8	Classroom 25	75.0	<b>2,300</b>
CLES-9	Health Unit	75.0	1,040
CLES-10	Multipurpose Room	75.0	<b>2,080</b>
CLES -BG	Background (Outdoors)	75.0	1,070

\*Highlighted Area indicate location where the concentrations of the indoor sample exceeded the level detected in the background sample.



<b>Table 3: Spore Trap Sampling Results Cooper Lane Elementary School</b>			
<b>March 2, 2021</b>			
<b>Sample Number</b>	<b>Sample Location</b>	<b>Sample Volume (L)</b>	<b>Total Fungi Concentration (Counts/m<sup>3</sup>)</b>
CLES-1	Classroom 25	75.0	40
CLES -2	Classroom 17	75.0	Noe Detected
CLES -BG	Background (Outdoors)	75.0	90



**APPENDIX B**

**LABORATORY REPORTS AND CHAIN OF CUSTODY FORMS**



# EMSL Analytical, Inc.

100 Green Park Industrial Court Saint Louis, MO 63123

Tel/Fax: (314) 577-0150 / (314) 776-3313

http://www.EMSL.com / saintlouislab@emsl.com

EMSL Order: 392011029

Customer ID: TIDE50

Customer PO:

Project ID:

**Attention:** Skanda Abeyeskere  
Tidewater, Inc.  
6625 Selnick Drive  
Suite A  
Elkridge, MD 21075

**Phone:** (410) 540-8700

**Fax:** (410) 997-8713

**Collected Date:** 11/19/2020

**Received Date:** 11/30/2020

**Analyzed Date:** 12/07/2020

**Project:** Cooper Lane ES

## Test Report: Allergenco-D™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	392011029-0001			392011029-0002			392011029-0003		
Client Sample ID:	CLES-1			CLES-2			CLES-3		
Volume (L):	75			75			75		
Sample Location:	Main Office			Library			Classroom 5		
Spore Types	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	2	90	10.8	5	200	20.2	3	100	8.1
Aspergillus/Penicillium	-	-	-	2	90	9.1	1	40	3.2
Basidiospores	10	440	53	15	660	66.7	8	300	24.2
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	8	300	36.1	1	40	4	18	790	63.7
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	1*	10*	0.8
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>20</b>	<b>830</b>	<b>100</b>	<b>23</b>	<b>990</b>	<b>100</b>	<b>31</b>	<b>1240</b>	<b>100</b>
Hyphal Fragment	1	40	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	1*	10*	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

*Amber Stegmann*

Amber Stegmann, Micro Supervisor  
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "\*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.

Samples analyzed by EMSL Analytical, Inc. Saint Louis, MO

Initial report from: 12/07/2020 08:57 AM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

100 Green Park Industrial Court Saint Louis, MO 63123

Tel/Fax: (314) 577-0150 / (314) 776-3313

http://www.EMSL.com / saintlouislab@emsl.com

EMSL Order: 392011029

Customer ID: TIDE50

Customer PO:

Project ID:

**Attention:** Skanda Abeyeskere  
Tidewater, Inc.  
6625 Selnick Drive  
Suite A  
Elkridge, MD 21075

**Project:** Cooper Lane ES

**Phone:** (410) 540-8700

**Fax:** (410) 997-8713

**Collected Date:** 11/19/2020

**Received Date:** 11/30/2020

**Analyzed Date:** 12/07/2020

## Test Report: Allergenco-D(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	392011029-0004			392011029-0005			392011029-0006		
Client Sample ID:	CLES-4			CLES-5			CLES-6		
Volume (L):	75			75			75		
Sample Location:	Classroom 10			Classroom 2			Classroom 14		
Spore Types	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	2	90	10.6	-	-	-	-	-	-
Aspergillus/Penicillium	-	-	-	4	200	28.2	4	200	17.2
Basidiospores	15	660	77.6	5	200	28.2	10	440	37.9
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	3	100	11.8	7	300	42.3	10	440	37.9
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	1*	10*	1.4	1	40	3.4
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	1	40	3.4
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>20</b>	<b>850</b>	<b>100</b>	<b>17</b>	<b>710</b>	<b>100</b>	<b>26</b>	<b>1160</b>	<b>100</b>
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

*Amber Stegmann*

No discernable field blank was submitted with this group of samples.

Amber Stegmann, Micro Supervisor  
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "\*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.

Samples analyzed by EMSL Analytical, Inc. Saint Louis, MO

Initial report from: 12/07/2020 08:57 AM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)





# EMSL Analytical, Inc.

100 Green Park Industrial Court Saint Louis, MO 63123

Tel/Fax: (314) 577-0150 / (314) 776-3313

http://www.EMSL.com / saintlouislam@emsl.com

EMSL Order: 392011029

Customer ID: TIDE50

Customer PO:

Project ID:

**Attention:** Skanda Abeyeskere  
Tidewater, Inc.  
6625 Selnick Drive  
Suite A  
Elkridge, MD 21075

**Project:** Cooper Lane ES

**Phone:** (410) 540-8700

**Fax:** (410) 997-8713

**Collected Date:** 11/19/2020

**Received Date:** 11/30/2020

**Analyzed Date:** 12/07/2020

## Test Report: Allergenco-D(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	392011029-0007			392011029-0008			392011029-0009		
Client Sample ID:	CLES-7			CLES-8			CLES-9		
Volume (L):	75			75			75		
Sample Location:	Classroom 17			Classroom 25			Health Unit		
Spore Types	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	1	40	3.8
Aspergillus/Penicillium	1180	51500	99.7	37	1600	69.6	3	100	9.6
Basidiospores	2	90	0.2	2	90	3.9	8	300	28.8
Bipolaris++	1	40	0.1	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	1	40	0.1	14	610	26.5	12	520	50
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	1	40	3.8
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	1	40	3.8
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>1184</b>	<b>51670</b>	<b>100</b>	<b>53</b>	<b>2300</b>	<b>100</b>	<b>26</b>	<b>1040</b>	<b>100</b>
Hyphal Fragment	1	40	-	-	-	-	1	40	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

*Amber Stegmann*

Amber Stegmann, Micro Supervisor  
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "\*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.

Samples analyzed by EMSL Analytical, Inc. Saint Louis, MO

Initial report from: 12/07/2020 08:57 AM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

100 Green Park Industrial Court Saint Louis, MO 63123

Tel/Fax: (314) 577-0150 / (314) 776-3313

http://www.EMSL.com / saintlouislam@emsl.com

EMSL Order: 392011029

Customer ID: TIDE50

Customer PO:

Project ID:

**Attention:** Skanda Abeyeskere  
Tidewater, Inc.  
6625 Selnick Drive  
Suite A  
Elkridge, MD 21075

**Project:** Cooper Lane ES

**Phone:** (410) 540-8700

**Fax:** (410) 997-8713

**Collected Date:** 11/19/2020

**Received Date:** 11/30/2020

**Analyzed Date:** 12/07/2020

## Test Report: Allergenco-D(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	392011029-0010			392011029-0011			
Client Sample ID:	CLES-10			CLES-BG			
Volume (L):	75			75			
Sample Location:	Multi Purpose			Outdoors			
Spore Types	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total	
Alternaria (Ulocladium)	-	-	-	-	-	-	-
Ascospores	3	100	4.8	4	200	18.7	-
Aspergillus/Penicillium	9	400	19.2	-	-	-	-
Basidiospores	15	660	31.7	10	440	41.1	-
Bipolaris++	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-
Cladosporium	19	830	39.9	6	300	28	-
Curvularia	-	-	-	-	-	-	-
Epicoccum	-	-	-	2	90	8.4	-
Fusarium	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-
Myxomycetes++	2	90	4.3	1	40	3.7	-
Pithomyces++	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>48</b>	<b>2080</b>	<b>100</b>	<b>23</b>	<b>1070</b>	<b>100</b>	-
Hyphal Fragment	-	-	-	4	200	-	-
Insect Fragment	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-
Background (1-5)	-	1	-	-	1	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

*Amber Stegmann*

No discernable field blank was submitted with this group of samples.

Amber Stegmann, Micro Supervisor  
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "\*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.

Samples analyzed by EMSL Analytical, Inc. Saint Louis, MO

Initial report from: 12/07/2020 08:57 AM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)

# Microbiology Chain of Custody

EMSL Order Number (Lab Use Only):

392011 029

PHONE:

FAX:

Company: Tidewater Inc		EMSL-Bill to: <input type="checkbox"/> Different <input type="checkbox"/> Same <small>If Bill to is Different note Instructions in Comments**</small>	
Street: 6625 Selnick Drive, Suite A		Third Party Billing requires written authorization from third party	
City: Elkridge	State/Province: MD	Zip/Postal Code:	Country:
Report To (Name): Skanda Abeyesekere		Telephone #:	
Email Address: skanda@tideh2o.net		Fax #:	Purchase Order:
Project Name/Number: Cooper Lane ES		Please Provide Results: <input type="checkbox"/> FAX <input checked="" type="checkbox"/> E-mail <input type="checkbox"/> Mail	
U.S. State Samples Taken: Maryland		Connecticut Samples: <input type="checkbox"/> Commercial <input type="checkbox"/> Residential	
Turnaround Time (TAT) Options* - Please Check			
<input type="checkbox"/> 3 Hour	<input type="checkbox"/> 6 Hour	<input checked="" type="checkbox"/> 24 Hour	<input type="checkbox"/> 48 Hour <input type="checkbox"/> 72 Hour <input type="checkbox"/> 96 Hour <input type="checkbox"/> 1 Week <input checked="" type="checkbox"/> 2 Week
<small>*Analysis completed in accordance with EMSL's Terms and Conditions located in the Analytical Price Guide. TATs are subject to methodology requirements</small>			

### Non Culturable Air Samples (Spore Traps) - Test Codes

- M001 Air-O-Cell
- M049 BioSIS
- M030 Micro 5
- M173 Allegro M2
- M003 Burkard
- M174 MoldSnap
- M004 Allergenco
- M043 Cyclcx
- M176 Relle Smart
- M032 Allergenco-D
- M002 Cyclcx-d
- M130 Via-Cell
- M172 Versa Trap

### Other Microbiology Test Codes

- M041 Fungal Direct Examination
- M005 Viable Fungi ID and Count
- M006 Viable Fungi ID and Count (Speciation)
- M007 Culturable Fungi
- M008 Culturable Fungi (Speciation)
- M009 Gram Stain Culturable Bacteria
- M010 Bacterial Count and ID - 3 Most Prominent
- M011 Bacterial Count and ID - 5 Most Prominent
- M013 Sewage Contamination in Buildings
- M014 Endotoxin Analysis
- M015 Heterotrophic Plate Count
- M180 Real Time Q-PCR-ERMI 36 Panel
- M018 Total Coliform (Membrane Filtration)
- M020 Fecal Streptococcus (Membrane Filtration)
- M210-215 Legionella Detection
- M026 Recreational Water Screen
- M027 Mycotoxin Analysis
- M029 Enterococci
- M019 Fecal Coliform
- M133 MRSA Analysis
- M028 Cryptococcus neoformans Detection
- M120 Histoplasma capsulatum Detection
- M033-39 Allergen Testing (Cat, Dog, Cockroach, Dustmites)
- M044 Group Allergen
- Other See Analytical Price Guide

Preservation Method (Water):

Name of Sampler: Skanda Abeyesekere

Signature of Sampler: *Skanda Abeyesekere*

Sample #	Sample Location	Sample Type	Test Code	Volume/Area	Date/Time Collected
Example: A1	Kitchen	Air	M001	75L	11/11/24:00 PM
CLES-1	Main office	Air	M032	75-0	11/19/2020
CLES-2	Library	↓	↓	↓	↓
CLES-3	Classroom 5	↓	↓	↓	↓
CLES-4	ClassRoom 10	↓	↓	↓	↓
CLES-5	Classroom 2	↓	↓	↓	↓
CLES-6	Classroom 14	↓	↓	↓	↓
CLES-7	Classroom 17	↓	↓	↓	↓

Client Sample # (s): 11

Total # of Samples: 11

Relinquished (Client): *Skanda Abeyesekere*

Date: 11/19/2020

Time: 12:00 PM

Received (Client): *J. Yonwith Fed Ex*

Date:

Time:

Comments:

RECEIVED  
 EMSL ANALYTICAL, INC  
 BELTSVILLE, MD  
 2020 NOV 23 A 10:07





# EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

http://www.EMSL.com / beltsvillelab@emsl.com

EMSL Order: 192101966

Customer ID: TIDE50

Customer PO:

Project ID:

**Attention:** Skanda Abeyeskere  
Tidewater, Inc.

6625 Selnick Drive

Suite A

Elkridge, MD 21075

**Project:** PGCPs COOPER LANE ES

**Phone:** (410) 540-8700

**Fax:** (410) 997-8713

**Collected Date:** 03/02/2021

**Received Date:** 03/02/2021

**Analyzed Date:** 03/05/2021

### Test Report: Allergenco-D(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	192101966-0001			192101966-0002			192101966-0003		
Client Sample ID:	CLES-1			CLES-1			CLES-BG		
Volume (L):	75			75			75		
Sample Location:	CLASSRM 25			CLASSRM 17			OUTDOORS		
Spore Types	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	1	40	100	-	-	-	-	-	-
Aspergillus/Penicillium	-	-	-	-	-	-	-	-	-
Basidiospores	-	-	-	-	-	-	2	90	100
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	-	-	-	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>1</b>	<b>40</b>	<b>100</b>	-	None Detected	-	<b>2</b>	<b>90</b>	<b>100</b>
Hyphal Fragment	-	-	-	1	40	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	2	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	2	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

No discernable field blank was submitted with this group of samples.

Abubakar Barry, Microbiology Lab Manager  
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "\*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC-EMLAP Accredited #102891

Initial report from: 03/05/2021 02:29 PM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)

### Microbiology Chain of Custody

EMSL Order Number (Lab Use Only):

192101966

PHONE:  
FAX:

Company: Tidewater Inc.		EMSL-Bill to: <input type="checkbox"/> Different <input type="checkbox"/> Same <small>If Bill to is Different note instructions in Comments**</small>	
Street: 6625 Selnick Drive, Suite A		Third Party Billing requires written authorization from third party	
City: Elkridge	State/Province: MD	Zip/Postal Code:	Country:
Report To (Name): Skanda Abeyesekere		Telephone #:	
Email Address: skanda@tideh2o.net		Fax #:	Purchase Order:
Project Name/Number: PGCPS Cooper Lane ES		Please Provide Results: <input type="checkbox"/> FAX <input type="checkbox"/> E-mail <input type="checkbox"/> Mail	
U.S. State Samples Taken: MD		Connecticut Samples: <input type="checkbox"/> Commercial <input type="checkbox"/> Residential	

Turnaround Time (TAT) Options\* - Please Check

3 Hour  
  6 Hour  
  24 Hour  
  48 Hour  
  72 Hour  
  96 Hour  
  1 Week  
  2 Week

\*Analysis completed in accordance with EMSL's Terms and Conditions located in the Analytical Price Guide. TATs are subject to methodology requirements

**Non Culturable Air Samples (Spore Traps) – Test Codes**

• M001 Air-O-Cell	• M173 Allegro M2	• M004 Allergenco	• M032 Allergenco-D	• M172 Versa Trap
• M049 BioSIS	• M003 Burkard	• M043 Cyclcx	• M002 Cyclcx-d	
• M030 Micro 5	• M174 MoldSnap	• M176 Relle Smart	• M130 Via-Cell	

**Other Microbiology Test Codes**

<ul style="list-style-type: none"> <li>• M041 Fungal Direct Examination</li> <li>• M005 Viable Fungi ID and Count</li> <li>• M006 Viable Fungi ID and Count (Speciation)</li> <li>• M007 Culturable Fungi</li> <li>• M008 Culturable Fungi (Speciation)</li> <li>• M009 Gram Stain Culturable Bacteria</li> <li>• M010 Bacterial Count and ID – 3 Most Prominent</li> <li>• M011 Bacterial Count and ID – 5 Most Prominent</li> <li>• M013 Sewage Contamination in Buildings</li> </ul>	<ul style="list-style-type: none"> <li>• M014 Endotoxin Analysis</li> <li>• M015 Heterotrophic Plate Count</li> <li>• M180 Real Time Q-PCR-ERMI 36 Panel</li> <li>• M018 Total Coliform (Membrane Filtration)</li> <li>• M020 Fecal Streptococcus (Membrane Filtration)</li> <li>• M210-215 Legionella Detection</li> <li>• M026 Recreational Water Screen</li> <li>• M027 Mycotoxin Analysis</li> </ul>	<ul style="list-style-type: none"> <li>• M029 Enterococci</li> <li>• M019 Fecal Coliform</li> <li>• M133 MRSA Analysis</li> <li>• M028 Cryptococcus neoformans Detection</li> <li>• M120 Histoplasma capsulatum Detection</li> <li>• M033-39 Allergen Testing</li> <li>• M044 Group Allergen (Cat, Dog, Cockroach, Dustmites)</li> <li>• Other See Analytical Price Guide</li> </ul>
-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Preservation Method (Water):

Name of Sampler: SKANDA ABEYESEKERE      Signature of Sampler: *Skanda Abeyesekere*

Sample #	Sample Location	Sample Type	Test Code	Volume/Area	Date/Time Collected
Example: A1	Kitchen	Air	M001	75L	1/1/12 4:00 PM
CLES-1	Classroom 25	Air	M032	75	03/02/2021
CLES-2	Classroom 17	Air	M032	75	
CLES-BG	Outdoors - Background	Air	M032	75	

Client Sample # (s): 3      Total # of Samples: 3

Relinquished (Client): *Skanda Abeyesekere*      Date: 03/02/2021      Time: 2:30 PM

Received (Client): *Marcus Thayer*      Date:      Time:      2021 MAR -2 3:00

Comments:

RECEIVED  
 EMSL ANALYTICAL, INC.  
 BELTVILLE, MD  
 2021 MAR -2 3:00



**APPENDIX C**  
**INSTRUMENT CALIBRATION CERTIFICATES**





# CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA  
 Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 <http://www.tsi.com>

ENVIRONMENT CONDITIONS			<b>MODEL</b>	<b>9565-X</b>
TEMPERATURE	74.1 (23.4)	°F (°C)		
RELATIVE HUMIDITY	26	%RH		
BAROMETRIC PRESSURE	29.26 (990.9)	inHg (hPa)		
			<b>SERIAL NUMBER</b>	<b>9565X1945002</b>

<input checked="" type="checkbox"/> AS LEFT	<input checked="" type="checkbox"/> IN TOLERANCE
<input type="checkbox"/> AS FOUND	<input type="checkbox"/> OUT OF TOLERANCE

-- CALIBRATION VERIFICATION RESULTS --

THERMO COUPLE <sup>^</sup>				SYSTEM PRESSURE01-01				Unit: °F (°C)
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	71.6 (22.0)	71.6 (22.0)	69.6~73.6 (20.9~23.1)					

BAROMETRIC PRESSURE				SYSTEM PRESSURE01-01				Unit: inHg (hPa)
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	29.26 (990.9)	29.26 (990.9)	28.67~29.85 (970.9~1010.8)					

<sup>^</sup> Circuit portion of temperature measurement only, not including probe.

*TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data), and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO 9001:2015*

<u>Measurement Variable</u>	<u>System ID</u>	<u>Last Cal.</u>	<u>Cal. Due</u>	<u>Measurement Variable</u>	<u>System ID</u>	<u>Last Cal.</u>	<u>Cal. Due</u>
DC Voltage	E003299	06-06-19	12-31-20	DC Voltage	E003500	06-06-19	12-31-20
Temperature	E004626	01-09-19	01-31-20	Pressure	E003302	08-07-19	02-29-20
Pressure	E003303	08-26-19	02-29-20				

Rose Germain

---

CALIBRATED

November 8, 2019

---

DATE






# CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA  
 Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 http://www.tsi.com

Environment Conditions			Model	<b>8534</b>
Temperature	75.83 (24.4)	°F (°C)	Serial Number	<b>8534170101</b>
Relative Humidity	43.6	%RH		
Barometric Pressure	28.93 (979.7)	inHg (hPa)		

<input checked="" type="checkbox"/> As Left	<input checked="" type="checkbox"/> In Tolerance	
<input type="checkbox"/> As Found	<input type="checkbox"/> Out of Tolerance	



FLOW AND PRESSURE VERIFICATION				SYSTEM DTH101-01			
Parameter	Standard	Measured	Allowable Range	Parameter	Standard	Measured	Allowable Range
Flow lpm	3.00	3.03	2.88 ~ 3.12	Pressure kPa	97.8	97.8	92.95 ~ 102.73
Full Flow lpm	N/A	4.54	>3.80				

*TSI Incorporated does hereby certify that all materials, components, and workmanship used in the manufacture of this equipment are in strict accordance with the applicable specifications agreed upon by TSI and the customer and with all published specifications. All performance and acceptance tests required under this contract were successfully conducted according to required specifications. There is no NIST standard for optical mass measurements. Calibration of this instrument performed by TSI has been done using emery oil and has been nominally adjusted to respirable mass per standard ISO 12103-1, Ai test dust (Arizona dust). Our calibration ratio is greater than 1.2:1*

Measurement Variable	System ID	Last Cal.	Cal. Due	Measurement Variable	System ID	Last Cal.	Cal. Due
DC Voltage	E003314	01-15-20	01-31-21	Photometer	E005612	08-19-20	02-28-21
Microbalance	M001324	10-03-18	10-31-20	1 um PSL	698880	n/a	n/a
3 um PSL	221853	n/a	n/a	10 um PSL	212455	n/a	n/a
Pressure	E003511	10-04-19	10-31-20	Flowmeter	E005140	01-09-20	01-31-21
DC Voltage	E003315	01-15-20	01-31-21	Photometer	E003433	09-15-20	03-31-21
Flowmeter	E005922	06-29-20	06-30-21	DC Voltage(Keithley)	E002859	06-15-20	06-30-21
Microbalance	M001324	10-03-18	10-31-20	Pressure	E005651	07-06-20	07-31-21
1 um PSL	698880	n/a	n/a	3 um PSL	206030	n/a	n/a
10 um PSL	212455	n/a	n/a				

David Farrell

September 24, 2020

Calibrated

Date

# Certificate of Conformance

Buck BioAire™

Buck BioSlide™

Serial number: B153043 Date Issued: 3-18-20

## Flow Calibration

The instrument listed above is in conformance with factory specifications and the flow is set to nominal using a BUCK Calibrator which is N.I.S.T. traceable to A. P. Buck, Inc. Calibration Procedure APB-1, Ver. 6.2.

**QA APPROVAL BY:** Thomas J. Coomaver

Information contained in this document should not be reproduced in any form without the written consent of A.P. Buck Inc. It is for reference only and cannot be used as a form of endorsement by any private or governmental regulatory body.


A.P. BUCK, INC.  
7101 Presidents Drive, Suite 110  
Orlando, FL 32809  
Phone: 407-851-8602 • Fax: 407-851-8910

**BUCK**  
A.P. BUCK, INC.

COCR-004 REV-01 3/3/2006



**APPENDIX D**  
**RELEVANT CERTIFICATIONS**



**american board of industrial hygiene®**

organized to improve the practice of industrial hygiene  
proclaims that

*Skandakumar Harshanath Abeysekere*

having met all requirements of  
education, experience and examination, and  
ongoing maintenance,  
is hereby certified in the

**COMPREHENSIVE PRACTICE  
of  
INDUSTRIAL HYGIENE**

and has the right to use the designations

**CERTIFIED INDUSTRIAL HYGIENIST**


**CIH**

Certificate Number	9928 CP
Awarded:	May 11, 2011
Expiration Date:	December 1, 2021



*Susan Ripple*  
Chair, ABIH

*William K. Oliver*  
Chief Executive Officer, ABIH



# BOARD OF CERTIFIED SAFETY PROFESSIONALS

affirms that

**Skandakumar Abeyesekere**

Has applied for, met qualifications, and passed required examination(s) and is hereby authorized to use the designation

**Certified Safety Professional<sup>®</sup>**  
in Comprehensive Practice

So long as this certificate is not suspended or revoked and the certificant renews this authorization annually and meets Continuance of Certification requirements.

Board of Examiners in witness whereof we have here unto set our hands and affixed the Seal of the Board this 7th Day of April, 2008



*Paul S Adams* President  
*Linda Japp* Secretary  
20110 CSF No.





THIS CERTIFIES THAT

*Skandakumar Abeyeskere*

HAS SUCCESSFULLY MET ALL THE REQUIREMENTS OF EDUCATION, EXPERIENCE AND EXAMINATION, AND IS HEREBY DESIGNATED A

**CERTIFIED HAZARDOUS MATERIALS MANAGER  
CHMM**



May 13, 2016

DATE OF CERTIFICATION

19053

CREDENTIAL NUMBER

May 31, 2021

CERTIFICATION EXPIRES

*M. Patricia Buley*  
ACTING EXECUTIVE DIRECTOR

VALID SO LONG AS THIS CREDENTIAL IS RENEWED ACCORDING TO SCHEDULE AND IS NOT OTHERWISE REVOKED.



Accredited by the American National Standards Institute and the Council of Engineering and Scientific Specialty Boards







**APPENDIX E**

**FLOOR PLAN WITH SAMPLING LOCATIONS**

COOPER LANE ELEMENTARY SCHOOL



General Notes

Scale: N/A

▲ Sample Location

Project #: 5419-029  
Date: November 19, 2020

Attachment C  
Cooper Lane Elementary School  
Floor Plan with Sampling Locations

