



Architecture | Engineering | Construction

9220 Rumsey Road, Suite 100, Columbia, MD 21045  
T: 410.992.3424 | F: 410.992.1837

March 2, 2021

Prince George's County Public Schools  
13300 Old Marlboro Pike  
Upper Marlboro, Maryland 20772  
Attention: Mr. Alex Baylor

RE: Indoor Air Quality Assessment, Glenridge Elementary School  
Purchase Order: 734977  
ATI Project Number: 20-694

Dear Mr. Baylor:

Prince George's County Public Schools requested that ATI, Inc., conduct a proactive indoor air quality (IAQ) assessment at Glenridge Elementary School on December 3, 2020 and a follow-up assessment on February 27, 2021. The assessments' key findings are enclosed in the Executive Summary on page three, and the official laboratory reports for total fungal spore trap sampling are enclosed in Appendix A.

Thank you for the opportunity to provide Industrial Hygiene services for Prince George's County Public Schools. If you have any questions regarding this report, please contact us at (202) 643-4283.

Sincerely,  
**ATI, INC.**

Reviewed By:

---

Mikal Frater  
Industrial Hygienist

---

Nate Burgei, CIH, CSP  
Certified Industrial Hygienist

# Indoor Air Quality Assessment Report

Prince George's County Public Schools  
Glenridge Elementary School  
7200 Gallatin Street  
Landover Hills, MD 20784

Prepared for:

Prince George's County Public Schools  
13300 Old Marlboro Pike  
Upper Marlboro, Maryland 20772

**March 2, 2021**

Submitted by:



ATI Job # 20-694

## Table of Contents

Table of Contents .....	1
1 Executive Summary .....	1
2 Assessment Methods .....	1
3 Visual Observations .....	2
4 Thermal Environmental Conditions for Human Occupancy .....	3
4.1 Temperature .....	3
4.2 Relative Humidity .....	4
4.3 Carbon Dioxide .....	5
4.4 Carbon Monoxide .....	6
5 Total Fungal Air Sampling Results .....	7
6 Summary of Findings .....	8

## List of Tables

<b>Table 1: Visual Observations and Sampling Locations .....</b>	<b>2</b>
<b>Table 2: Temperature .....</b>	<b>4</b>
<b>Table 3: Relative Humidity .....</b>	<b>5</b>
<b>Table 4: Carbon Dioxide .....</b>	<b>6</b>
<b>Table 5: Carbon Monoxide .....</b>	<b>6</b>
<b>Table 6: <i>Aspergillus/Penicillium</i> Concentration Comparison .....</b>	<b>8</b>

## Appendices

Appendix A: Laboratory Reports and Chain of Custody

Appendix B: Instrument Calibration Records

## Abbreviations and Acronyms

<b>AHU</b>	Air-Handling Unit
<b>AIHA</b>	American Industrial Hygiene Association
<b>ASHRAE</b>	American Society of Heating, Refrigerating and Air-Conditioning Engineers
<b>ASTM</b>	American Society for Testing and Materials
<b>CO</b>	Carbon Monoxide
<b>CO<sub>2</sub></b>	Carbon Dioxide
<b>EMLAP</b>	Environmental Microbiology Laboratory Accreditation Program
<b>HVAC</b>	Heating, Ventilating, And Air-Conditioning
<b>IAQ</b>	Indoor Air Quality
<b>NIST</b>	National Institute for Standards and Technology
<b>NVLAP</b>	National Voluntary Laboratory Accreditation Program
<b>RH</b>	Relative Humidity
<b>Rev.</b>	Revision

### **Abbreviations involving scientific volume and measurements involving media or water sampling**

<b>Spores/m<sup>3</sup></b>	Mold spores per cubic meter of air
<b>LPM</b>	Liters Per Minute
<b>NTE</b>	Not to exceed
<b>°F</b>	degree Fahrenheit
<b>PPM</b>	Parts Per Million

## 1 Executive Summary

---

ATI conducted a proactive Indoor Air Quality (IAQ) assessment on December 3, 2020, at Glenridge Elementary School, located at 7200 Gallatin Street, in Landover Hills, Maryland, and a follow-up assessment on February 27, 2021 in select rooms that had unusual results in the initial inspection.

The initial assessment on December 3, 2020 included a visual assessment of randomly selected classrooms and other frequently occupied spaces, such as the cafeteria/gym, the main office, and randomly selected classrooms, for potential IAQ contributors and pathways. The Main Office, Room 104, and Room 112 had unusual fungal spore concentrations during the initial assessment and were selected for a follow-up assessment after actions were taken to reduce the presence of mold and repair any water issues discovered. On February 27, 2021, select rooms were reassessed after unusual spore concentrations were present during the first assessment. Steps were taken between the two assessments to repair water issues and treat the area for fungal growth. As part of both assessments, ATI measured common IAQ comfort parameters, including temperature, relative humidity, carbon dioxide, and carbon monoxide. Also, ATI collected total fungal air samples on spore trap cassettes for microbiological analysis.

The following is a summary of the key findings from these assessments:

1. One of the tested spaces had a temperature less than the ASHRAE recommended winter range of 68°F - 75°F during the initial assessment. During the reassessment on February 27, one of the three tested spaces had a temperature less than the ASHRAE recommended winter range of 68°F - 75°F.
2. The relative humidity in all tested spaces was less than the ASHRAE guidelines of less than or equal to 65% during the initial December assessment, and two of tested rooms had relative humidity less than 30%, which can cause occupant discomfort. All three reassessed spaces on February 27 had a relative humidity less than 65% but greater than 30%.
3. Carbon dioxide concentrations in all tested spaces were less than the ASHRAE limits for carbon dioxide, which were 1,148 and 1,041 parts per million (ppm) for the day of the December assessment and February reassessment, respectively.
4. Carbon monoxide concentrations were less than the IAQ meter's detection limit throughout the tested spaces.
5. The spore trap sampling results from the initial assessment suggested some level of indoor amplification in the Main Office, Room 104, and Room 112. Other tested spaced did not suggest noteworthy amplification.
6. The February 27, 2021 reassessment showed a favorable decrease in *Aspergillus/Penicillium*-like spores in all of the tested spaces, ranging from a 95% decrease to a 100% decrease. The *Aspergillus/Penicillium*-like spore concentration in Room 104, while significantly dropping by 95%, was still greater than 1,000 spores/m<sup>3</sup>. The *Cladosporium* spore concentrations in Room 112 also dropped 76% but remained greater than 1,000 spores/m<sup>3</sup>. ATI recommends a thorough cleaning of Rooms 112 and 104 using HEPA vacuums to clean all vertical and horizontal surfaces, wet wiping all non-porous vertical and horizontal surfaces and materials and running HEPA equipped air scrubbers for at least 24 - 48 hours.

## 2 Assessment Methods

---

Mikal Frater, Industrial Hygienist of ATI, Inc. conducted the initial visual assessment and air sampling on December 3, 2020. Sampled rooms were randomly selected and accounted for approximately 10% of classrooms or a minimum of five samples. Ms. Frater documented visual observations at the time she collected the air samples. Ms. Frater conducted a follow-up inspection on February 27, 2021 in The Main Office, Room 104, and Room 112 after the areas were treated for mold presence. ATI references the American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) *Standard 62.1 – 2016* and *ASHRAE Standard 55 – 2017* when providing IAQ services to clients. ASHRAE is an industry leader on energy efficiency and indoor air quality.

All measurements and air samples were collected between three-six feet from floor elevation, which represents a typical adult breathing zone, and away from air-supply and return diffusers. Real-time direct readings for temperature, relative humidity, carbon dioxide (CO<sub>2</sub>), and carbon monoxide (CO), were measured with a calibrated TSI Q-Trak 7575-X Meter and attached 982 Probe.

Total fungal air samples were collected with a field calibrated Buck BioAire High-Volume Sampling Pump on Zefon Air-O-Cell spore-trap cassettes at a flow rate of 15 liters per minute for five minutes, for a sample volume of 75 liters. AMA Analytical Services, Inc. of Lanham, MD analyzed the samples using direct microscopic examination per ASTM D7391, which spores both viable and non-viable mold spores and particulates, which combined yields total fungal results. AMA participates in the National Institute of Standards and Technology’s (NIST) National Voluntary Laboratory Accreditation Program (NVLAP) for general laboratory performance and management, and the American Industrial Hygiene Association (AIHA) for Environmental Microbial Laboratory Accreditation Program (EMLAP). The AMA laboratory reports are included in Appendix A.

### 3 Visual Observations

Table 1 lists the areas, conditions, observations, and other pertinent details related to the initial and follow-up IAQ assessments. On both dates of sampling, few occupants were present in the school because of the COVID-19 global pandemic.

**Table 1: Visual Observations and Sampling Locations**

Sample Location	December 3, 2020 Observations
Outdoors – Parking Lot	<ul style="list-style-type: none"> <li>• Cloudy skies</li> <li>• Light foot and vehicle traffic observed</li> <li>• Light winds, about 12mph NW</li> </ul>
Main Office	<ul style="list-style-type: none"> <li>• Three occupants at time of assessment</li> <li>• Doors to corridor open at time of assessment</li> <li>• Light foot traffic in and out of space</li> <li>• Two air supplies and one return with light dust accumulation</li> <li>• Space is approximately 320 ft.<sup>2</sup></li> </ul>
Room 200	<ul style="list-style-type: none"> <li>• One occupant at time of assessment and door to hallway was open</li> <li>• No signs of major water intrusion</li> <li>• No stained ceiling tiles, area mostly clean with trace dust accumulation</li> <li>• One air supplier in the form of a wall unit, one return with light dust accumulation</li> <li>• Space is approximately 720 ft.<sup>2</sup></li> </ul>
Room 104	<ul style="list-style-type: none"> <li>• One occupant at time of assessment, and door to hallway was open</li> <li>• One air supplier in the form of a wall unit, four air returns</li> <li>• Various light brown stains on ceiling tiles</li> <li>• Space is approximately 880 ft.<sup>2</sup></li> </ul>
Gymnasium	<ul style="list-style-type: none"> <li>• Fans OFF at time of assessment</li> <li>• One occupant at time of assessment</li> </ul>
Room 112	<ul style="list-style-type: none"> <li>• One air supplier in the form of a wall unit, one return</li> <li>• Stained ceiling tiles towards back of room, in centralized location near whiteboard (similar to notes from previous assessment)</li> <li>• One occupant at time of assessment</li> <li>• Door to corridor open at time of assessment</li> <li>• No visible mold</li> </ul>

Sample Location	December 3, 2020 Observations
	<ul style="list-style-type: none"> <li>Space is approximately 880 ft.<sup>2</sup></li> </ul>
Room 223	<ul style="list-style-type: none"> <li>One occupant, and door to hallway was closed</li> <li>Moderate dust accumulation in this space</li> <li>Two air suppliers; one in the form of a wall unit, one air return</li> <li>Ceiling tiles and floors were clean</li> <li>Space is approximately 800 ft.<sup>2</sup></li> </ul>
Room 215	<ul style="list-style-type: none"> <li>One occupant at time of assessment</li> <li>Door to corridor open at time of assessment</li> <li>One air supplier in the form of a wall unit, off at time of sampling</li> <li>Space is approximately 800 ft.<sup>2</sup></li> </ul>
Sample Location	February 27, 2021 Reassessment Observations
Outdoors	<ul style="list-style-type: none"> <li>Cloudy skies, light rain</li> <li>Parking lot was mostly empty with little to no foot traffic</li> </ul>
Main Office	<ul style="list-style-type: none"> <li>Two occupants at time of assessment</li> <li>Door to corridor closed</li> <li>Doors to adjoining rooms open</li> <li>Central air off during assessment</li> <li>Trace dust accumulation on surfaces</li> </ul>
Room 112	<ul style="list-style-type: none"> <li>Vents to air unit open, with trace dust accumulation</li> <li>Two occupants at time of assessment</li> <li>Door to corridor open</li> <li>Light brown stained ceiling tile observed near front of classroom</li> </ul>
Room 104	<ul style="list-style-type: none"> <li>Door to corridor open</li> <li>AC unit and wall unit off at time of assessment</li> <li>Two occupants at time of assessment</li> <li>Trace dust accumulation on surfaces</li> <li>Light brown stained ceiling tile above bookshelf</li> </ul>

## 4 Thermal Environmental Conditions for Human Occupancy

ASHRAE *Standard 55-2017, Thermal Environmental Conditions for Human Occupancy*, addresses thermal comfort in an office environment, which means that an employee wearing a normal amount of clothing feels neither too cold nor too warm. This standard discusses thermal comfort within the context of air temperature, humidity, and air movement and provides recommended ranges for temperature and humidity that are intended to satisfy 80% of occupants. The recommended ASHRAE ranges are referenced below by each comfort parameter.

### 4.1 Temperature

The ASHRAE standard establishes a winter comfort range of between 68°F and 75°F and a summer range of between 73°F and 79°F. The temperatures measured during the December 3, 2020 initial assessment and reassessment from February 27, 2021 are summarized in Table 2. As indicated by the data in the table, temperatures in the school on December

3 averaged between 64°F and 76°F, with two tested locations greater than the ASHRAE recommended winter range and one location less than the recommended range. ATI recommends increasing the temperature in the main office if the occupants express concerns of being too cold.

ATI reassessed select rooms that had unusual fungal spore concentrations on February 27, 2021, after remediation actions were completed. ATI also reassessed the temperature in the reassessed rooms. The average temperatures in the reassessed locations range between 62°F and 75°F, with one tested location measuring less than the ASHRAE recommended winter range.

**Table 2: Temperature**

Sample Location	12/03/2020 Initial Assessment Temperature in °F			ASHRAE Standard °F
	Min	Max	Average	
Outdoors	46	47	47	N/A
<b>Indoors</b>				
Main Office	62	65	64	68°F - 75°F
Room 200	70	70	70	68°F - 75°F
Room 104	72	72	72	68°F - 75°F
Gymnasium	75	76	76	68°F - 75°F
Room 112	76	76	76	68°F - 75°F
Room 223	69	71	70	68°F - 75°F
Room 215	72	72	72	68°F - 75°F
<b>February 27, 2021 Reassessment Temperature in °F</b>				
Outdoors	42	43	43	N/A
<b>Indoors</b>				
Main Office	61	63	62	68°F - 75°F
Room 112	74	75	75	68°F - 75°F
Room 104	74	74	74	68°F - 75°F

**4.2 Relative Humidity**

Relative humidity is a key factor for mold growth. Mold has the potential of growing on suitable surfaces with humidity levels above 65%. ASHRAE *Standard 62.1-2016, Ventilation for Acceptable Indoor Air Quality*, recommends a maximum indoor relative humidity of 65% to prevent condensation of moisture on surfaces. Relative humidity less than 30% may result in drying of occupants’ mucous membranes and skin. Relative humidity measurements for December 3, 2020 and February 27, 2021 are summarized in Table 3. As indicated by the data in the table, the average relative humidity ranged between 21% and 42% with all tested locations measuring less than the ASHRAE maximum recommendation of 65% relative humidity, and three of the tested locations also measuring less than 30% relative humidity.

ATI reassessed select rooms that had unusual fungal spore concentrations on February 27, 2021, after remediation actions were completed. ATI also reassessed the relative humidity in the space during the reassessment, and the average relative humidity ranged between 34% and 54% with all tested locations measuring less than the ASHRAE maximum recommendation of 65% relative humidity.



**Table 3: Relative Humidity**

Sample Location	12/03/2020 Initial Assessment Relative Humidity (%RH)			ASHRAE Standard (% RH)
	Min	Max	Average	
Outdoors	32	42	37	N/A
<b>Indoors</b>				
Main Office	35	38	37	≤ 65
Room 200	37	37	37	≤ 65
Room 104	31	32	32	≤ 65
Gymnasium	25	26	26	≤ 65
Room 112	21	21	21	≤ 65
Room 223	23	26	25	≤ 65
Room 215	42	42	42	≤ 65
February 27, 2021 Reassessment Relative Humidity (%RH)				
Outdoors	70	78	74	N/A
<b>Indoors</b>				
Main Office	51	57	54	≤ 65
Room 112	38	39	39	≤ 65
Room 104	33	34	34	≤ 65

### 4.3 Carbon Dioxide

Carbon dioxide concentrations within an occupied building are a standard method used to gauge the efficiency of ventilation systems. Carbon dioxide is a by-product of human respiration and does not pose an acute health hazard alone. Elevated concentrations may suggest that insufficient fresh air is being supplied to an occupied space and/or that the ventilation system does not provide a sufficient rate of air exchange.

Research has indicated that buildings with adequately operating ventilation systems are able to remove odors generated by activities in an indoor office environment efficiently. ASHRAE *Standard 62.1-2016* states that comfort (odor) criteria with respect to human bioeffluents are likely to be satisfied if the ventilation can maintain indoor carbon dioxide concentrations less than 700 parts per million (ppm) greater than the outdoor air concentration. Typically, outdoor carbon dioxide concentrations range from 300 ppm to 450 ppm, with the higher range typically found in urban areas during peak rush hour.

Carbon dioxide concentrations for December 3, 2020 are summarized in Table 4. On the day of the assessment, the average outdoor carbon dioxide concentration was 448 ppm, which calculates to a maximum indoor concentration of 1,148 ppm (700 + 448). All tested locations indoors were less than the recommended maximum for the day of the assessment.

ATI reassessed select rooms that had unusual fungal spore concentrations on February 27, 2021 after remediation actions were completed. The carbon dioxide concentrations measured during the reassessment are included in Table 4. The average outdoor carbon dioxide concentration on February 27, 2021 was 341 ppm, which calculates to a maximum indoor concentration of 1,041 ppm (700 + 341). All tested locations indoors were less than the recommended maximum for the day of the reassessment.

**Table 4: Carbon Dioxide**

Sample Location	12/03/2020 Initial Assessment Concentration (parts per million)			ASHRAE Standard (ppm) NTE
	Min	Max	Average	
Outdoors	428	467	448	N/A
<b>Indoors</b>				
Main Office	505	565	535	< 1,148
Room 200	394	396	395	< 1,148
Room 104	387	395	391	< 1,148
Gymnasium	392	438	415	< 1,148
Room 112	408	418	413	< 1,148
Room 223	405	405	405	< 1,148
Room 215	421	439	430	< 1,148
<b>February 27, 2021 Reassessment Concentration (parts per million)</b>				
Outdoors	324	358	341	N/A
<b>Indoors</b>				
Main Office	395	401	398	< 1,041
Room 112	426	428	427	< 1,041
Room 104	427	451	439	< 1,041

**4.4 Carbon Monoxide**

Carbon monoxide is a colorless and odorless gas produced by the incomplete combustion of carbon containing fuels. Oil, gasoline, diesel fuels, wood, coke, and coal are the major sources of carbon monoxide. ASHRAE recommends that carbon monoxide not exceed nine ppm indoors over an eight-hour time-weighted average. ATI measured carbon monoxide concentrations using a TSI Q-Trak model number 7575-X with an attached IAQ probe (model number 982). The instrument’s carbon monoxide sensor has an error range of ± 3% of the reading or three (3) ppm, whichever is greater. As indicated by the data in Table 5, carbon monoxide concentrations for December 3, 2020 were less than the Q-Trak’s detection limit throughout the school.

ATI reassessed select rooms that had unusual fungal spore concentrations on February 27, 2021, after remediation actions were completed. The carbon monoxide concentrations measured during the reassessment are included in Table 5. The carbon monoxide concentrations from the reassessment were also less than the Q-Trak’s limit of detection and less than the EPA/ASHRAE recommended maximum of 9 ppm.

**Table 5: Carbon Monoxide**

Sample Location	12/03/2020 Initial Assessment Concentration (parts per million)			ASHRAE Standard (ppm)
	Min	Max	Average	
Outdoors	< 3	< 3	< 3	N/A
<b>Indoors</b>				
Main Office	< 3	< 3	< 3	< 9
Room 200	< 3	< 3	< 3	< 9
Room 104	< 3	< 3	< 3	< 9
Gymnasium	< 3	< 3	< 3	< 9
Room 112	< 3	< 3	< 3	< 9

Room 223	< 3	< 3	< 3	< 9
Room 215	< 3	< 3	< 3	< 9
<b>February 27, 2021 Reassessment Concentration (parts per million)</b>				
Outdoors	< 3	< 3	< 3	N/A
<b>Indoors</b>				
Main Office	< 3	< 3	< 3	< 9
Room 112	< 3	< 3	< 3	< 9
Room 104	< 3	< 3	< 3	< 9

## 5 Total Fungal Air Sampling Results

Mold is carried indoors through building entrances, open windows, loading docks, foot traffic into buildings, and the HVAC system. To thrive indoors, mold requires a food source, proper temperature and humidity to foster its growth.

The December 3, 2020 and February 27, 2021 mold assessments sampled air using spore trap cassettes in randomly selected classrooms and other areas throughout the facility. These cassettes collect both viable spores, those capable of producing more fungal colonies, and non-viable spores, which cannot reproduce. Based upon recognized industry practices, indoor mold concentrations are compared with those detected outdoors, which are also known as ambient or baseline samples.

In normal circumstances, the diversity of spores identified indoors and outdoors should be similar with some exceptions. The high concentration of one or two species of fungal spores identified indoors and the absence of the same species outdoors can indicate a moisture problem with the potential to degrade the air quality. Fungi species present indoors are typically found at levels ranging from approximately 10-50% of their levels in the outdoor air, reflecting the filtering by the building’s HVAC system.

The results from December 3, 2020 suggested unusual mold spore concentrations in three locations: Main Office, Room 112, and Room 104. The total ambient, outdoor spore concentration was 1,404 spores/m<sup>3</sup>. Room 104 had the greatest total spore concentration of 36,062 spores/m<sup>3</sup>, with *Aspergillus/Penicillium*-like spores being the predominant spores present at 36,010 spores/m<sup>3</sup>. Room 112 and the Main Office had total spore concentrations of 8,892 spores/m<sup>3</sup> and 4,836 spores/m<sup>3</sup>, respectively, with *Aspergillus/Penicillium*-like being the predominant spore type in each room. The *Cladosporium* concentration in Room 112 was 5,252 spores/m<sup>3</sup>, which was also greater than the outdoor concentration.

The fungal spore concentrations in the Main Office, Room 104 and Room 112 are greater than the typical occupied space and suggest at least some level of mold amplification indoors. ATI recommended evaluating these rooms and the surrounding areas to try and identify water sources, abate any mold issues and clean the area before retesting the space.

The Main Office, Room 112, and Room 104 were reassessed on February 27, 2021 after the initial assessment indicated the unusual presence of airborne mold spores. The total ambient, outdoor spore concentration was 4,293 spores/m<sup>3</sup>, with most of the spore types identified as ascospores and no detectable presence of *Aspergillus/Penicillium*-like spores, or *Cladosporium*. Room 104 had the greatest total spore concentration of 1,855 spores/m<sup>3</sup>, with *Aspergillus/Penicillium*-like spores being the predominant spores present at 1,749 spores/m<sup>3</sup>. Room 112 and the Main Office had total spore concentrations of 1,802 spores/m<sup>3</sup> and 371 spores/m<sup>3</sup>, respectively. The *Cladosporium* concentration in Room 112 was 1,272 spores/m<sup>3</sup>, which was also greater than the outdoor concentration.

While there was a significant reduction in airborne mold spores in Rooms 104 and 112, Room 112 had *Cladosporium* concentrations greater than 1,000 spores/m<sup>3</sup> and Room 104 had an *Aspergillus/Penicillium*-like spore concentration greater than 1,000 spores/m<sup>3</sup>. It is possible that the measured spore concentrations in the spaces on February 27 were residual spores due to insufficient cleaning; therefore, ATI recommends using HEPA vacuums to clean all vertical and horizontal surfaces, wet

wiping all non-porous vertical and horizontal surfaces and materials and running HEPA equipped air scrubbers for at least 24 - 48 hours.

**Table 6: *Aspergillus/Penicillium* Concentration Comparison**

Sample Location	December 3, 2020 Concentrations	February 27, 2021 Concentrations	% Change
Main Office	4,576	212	-95%
Room 112*	2,860	None Detected	-100%
Room 104	36,010	1,749	-95%

\*Room 112 also had a *Cladosporium* concentration of 5,252 spores/m<sup>3</sup> during the initial assessment and a concentration of 1,272 spores/m<sup>3</sup> during the follow-up assessment, which is a drop of 76%.

The official laboratory reports with spore trap samples collected on December 3, 2020 and February 27, 2021 are presented in Appendix A.

## 6 Summary of Findings

1. One of the tested spaces had a temperature less than the ASHRAE recommended winter range of 68°F - 75°F during the initial assessment. During the reassessment on February 27, one of the three tested spaces had a temperature less than the ASHRAE recommended winter range of 68°F - 75°F.
2. The relative humidity in all tested spaces was less than the ASHRAE guidelines of less than or equal to 65% during the initial December assessment, and two of tested rooms had relative humidity less than 30%, which can cause occupant discomfort. All three reassessed spaces on February 27 had a relative humidity less than 65% but greater than 30%.
3. Carbon dioxide concentrations in all tested spaces were less than the ASHRAE limits for carbon dioxide, which were 1,148 and 1,041 parts per million (ppm) for the day of the December assessment and February reassessment, respectively.
4. Carbon monoxide concentrations were less than the IAQ meter's detection limit throughout the tested spaces.
5. The spore trap sampling results from the initial assessment suggested some level of indoor amplification in the Main Office, Room 104, and Room 112. Other tested spaced did not suggest noteworthy amplification.
6. The February 27, 2021 reassessment showed a favorable decrease in *Aspergillus/Penicillium*-like spores in all of the tested spaces, ranging from a 95% decrease to a 100% decrease. The *Aspergillus/Penicillium*-like spore concentration in Room 104, while significantly dropping by 95%, was still greater than 1,000 spores/m<sup>3</sup>. The *Cladosporium* spore concentrations in Room 112 also dropped 76% but remained greater than 1,000 spores/m<sup>3</sup>. ATI recommends a thorough cleaning of Rooms 112 and 104 using HEPA vacuums to clean all vertical and horizontal surfaces, wet wiping all non-porous vertical and horizontal surfaces and materials and running HEPA equipped air scrubbers for at least 24 - 48 hours.

We appreciate the opportunity to provide these IAQ testing services for you. If you have any questions, please contact us at (202) 643-4283.

Best,  
**ATI, INC.**

*Mikal Frater*

Mikal Frater  
 Industrial Hygienist

**Appendix A: Laboratory Report and Chain of Custody**

# CERTIFICATE OF ANALYSIS

## ASTM D7391-09 Spore Trap Analysis Report

**Chain of Custody:** 624357  
**Client:** ATI, Inc.  
**Address:** 9220 Rumsey Road  
Suite 100  
Columbia, MD 21045  
**Attention:** Courtney McCall

**Job Name:** Glenridge Elementary School IAQ  
**Job Location:** Hyattsville, MD  
**Job Number:** 20-694  
**P.O. Number:** Not Provided

**Date Submitted:** 12/03/2020  
**Person Submitting:** Mikal Frater  
**Date Analyzed:** 12/07/2020  
**Report Date:** 12/08/2020

**AMA Sample #** 624357-1  
**Client ID** 20-694-1  
**Analyst ID** CD  
**Collection Apparatus** Air-O-Cell  
**Sample Volume (L)** 75  
**Sample Condition** Acceptable  
**Debris Loading** 2  
**Location** Outdoors - Parking Lot

**AMA Sample #** 624357-2  
**Client ID** 20-694-2  
**Analyst ID** CD  
**Collection Apparatus** Air-O-Cell  
**Sample Volume (L)** 0  
**Sample Condition** Acceptable  
**Debris Loading** 0  
**Location** Field Blank

**AMA Sample #** 624357-3  
**Client ID** 20-694-3  
**Analyst ID** CD  
**Collection Apparatus** Air-O-Cell  
**Sample Volume (L)** 75  
**Sample Condition** Acceptable  
**Debris Loading** 2  
**Location** Main Office

	Raw Ct	Trav/Flds	A.S.	sp/m <sup>3</sup>	%		Raw Ct	Trav/Flds	A.S.	sp/m <sup>3</sup>	%		Raw Ct	Trav/Flds	A.S.	sp/m <sup>3</sup>	%	
Alternaria						Alternaria						Alternaria						
Ascospores	6	15	52	312	22.2%	Ascospores						Ascospores	2	15	52	104	2.2%	
Basidiospores	11	15	52	572	40.7%	Basidiospores						Basidiospores	1	15	52	52	1.1%	
Bipolaris/Drechslera/Helm.						Bipolaris/Drechslera/Helm.						Bipolaris/Drechslera/Helm.						
Chaetomium						Chaetomium						Chaetomium						
Cladosporium	Present	15	52	<52		Cladosporium						Cladosporium	1	15	52	52	1.1%	
Curvularia						Curvularia						Curvularia						
Penicillium / Aspergillus	8	15	52	416	29.6%	Penicillium / Aspergillus						Penicillium / Aspergillus	88	15	52	4576	94.6%	
Smuts/Periconia/Myxomycetes	2	15	52	104	7.4%	Smuts/Periconia/Myxomycetes						Smuts/Periconia/Myxomycetes						
Stachybotrys/Memnoniella						Stachybotrys/Memnoniella						Stachybotrys/Memnoniella						
Ulocladium						Ulocladium						Ulocladium						
Unknown						Unknown						Unknown						
Torula						Torula						Torula	1	15	52	52	1.1%	
Pithomyces						Pithomyces						Pithomyces						
Hyphal Fragments*						Hyphal Fragments*						Hyphal Fragments*						
<b>Total Raw Ct:</b>	27					<b>Total Raw Ct:</b>	0					<b>Total Raw Ct:</b>	93					
<b>Total sp/m<sup>3</sup>:</b>				1404		<b>Total sp/m<sup>3</sup>:</b>				0		<b>Total sp/m<sup>3</sup>:</b>				4836		

Comments

Comments

Comments

No Mold Spores Observed

# CERTIFICATE OF ANALYSIS

## ASTM D7391-09 Spore Trap Analysis Report

**Chain of Custody:** 624357  
**Client:** ATI, Inc.  
**Address:** 9220 Rumsey Road  
Suite 100  
Columbia, MD 21045  
**Attention:** Courtney McCall

**Job Name:** Glenridge Elementary School IAQ  
**Job Location:** Hyattsville, MD  
**Job Number:** 20-694  
**P.O. Number:** Not Provided

**Date Submitted:** 12/03/2020  
**Person Submitting:** Mikal Frater  
**Date Analyzed:** 12/07/2020  
**Report Date:** 12/08/2020

**AMA Sample #** 624357-4  
**Client ID** 20-694-4  
**Analyst ID** CD  
**Collection Apparatus** Air-O-Cell  
**Sample Volume (L)** 75  
**Sample Condition** Acceptable  
**Debris Loading** 1  
**Location** Room 200

**AMA Sample #** 624357-5  
**Client ID** 20-694-5  
**Analyst ID** CD  
**Collection Apparatus** Air-O-Cell  
**Sample Volume (L)** 75  
**Sample Condition** Acceptable  
**Debris Loading** 2  
**Location** Room 104

**AMA Sample #** 624357-6  
**Client ID** 20-694-6  
**Analyst ID** CD  
**Collection Apparatus** Air-O-Cell  
**Sample Volume (L)** 75  
**Sample Condition** Acceptable  
**Debris Loading** 1  
**Location** Gymnasium

	Raw Ct	Trav/Flds	A.S.	sp/m <sup>3</sup>	%		Raw Ct	Trav/Flds	A.S.	sp/m <sup>3</sup>	%		Raw Ct	Trav/Flds	A.S.	sp/m <sup>3</sup>	%	
Alternaria						Alternaria						Alternaria						
Ascospores	1	15	52	52	33.3%	Ascospores						Ascospores	4	15	52	208	40%	
Basidiospores	1	15	52	52	33.3%	Basidiospores						Basidiospores	5	15	52	260	50%	
Bipolaris/Drechslera/Helm.						Bipolaris/Drechslera/Helm.						Bipolaris/Drechslera/Helm.						
Chaetomium						Chaetomium						Chaetomium						
Cladosporium						Cladosporium						Cladosporium						
Curvularia						Curvularia						Curvularia						
Penicillium / Aspergillus	1	15	52	52	33.3%	Penicillium / Aspergillus	277	6	130	36010	99.6%	Penicillium / Aspergillus	1	15	52	52	10%	
Smuts/Periconia/Myxomycetes						Smuts/Periconia/Myxomycetes	1	15	52	52	0.4%	Smuts/Periconia/Myxomycetes						
Stachybotrys/Memnoniella						Stachybotrys/Memnoniella						Stachybotrys/Memnoniella						
Ulocladium						Ulocladium						Ulocladium						
Unknown						Unknown						Unknown						
Torula						Torula						Torula						
Pithomyces						Pithomyces	Present	15	52	<52		Pithomyces						
Hyphal Fragments*						Hyphal Fragments*						Hyphal Fragments*						
<b>Total Raw Ct:</b>	3					<b>Total Raw Ct:</b>	278					<b>Total Raw Ct:</b>	10					
<b>Total sp/m<sup>3</sup>:</b>				156		<b>Total sp/m<sup>3</sup>:</b>				36062		<b>Total sp/m<sup>3</sup>:</b>					520	

**Comments**  
Very Light Trace

**Comments**

**Comments**





# CERTIFICATE OF ANALYSIS

## ASTM D7391-09 Spore Trap Analysis Report

**Chain of Custody:** 624357  
**Client:** ATI, Inc.  
**Address:** 9220 Rumsey Road  
 Suite 100  
 Columbia, MD 21045  
**Attention:** Courtney McCall

**Job Name:** Glenridge Elementary School IAQ  
**Job Location:** Hyattsville, MD  
**Job Number:** 20-694  
**P.O. Number:** Not Provided

**Date Submitted:** 12/03/2020  
**Person Submitting:** Mikal Frater  
**Date Analyzed:** 12/07/2020  
**Report Date:** 12/08/2020

### Spore Comparison Guide

The criteria for these specifications are outlined, but not limited to those listed, below. Final specifications may differ from the listed criteria for certain samples. AMA Analytical Services, Inc. reserves the right to make changes to these criteria at any time without notice.



Stachybotrys / Memnoniella, and Chaetomium	Other Spores* (Control Present)	Other Spores* (No Control)
1-4 Spores: Yellow 5-9 Spores: Orange 10+ Spores: Red	< 10 Spores: Insignificant (no color) <= Control's spore count: Green Between Control and 2x Control: Yellow Between 2x Control and 3x Control: Orange 3x+ Control: Red	< 10 Spores: Insignificant (no color) 10-20 Spores: Yellow 20-50 Spores: Orange 50+ Spores: Red

\*No evaluation is provided for the following spore types: Other, Other Colorless, and Unknown Fungi, and Misc

Interpretation of the data contained in this report is the sole responsibility of the client or the persons who conducted the field work. There are no federal or national standards for the number of fungal spores that may be present in the indoor environment. As a general rule and guideline that is widely accepted in the indoor air quality field, the numbers and types of spores that are present in the indoor environment should be comparable to those that are present outdoors at any given time. There will always be some mold spores present in "Normal" indoor environments. The purpose of sampling and counting spores is to help determine whether an abnormal condition exists within the indoor environment and if it does, to help pinpoint the area of contamination. Spore counts should not be used as the sole determining factor of mold contamination. There are many factors that can cause anomalies in the comparison of indoor and outdoor samples due to the dynamic nature of both of those environments.

This report is provided for informational and comparative purposes only and should not be relied upon for any other purpose. Sampling techniques, possible contaminants, unrepresentative samples and other similar or dissimilar factors may affect these results. With the statistical evaluation provided, as with all statistical comparisons and analyses, false-positive and false-negative results can and do occur. AMA Analytical Services, Inc. hereby disclaims any liability for any and all direct, indirect, punitive, incidental, special or consequential damages arising out of the use or interpretation of the data contained in, or any actions taken or omitted in reliance upon, this report.

# CERTIFICATE OF ANALYSIS

## ASTM D7391-09 Spore Trap Analysis Report

<b>Chain of Custody:</b> 624357	<b>Job Name:</b> Glenridge Elementary School IAQ	<b>Date Submitted:</b> 12/03/2020
<b>Client:</b> ATI, Inc.	<b>Job Location:</b> Hyattsville, MD	<b>Person Submitting:</b> Mikal Frater
<b>Address:</b> 9220 Rumsey Road	<b>Job Number:</b> 20-694	<b>Date Analyzed:</b> 12/07/2020
Suite 100	<b>P.O. Number:</b> Not Provided	<b>Report Date:</b> 12/08/2020
Columbia, MD 21045		
<b>Attention:</b> Courtney McCall		

### General Comments, Disclaimers, and Footnotes

**Analytical Method:** Sample are analyzed following the instructions and guidelines outlined in ASTM 7391-09.

**Sample Condition:** Acceptable: The sample was collected and delivered to the our location without disturbing the material on the sampling media.  
Unacceptable: 1. The sample trace (TR) has been disturbed. 2. The sample was damaged or otherwise unsuitable for analysis.  
0 = No particulate matter detected; 1 = >nd-~5% Particulate Loading; 2 = ~5%-25% Particulate Loading; 3 = ~25%- 75% Particulate Loading; 4 = ~75%-90% Particulate Loading; 5 = >90% Particulate Loading

**Spore Notes:** Based on their small size and very few distinguishing characteristics, Aspergillus and Penicillium cannot be differentiated by non-viable sampling methods. There are other types of spores whose morphology is similar to Aspergillus and Penicillium and cannot be differentiated by non-viable sampling methods. Examples of these similar spores are Acremonium, Paecilomyces, Wallemia, Trichoderma, Scopulariopsis, and Gliocladium.  
Smuts, Periconia and Myxomycetes are three different types of genera that have similar morphological characteristics.  
Bipolaris/Dreschlera/Helm: Bipolaris / Dreschlera / Helminthosporium are three different types of genera that have smiliar morphological characteristics.  
Other Colorless represents all colorless spores that are non-distinctive and unidentifiable.  
\*Hyphal Fragments: A portion of the mycelium that becomes separated from the remainder of the thallus (vegetative body), each of which has the capacity to grow and form new individuals. Results for hyphal fragments are in fragments/m3 and are not incorporated in the total spore concentration.  
The droplet symbol (💧) refers to water-intrusion indicator spores. These fungal spores, when found on indoor air samples, can be an indication of moisture sources and resultant fungal growth that may be problematic.

**Quantification:** Analytical Sensitivity (A.S.): This is dependent on the volume of air collected, size of the trace, ocular diameter, and the amount of the trace that was analyzed.  
The value of "Present" indicated in the Raw Count column represents the presence of this spore type during the preliminary exam at 400x. The Raw Count converts to a whole number if the spore type is encountered again during the 600x-1,000x enumeration. The sp/m3concentration will be reported as less than the analytical sensitivity if "Present" is reported in the Raw Count.  
Results are reported to 3 significant figures. sp/m3: Spores per cubic meter.  
Uncertainty: for raw count in the range of 0-50 the SR is 0.375, 51-100 SR=0.333, 101-200 SR=0.257, >200 SR=0.245  
All results are to be considered preliminary and subject to change unless signed by the Technical Director or Deputy.  
**Analyst(s):** Christopher Dell



**Technical Director** Tristan Ward

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations, and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client.

## MOLD SPORE DESCRIPTIONS

### Ascospores

Ascospores are spores formed inside an ascus (asci-plural) or sac-like cell which is contained inside a fruiting body called an ascocarp or an ascoma (ascomata-plural). An ascus typically contains a definite number of ascospores, usually eight. Ascospores are unique in shape, size, and color as to the Genus/species they represent. These spores are specific to fungi classified as Ascomycetes. They are ubiquitous in nature. Many decay organic matter, others are plant or animal pathogens. They can grow indoors on damp materials. Release of ascospores are released by forcible ejection and dispersed by wind, water, animals and other agents. Health Effects: Depending on the Genera, Ascospores may be allergenic.

### Basidiospores

Basidiospores are reproductive spores produced by a group of fungi called basidiomycetes. This group includes the mushrooms, shelf fungi and various other macrofungi. Basidiospores serve as the main air (wind) dispersal units for the fungi and their release is dependent upon moisture. The structure of the spore complex can develop in various manners resulting in different appearances. It is often found growing in soil, decaying plant debris, compost piles and fruit rot. Indoors, it can be found on water damaged building materials (chipboard /OSB, plywood, wallpaper, and glue) as well as on food items (dried foods, cheeses, fruits, herbs, spices, cereals). Health effects: Some basidiospores may produce toxins and can act as allergens. They have not been reported to be pathogens.

### Cladosporium

Cladosporium is the most common indoor and outdoor mold. The spores are wind dispersed and are often extremely abundant in outdoor air. Many species are commonly found on living and dead plant material. Indoors, they may grow on surfaces with high moisture or high humidity levels such as damp window sills, poorly ventilated bathrooms and soiled refrigerators. It produces powdery or velvety olive-green to brown or black colonies. The conidia (spores) vary depending on the species and are formed in simple or branching chains with multi-attachment points. Health Effects: Cladosporium species are rarely pathogenic to humans, but have been reported to occasionally cause sinusitis and pulmonary infections as well as infections of the skin and toenails. The airborne spores are significant allergens, and in large amounts they may severely affect asthmatics and people with respiratory diseases.

### Penicillium/Aspergillus Like

Penicillium and Aspergillus are ubiquitous, filamentous fungi that are found in soil, decaying plant debris, compost piles, and in the air. Indoors, spores are commonly found in house dust, in water-damaged buildings (wallpaper, wallpaper glue, decaying fabrics, moist chipboards, and behind paint) as well as fruit and grains. They are the most common fungal genera, worldwide. Both produce chains of spores that are small, round to oval, colorless or slightly pigmented, and smooth to rough walled. These spores are indistinguishable between the two as well as other genera, such as Gliocladium, Trichoderma, Paecilomyces, and Scopulariopsis. They differ as to their conidiophores or fruiting bodies. While, Aspergillus spores are produced from phialides supported on conidia heads or swollen vesicles, Penicillium spores are produced on finger-like projections. Depending on species, typical colonies of Aspergillus are initially white and later turn to either shades of green, yellow, orange, brown or black. Texture is usually velvety to cottony. Typical colonies of Penicillium, other than Penicillium marneffeii (yeast-like at 37oC), grow rapidly, white in color at first, later becoming bluish green with white borders with velvety to powdery textures depending on species. Some species produce radial patterns. Health Effects: Both Aspergillus and Penicillium are potential allergens. Several species of Aspergillus (*A. flavus* and *A. parasiticus*) produce aflatoxins or naturally occurring mycotoxins that are toxic and carcinogenic. These are found in contaminated foodstuff and are hazardous to consumers. Penicillium has only one known species that is pathogenic to humans (*P. marneffeii*) that causes lethal systemic infection (Penicilliosis) in immunocompromised individuals.

### Pithomyces

Pithomyces is a cosmopolitan, dark-walled fungus often found growing outside in soil, decaying leaves, and grasses. It is rarely found growing indoors, but will grow on paper given the right conditions. Colonies grow rapidly, cottony in texture with light to dark brownish black surface color. Spores are single, oval yellow to dark brown, multi-celled, and usually rough. One identification feature of the spores is the resemblance to barrels. Another identifying character is beak-like structures on young spores. Spores of *Pithomyces chartarum* are most common and are identified by distinctive transverse septa. This species has been linked to facial eczema in sheep. Health Effects: It is a potential but not well-studied allergen or human pathogen.

## Smuts/Periconia/Myxomycetes

Smuts, Periconia, and Myxomycetes spores are grouped together due to their similar round, brown morphology. Smuts are outdoor parasitic plant pathogens. They rarely grow indoors but may grow on host plants if appropriate conditions are present. They are parasitic plant pathogens. They can be found on cereal crops, grasses, flowering plants, weed, and other fungi. They can cause allergies. Periconia are found in soils, dead herbaceous stems and leaf spots, and grasses. They have wind dispersed dry spores. Their spores are abundant in the air but it is not known if they are allergenic. Myxomycetes are found on decaying logs, stumps and dead leaves. They have wind-dispersed dry spores and wet motile (amoebic phase) spores. During favorable conditions they move about like amoebae. They form dry airborne spores when conditions are unfavorable. They are rarely found indoors. Health Effects: They may cause Type 1 allergies (hay fever, asthma). No human infections have been reported.

## Torula

Torula is a cosmopolitan, dark-walled fungus often found growing outside in soil, dead herbaceous stems, wood, grasses, and seeds. It can grow indoors on cellulose containing materials. It is frequently found in temperate regions. Torula spores are colored in shades of brown, from pale brown to reddish brown. Spores are formed in simple or branched chains, one to several cells long that are often detached. A cup-like indentation at the point of detachment is characteristic of these spores. Health Effects: Torula is an allergen, which may cause hay fever and asthma. It has not been reported to be pathogenic to humans or produce toxins.





Analytical Services, Inc.

Focus: Results www.amalab.com

AIHA-LAP (#100470) NVLAP (#101143-0) NY ELAP (10920)

4475 Forbes Blvd. • Lanham, MD 20706

(301) 459-2640 • (800) 346-0961 • Fax (301) 459-2643

# CHAIN OF CUSTODY

(Please Refer To This Number For Inquires)

6024357

### Mailing/Billing Information:

- Client Name: ATI, Inc.
- Address 1: 4221 Forbes Blvd
- Address 2: Suite 250
- Address 3: Lanham, MD 20706
- Phone #: \_\_\_\_\_ Fax #: \_\_\_\_\_

### Submittal Information:

- Job Name: Glenridge ES IAQ
- Job Location: Hvattsville, MD
- Job #: 20-694 P.O. #: \_\_\_\_\_
- Contact Person: Mikal Frater Cell: (848) 702-8621
- Collected by: Mikal Frater Cell: (848) 702-8621

Reporting Info (Results provided as soon as technically feasible). If no TAT/Reporting Info is provided, AMA will assign defaults of 5-Day and email/fax to contacts on file.

<b>AFTER HOURS (must be pre-scheduled)</b> <input type="checkbox"/> 4 Hours <input type="checkbox"/> Late Night <input type="checkbox"/> Immediate Date Due: _____ <input type="checkbox"/> 24 Hours Time Due: _____ Comments: _____		<b>NORMAL BUSINESS HOURS</b> <input type="checkbox"/> 4 Hours <input type="checkbox"/> 3 Day <input type="checkbox"/> Same Day <input type="checkbox"/> 5 Day + <input checked="" type="checkbox"/> Results Required By Noon <input type="checkbox"/> Next Day <input type="checkbox"/> 2 Day Date Due: <u>12/11/20</u>		<b>REPORT TO:</b> <input checked="" type="checkbox"/> Email: <u>Mikal@atinc.com</u> <input checked="" type="checkbox"/> Email 2: <u>Courtney@atinc.com</u> <input type="checkbox"/> Verbals: _____
--	--	--	--	---

### Asbestos Analysis

\*PCM Air - Please Indicate Filter Type: \_\_\_\_\_

- NIOSH 7400 (QTY)
- Fiberglass (QTY)

TEM Air\* - Please Indicate Filter Type: \_\_\_\_\_

- AHERA (QTY)
- NIOSH 7402 (QTY)
- Other (specify \_\_\_\_\_) (QTY)

### PLM Bulk

- EPA 600 - Visual Estimate (QTY)  Pos Stop
- EPA Point Count (QTY)
- NY State Friable 198.1 (QTY)
- Grav. Reduction ELAP 198.6 (QTY)
- Other (specify \_\_\_\_\_) (QTY)

### MISC

- Asbestos Soil PLM (Qual) PLM (Quan) PLM/TEM (Qual) PLM/TEM (Quan)

\*It is recommended that blank samples be submitted with all air and surface samples

### TEM Bulk

- ELAP 198.4/Chatfield (QTY)
- NY State PLM/TEM (QTY)
- Residual Ash (QTY)
- Vermiculite

### TEM Dust\*

- Qual. (pres/abs) Vacuum/Dust (QTY)
- Quan. (s/area) Vacuum D5755-95 (QTY)
- Quan. (s/area) Dust D6480-99 (QTY)

### TEM Water

- Qual. (pres/abs) (QTY)
- ELAP 198.2/EPA 100.2 (QTY)
- EPA 100.1 (QTY)

All samples received in good condition unless otherwise noted. (TEM Water samples \_\_\_\_\_ °C)

If field data sheets are submitted, there is no need to complete bottom section.

### Metals Analysis

- Pb Paint Chip (QTY)
- \*Pb Dust Wipe (wipe type \_\_\_\_\_) (QTY)
- \*Pb Air (QTY)
- Pb Soil/Solid (QTY)
- Pb TCLP (QTY)
- Drinking Water  Pb (QTY)  Cu (QTY)  As (QTY)
- Waste Water  Pb (QTY)  Cu (QTY)  As (QTY)
- Pb Furnace (Media \_\_\_\_\_) (QTY)

### Fungal Analysis

- Collection Apparatus for Spore Traps/Air Samples: \_\_\_\_\_
- Collection Media \_\_\_\_\_
- \*Spore-Trap 9 (QTY)  Surface Vacuum Dust (QTY)
- \*Surface Swab (QTY)
- \*Surface Tape (QTY)
- Other (Specify \_\_\_\_\_) (QTY)

CLIENT ID #	SAMPLE INFORMATION SAMPLE LOCATION/ ID	DATE/ TIME	VOL (L)/ Wipe Area	ANALYSIS						MATRIX					COMMENTS / SPECIAL INSTRUCTIONS			
				TEM	PCM	PLM	LEAD	MOLD	AIR	BULK	DUST	WATER AND OTHER	SPORE TRAP	TAPE		SWAB		
20-694	1	Outdoors - parking lot	12/2 9:44 AM															
20-694	2	field blank	12/2 9:44 AM															
20-694	3	main office	12/2 9:53 AM															
20-694	4	room 200	12/2 10:00 AM															
20-694	5	room 104	12/2 10:08 AM															
20-694	6	gymnasium	12/2 10:18 AM															
20-694	7	room 112	12/2 10:27 AM															
20-694	8	room 223	12/2 10:37 AM															
20-694	9	room 215	12/2 10:45 AM															

Relinquished by: <u>Mikal Frater</u>	Signature: <u>Mikal Frater</u>	Date: <u>12/3/20</u>	Time: <u>3:00 PM</u>	Shipping Information <input type="checkbox"/> UPS <input checked="" type="checkbox"/> In-Person <input type="checkbox"/> Other <input type="checkbox"/> FedEx <input type="checkbox"/> Drop Box
Received by: <u>[Signature]</u>	Signature: <u>[Signature]</u>	Date: <u>12/3/20</u>	Time: <u>1520</u>	





# CERTIFICATE OF ANALYSIS

## ASTM D7391-09 Spore Trap Analysis Report

**Chain of Custody:** 285346  
**Client:** ATI, Inc.  
**Address:** 9220 Rumsey Road  
 Suite 100  
 Columbia, MD 21045  
**Attention:** Mikal Frater

**Job Name:** IAQ - PGCPS  
**Job Location:** Glenridge Elementary School  
**Job Number:** 20-694  
**P.O. Number:** Not Provided

**Date Submitted:** 03/01/2021  
**Person Submitting:** Mikal Frater  
**Date Analyzed:** 03/01/2021  
**Report Date:** 03/01/2021

### Spore Comparison Guide

The criteria for these specifications are outlined, but not limited to those listed, below. Final specifications may differ from the listed criteria for certain samples. AMA Analytical Services, Inc. reserves the right to make changes to these criteria at any time without notice.



Stachybotrys / Memnoniella, and Chaetomium	Other Spores* (Control Present)	Other Spores* (No Control)
1-4 Spores: Yellow 5-9 Spores: Orange 10+ Spores: Red	< 10 Spores: Insignificant (no color) <= Control's spore count: Green Between Control and 2x Control: Yellow Between 2x Control and 3x Control: Orange 3x+ Control: Red	< 10 Spores: Insignificant (no color) 10-20 Spores: Yellow 20-50 Spores: Orange 50+ Spores: Red

\*No evaluation is provided for the following spore types: Other, Other Colorless, and Unknown Fungi, and Misc

Interpretation of the data contained in this report is the sole responsibility of the client or the persons who conducted the field work. There are no federal or national standards for the number of fungal spores that may be present in the indoor environment. As a general rule and guideline that is widely accepted in the indoor air quality field, the numbers and types of spores that are present in the indoor environment should be comparable to those that are present outdoors at any given time. There will always be some mold spores present in "Normal" indoor environments. The purpose of sampling and counting spores is to help determine whether an abnormal condition exists within the indoor environment and if it does, to help pinpoint the area of contamination. Spore counts should not be used as the sole determining factor of mold contamination. There are many factors that can cause anomalies in the comparison of indoor and outdoor samples due to the dynamic nature of both of those environments.

This report is provided for informational and comparative purposes only and should not be relied upon for any other purpose. Sampling techniques, possible contaminants, unrepresentative samples and other similar or dissimilar factors may affect these results. With the statistical evaluation provided, as with all statistical comparisons and analyses, false-positive and false-negative results can and do occur. AMA Analytical Services, Inc. hereby disclaims any liability for any and all direct, indirect, punitive, incidental, special or consequential damages arising out of the use or interpretation of the data contained in, or any actions taken or omitted in reliance upon, this report.





# CERTIFICATE OF ANALYSIS

## ASTM D7391-09 Spore Trap Analysis Report

**Chain of Custody:** 285346  
**Client:** ATI, Inc.  
**Address:** 9220 Rumsey Road  
 Suite 100  
 Columbia, MD 21045  
**Attention:** Mikal Frater

**Job Name:** IAQ - PGCPS  
**Job Location:** Glenridge Elementary School  
**Job Number:** 20-694  
**P.O. Number:** Not Provided

**Date Submitted:** 03/01/2021  
**Person Submitting:** Mikal Frater  
**Date Analyzed:** 03/01/2021  
**Report Date:** 03/01/2021

### General Comments, Disclaimers, and Footnotes

**Analytical Method:** Sample are analyzed following the instructions and guidelines outlined in ASTM 7391-09.

**Sample Condition:** Acceptable: The sample was collected and delivered to the our location without disturbing the material on the sampling media.  
 Unacceptable: 1. The sample trace (TR) has been disturbed. 2. The sample was damaged or otherwise unsuitable for analysis.  
 0 = No particulate matter detected; 1 = >nd-~5% Particulate Loading; 2 = ~5%-25% Particulate Loading; 3 = ~25%- 75% Particulate Loading; 4 = ~75%-90% Particulate Loading; 5 = >90% Particulate Loading

**Spore Notes:** Based on their small size and very few distinguishing characteristics, Aspergillus and Penicillium cannot be differentiated by non-viable sampling methods. There are other types of spores whose morphology is similar to Aspergillus and Penicillium and cannot be differentiated by non-viable sampling methods. Examples of these similar spores are Acremonium, Paecilomyces, Wallemia, Trichoderma, Scopulariopsis, and Gliocladium.  
 Smuts, Periconia and Myxomycetes are three different types of genera that have similar morphological characteristics.  
 Bipolaris/Dreschlera/Helm: Bipolaris / Dreschlera / Helminthosporium are three different types of genera that have smiliar morphological characteristics.  
 Other Colorless represents all colorless spores that are non-distinctive and unidentifiable.  
 \*Hyphal Fragments: A portion of the mycelium that becomes separated from the remainder of the thallus (vegetative body), each of which has the capacity to grow and form new individuals. Results for hyphal fragments are in fragments/m3 and are not incorporated in the total spore concentration.  
 The droplet symbol (💧) refers to water-intrusion indicator spores. These fungal spores, when found on indoor air samples, can be an indication of moisture sources and resultant fungal growth that may be problematic.

**Quantification:** Analytical Sensitivity (A.S.): This is dependent on the volume of air collected, size of the trace, ocular diameter, and the amount of the trace that was analyzed.  
 The value of "Present" indicated in the Raw Count column represents the presence of this spore type during the preliminary exam at 400x. The Raw Count converts to a whole number if the spore type is encountered again during the 600x-1,000x enumeration. The sp/m3concentration will be reported as less than the analytical sensitivity if "Present" is reported in the Raw Count.  
 Results are reported to 3 significant figures. sp/m3: Spores per cubic meter.  
 Uncertainty: for raw count in the range of 0-50 the SR is 0.375, 51-100 SR=0.333, 101-200 SR=0.257, >200 SR=0.245  
 All results are to be considered preliminary and subject to change unless signed by the Technical Director or Deputy.  
**Analyst(s):** Tristan Ward

**Technical Director** Tristan Ward

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations, and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client.

# MOLD SPORE DESCRIPTIONS

## Ascospores

Ascospores are spores formed inside an ascus (asci-plural) or sac-like cell which is contained inside a fruiting body called an ascocarp or an ascoma (ascomata-plural). An ascus typically contains a definite number of ascospores, usually eight. Ascospores are unique in shape, size, and color as to the Genus/species they represent. These spores are specific to fungi classified as Ascomycetes. They are ubiquitous in nature. Many decay organic matter, others are plant or animal pathogens. They can grow indoors on damp materials. Release of ascospores are released by forcible ejection and dispersed by wind, water, animals and other agents. Health Effects: Depending on the Genera, Ascospores may be allergenic.

## Basidiospores

Basidiospores are reproductive spores produced by a group of fungi called basidiomycetes. This group includes the mushrooms, shelf fungi and various other macrofungi. Basidiospores serve as the main air (wind) dispersal units for the fungi and their release is dependent upon moisture. The structure of the spore complex can develop in various manners resulting in different appearances. It is often found growing in soil, decaying plant debris, compost piles and fruit rot. Indoors, it can be found on water damaged building materials (chipboard /OSB, plywood, wallpaper, and glue) as well as on food items (dried foods, cheeses, fruits, herbs, spices, cereals). Health effects: Some basidiospores may produce toxins and can act as allergens. They have not been reported to be pathogens.

## Cladosporium

Cladosporium is the most common indoor and outdoor mold. The spores are wind dispersed and are often extremely abundant in outdoor air. Many species are commonly found on living and dead plant material. Indoors, they may grow on surfaces with high moisture or high humidity levels such as damp window sills, poorly ventilated bathrooms and soiled refrigerators. It produces powdery or velvety olive-green to brown or black colonies. The conidia (spores) vary depending on the species and are formed in simple or branching chains with multi-attachment points. Health Effects: Cladosporium species are rarely pathogenic to humans, but have been reported to occasionally cause sinusitis and pulmonary infections as well as infections of the skin and toenails. The airborne spores are significant allergens, and in large amounts they may severely affect asthmatics and people with respiratory diseases.

## Other Colorless

- "Other Colorless" are all non-distinctive, unidentifiable, colorless spores seen on spore trap samples and include all the genera that do not have distinguishing morphology to belong to any of the other defined categories."

## Penicillium/Aspergillus Like

Penicillium and Aspergillus are ubiquitous, filamentous fungi that are found in soil, decaying plant debris, compost piles, and in the air. Indoors, spores are commonly found in house dust, in water-damaged buildings (wallpaper, wallpaper glue, decaying fabrics, moist chipboards, and behind paint) as well as fruit and grains. They are the most common fungal genera, worldwide. Both produce chains of spores that are small, round to oval, colorless or slightly pigmented, and smooth to rough walled. These spores are indistinguishable between the two as well as other genera, such as Gliocladium, Trichoderma, Paecilomyces, and Scopulariopsis. They differ as to their conidiophores or fruiting bodies. While, Aspergillus spores are produced from phialides supported on conidia heads or swollen vesicles, Penicillium spores are produced on finger-like projections. Depending on species, typical colonies of Aspergillus are initially white and later turn to either shades of green, yellow, orange, brown or black. Texture is usually velvety to cottony. Typical colonies of Penicillium, other than Penicillium marneffeii (yeast-like at 37oC), grow rapidly, white in color at first, later becoming bluish green with white borders with velvety to powdery textures depending on species. Some species produce radial patterns. Health Effects: Both Aspergillus and Penicillium are potential allergens. Several species of Aspergillus (A. flavus and A. parasiticus) produce aflatoxins or naturally occurring mycotoxins that are toxic and carcinogenic. These are found in contaminated foodstuff and are hazardous to consumers. Penicillium has only one known species that is pathogenic to humans (P. marneffeii) that causes lethal systemic infection (Penicilliosis) in immunocompromised individuals.

## Smuts/Periconia/Myxomycetes

Smuts, Periconia, and Myxomycetes spores are grouped together due to their similar round, brown morphology. Smuts are outdoor parasitic plant pathogens. They rarely grow indoors but may grow on host plants if appropriate conditions are present. They are parasitic plant pathogens. They can be found on cereal crops, grasses, flowering plants, weed, and other fungi. They can cause allergies. Periconia are found in soils, dead herbaceous stems and leaf spots, and grasses. They have wind dispersed dry spores. Their spores are abundant in the air but it is not known if they are allergenic. Myxomycetes are found on decaying logs, stumps and dead leaves. They have wind-dispersed dry spores and wet motile (amoebic phase) spores. During favorable conditions they move about like amoebae. They form dry airborne spores when conditions are unfavorable. They are rarely found indoors. Health Effects: They may cause Type 1 allergies (hay fever, asthma). No human infections have been reported.



**Appendix B: Instrument Calibration Records**

# Certificate of Calibration

(✓) Buck™ BioAire Pump Calibration Rotameter

( ) Buck™ BioSlide Pump Calibration Rotameter

Serial number: R15046

Date Calibrated: 11/12/2020

Calibration Due Date: 11/12/2021

## Flow Calibration

This is to certify that the rotameter listed above has been calibrated using a Buck Primary calibrator listed below which is calibrated according to A.P. Buck, Inc. calibration procedure APB-1, Ver. 6.2 and is traceable to the National Institute of Standards & Technology (N.I.S.T). A.P. Buck guarantees the accuracy of the rotameter to be within  $\pm 5\%$  of the actual flow rate.

AMBIENT CONDITIONS: Temperature  $74 \pm 3^{\circ}$  F Relative Humidity  $50 \pm 10\%$

Description	MFR.	Model	Serial #
Primary Calibrator	A.P. Buck Inc.	M30B	<input type="checkbox"/> A40020 <input checked="" type="checkbox"/> A40021

QA Approval By: *Moreni Mank*

Information contained in this document should not be reproduced in any form without the written consent of A.P. Buck, Inc. It is for reference only and cannot be used as a form of endorsement by any private or governmental regulatory body.

A.P. BUCK, INC.  
7101 Presidents Drive, Suite 110  
Orlando, FL 32809  
Phone: 407-851-8602  
Fax: 407-851-8910







# CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA  
Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 http://www.tsi.com

ENVIRONMENT CONDITIONS			MODEL	7575-X
TEMPERATURE	70.72 (21.5)	°F (°C)	SERIAL NUMBER	7575X1711006
RELATIVE HUMIDITY	39.0	%RH		
BAROMETRIC PRESSURE	29.15 (987.1)	inHg (hPa)		

<input checked="" type="checkbox"/> AS LEFT	<input checked="" type="checkbox"/> IN TOLERANCE
<input type="checkbox"/> AS FOUND	<input type="checkbox"/> OUT OF TOLERANCE

## - CALIBRATION VERIFICATION RESULTS -

THERMO COUPLE				SYSTEM PRESSURE01-02			Unit: °F (°C)
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	70.9 (21.6)	70.8 (21.6)	68.9-72.9 (20.5-22.7)				

BAROMETRIC PRESSURE				SYSTEM PRESSURE01-02			Unit: inHg (hPa)
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	29.22 (989.5)	29.23 (989.8)	28.64-29.80 (969.9-1009.1)				

TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data) and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO-9001:2015.

Measurement Variable	System ID	Last Cal.	Cal. Due	Measurement Variable	System ID	Last Cal.	Cal. Due
Temperature	E004626	02-14-20	02-28-21	Pressure	E005254	10-10-19	10-31-20
Pressure	E003982	01-24-20	07-31-20	DC Voltage	E003493	08-14-19	08-31-20

*Chao Yang*

June 15, 2020

CALIBRATED

DATE

Doc ID: CERT\_GEN\_WCC





# CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA  
 Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 http://www.tsi.com

ENVIRONMENT CONDITIONS			<b>MODEL</b>	<b>7575-X</b>
TEMPERATURE	70.68 (21.5)	°F (°C)	<b>SERIAL NUMBER</b>	<b>7575X1711006</b>
RELATIVE HUMIDITY	38.0	%RH		
BAROMETRIC PRESSURE	29.16 (987.5)	inHg (hPa)		

- |  |  |
|--|--|
| <input type="checkbox"/> AS LEFT             | <input checked="" type="checkbox"/> IN TOLERANCE |
| <input checked="" type="checkbox"/> AS FOUND | <input type="checkbox"/> OUT OF TOLERANCE        |

### - CALIBRATION VERIFICATION RESULTS -

THERMO COUPLE			SYSTEM PRESSURE01-02			Unit: °F (°C)	
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	70.8 (21.6)	71.1 (21.7)	68.8-72.8 (20.4-22.7)				

BAROMETRIC PRESSURE			SYSTEM PRESSURE01-02			Unit: inHg (hPa)	
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	29.22 (989.5)	29.17 (987.8)	28.64-29.80 (969.9-1009.1)				

*TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data) and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO-9001:2015.*

<u>Measurement Variable</u>	<u>System ID</u>	<u>Last Cal.</u>	<u>Cal. Due</u>	<u>Measurement Variable</u>	<u>System ID</u>	<u>Last Cal.</u>	<u>Cal. Due</u>
Temperature	E004626	02-14-20	02-28-21	Pressure	E005254	10-10-19	10-31-20
Pressure	E003982	01-24-20	07-31-20	DC Voltage	E003493	08-14-19	08-31-20

ChaoVang

---

VERIFIED

June 15, 2020

---

DATE

Doc ID CERT\_GEN\_WCC





# CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA  
Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 http://www.tsi.com

ENVIRONMENT CONDITIONS			<b>MODEL</b>	<b>982</b>
TEMPERATURE	74.0 (23.3)	°F (°C)	<b>SERIAL NUMBER</b>	<b>P17100007</b>
RELATIVE HUMIDITY	34	%RH		
BAROMETRIC PRESSURE	29.20 (988.8)	inHg (hPa)		

AS LEFT                       IN TOLERANCE  
 AS FOUND                       OUT OF TOLERANCE

## - CALIBRATION VERIFICATION RESULTS -

GAS CO <sub>2</sub> AS FOUND				SYSTEM G-101			Unit: ppm
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	0	0	0~50	4	3015.3	* 2902.7	2924.9~3105.8
2	499	458	449~549	5	5056	* 4859.6	4904.3~5207.7
3	1002	963	952~1052				

GAS CO AS FOUND				SYSTEM G-101			Unit: ppm
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	35.1	* 29.5	32.1~38.1	2	100.5	* 84.8	97.5~103.5

TEMPERATURE AS FOUND				SYSTEM T-101			Unit: °F (°C)
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	32.1 (0.0)	32.8 (0.4)	31.1~33.1 (-0.5~0.6)	2	140.02 (60.01)	* 141.31 (60.73)	139.02~141.02 (59.45~60.57)

HUMIDITY AS FOUND				SYSTEM H-102			Unit: %RH
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	10.0	10.4	7.0~13.0	4	70.0	67.1	67.0~73.0
2	30.0	29.3	27.0~33.0	5	90.01	* 85.88	87.01~93.01
3	50.0	48.5	47.0~53.0				

\*Indicates Out-of-Tolerance Condition

TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data) and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO-9001:2015.

Measurement Variable	System ID	Last Cal.	Cal. Due	Measurement Variable	System ID	Last Cal.	Cal. Due
5000 CO <sub>2</sub>	14A044095	04-06-20	04-06-25	200 CO	149886	04-30-20	03-24-28
N <sub>2</sub>	T-0608	05-19-20	05-19-28	Air	T17939	04-09-20	04-09-28
Flow	E003341	09-03-19	09-30-20	Flow	E003980	04-22-20	04-30-21
Flow	E003525	01-06-20	01-31-21	Flow	E003342	09-03-19	09-30-20
2000 C4H8	EB0054467	08-13-19	08-12-22	100 C4H8	CC507339	03-24-20	03-24-28
Temperature	E010657	02-14-20	02-28-21	Temperature	E010658	02-14-20	02-28-21
Temperature	E010655	01-21-20	01-31-21	Humidity	E003539	02-26-20	08-31-20

*Chimera Use*  
VERIFIED

June 15, 2020

DATE

Doc ID CERT\_GEN\_WCC





# CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA  
 Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 <http://www.tsi.com>

ENVIRONMENT CONDITIONS			<b>MODEL</b>	<b>982</b>
TEMPERATURE	70.41 (21.3)	°F (°C)	<b>SERIAL NUMBER</b>	<b>P17100007</b>
RELATIVE HUMIDITY	50.3	%RH		
BAROMETRIC PRESSURE	29.15 (987.1)	inHg (hPa)		

<input checked="" type="checkbox"/> AS LEFT	<input checked="" type="checkbox"/> IN TOLERANCE
<input type="checkbox"/> AS FOUND	<input type="checkbox"/> OUT OF TOLERANCE

## - CALIBRATION VERIFICATION RESULTS -

TEMPERATURE VERIFICATION				SYSTEM T-101				Unit: °F (°C)
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	22.1 (9.0)	31.9 (-0.1)	31.1~33.1 (-0.5~0.6)	2	140.0 (60.0)	140.5 (60.3)	139.0~141.0 (59.5~60.6)	

HUMIDITY VERIFICATION				SYSTEM H-102				Unit: %RH
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	10.0	9.0	7.8~12.2	4	70.0	69.5	67.8~72.2	
2	30.0	29.1	27.8~32.2	5	90.0	88.7	87.8~92.2	
3	50.0	49.6	47.8~52.2					

CO2 GAS VERIFICATION				SYSTEM G-101				Unit: ppm
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	0	0	0~50	4	3016	3012	2926~3107	
2	502	502	452~552	5	5056	5032	4904~5208	
3	1005	1019	955~1055					

CO GAS VERIFICATION				SYSTEM G-101				Unit: ppm
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	35	36	32~38	2	101	100	98~104	

*TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data) and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO-9001:2015.*

Measurement Variable	System ID	Last Cal.	Cal. Due	Measurement Variable	System ID	Last Cal.	Cal. Due
Temperature	E010657	02-14-20	02-28-21	Temperature	E010658	02-14-20	02-28-21
Temperature	E010655	01-21-20	01-31-21	Humidity	E003539	02-26-20	08-31-20
5000 CO2	14A044095	04-06-20	04-06-25	200 CO	149886	04-30-20	03-24-28
N2	T-0608	05-19-20	05-19-28	Air	117939	04-09-20	04-09-28
Flow	E003341	09-03-19	09-30-20	Flow	E003980	04-22-20	04-30-21
Flow	E003525	01-06-20	01-31-21	Flow	E003342	09-03-19	09-30-20
2000 C4H8	EB0054467	08-13-19	08-12-22	100 C4H8	CC507339	03-24-20	03-24-28

ChaoVang

CALIBRATED

June 16, 2020

DATE

D:\CHD-CERT\_GEN\_WCC