



Environmental Consultants and Engineers

1818 New York Avenue Suite 217  
Washington, DC 20002

[www.globalincusa.net](http://www.globalincusa.net)

March 1, 2021

Prince Georges County  
Environmental Safety Office  
13306 Old Marlboro Pike  
Upper Marlboro, MD 20772

Attention: Mr. Alex Baylor

RE: Indoor Air Quality Screening Report

Global Project Number: 20-064  
School: Marlton Elementary School

Dear Mr. Baylor,

On January 25, 2021, Global Inc.'s (GLOBAL) team of Industrial Hygienists under the supervision of Certified Industrial Hygienist, Dr. Channa Bambaradeniya, conducted an Indoor Air Quality Screening at Marlton Elementary School located at 8506 Old Colony Dr S, Upper Marlboro, MD 20772.

## Methodology

The IAQ evaluation included a visual assessment, sampling for non-viable mold spores in air, and measurement of comfort parameters (temperature, humidity, carbon dioxide, and carbon monoxide) in randomly selected representative locations within the building. GLOBAL's inspector conducted a walkthrough with Prince Georges County Public School (PGCPS) personnel present. Rooms were selected in a random manner throughout the building so as to prevent sampling bias.

During the visual assessment of representative locations, and when noted, GLOBAL documented those areas with suspected mold growth, water intrusions, and wet conditions that have the potential to lead to mold growth. GLOBAL also noted any unusual odors. At least one microbial air sample was collected for every 10,000 Square Feet (SF) of space in the building and the analytical results for the interior spaces were compared to an outdoor (ambient) sample collected on the same day.

Microbial samples (including a field blank for quality control) were delivered under strict chain-of-custody procedures were to Hayes Microbial Consulting - an AIHA EMPAT-certified laboratory in Midlothian, Virginia for analysis by microscopy. The sample chain-of-custody and laboratory report is attached.



Environmental Consultants and Engineers

1818 New York Avenue Suite 217  
Washington, DC 20002

[www.globalincusa.net](http://www.globalincusa.net)

## Observations

The general observations in the five indoor locations inspected are summarized in Table 1 below:

**Table 1: Observations**

Location	Observations
Room 9	No issues
Room 3	No issues
Gymnasium Stage	No issues
Room 22	No issues
Chambers 8B	No issues

## Comfort Parameter Measurements and Mold-in-Air Sample Results

The comfort parameter measurements and status of fungal ecology is summarized in Table 2 and Table 3.

### *Temperature*

The American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) have published recommendations for year-round acceptable temperatures in Standard 55-2016 (*Thermal Environmental Conditions for Human Occupancy*). The winter comfort range is 68 to 75°F and the summer comfort range is 73 to 79°F. It is important to note that ASHRAE standards are intended as a suggested guideline as opposed to a regulation. The indoor temperature readings of room 9, 3 and Gymnasium were below the ASHRAE Standard for winter.

### *Relative Humidity (RH)*

Relative humidity is a key factor for mold growth. Mold has the potential of growing on suitable surfaces with humidity levels above 60%. ASHRAE standard 62.1-2013 (*Ventilation for Acceptable Indoor Air Quality*) recommends a maximum indoor relative humidity of 65% to preclude the likelihood of condensation on cool surfaces encouraging mold growth. All the indoor relative humidity readings were below the maximum ASHRAE recommended level of 65%.

### *Carbon Monoxide*

Carbon monoxide (CO) is a colorless and odorless gas that is produced by the incomplete combustion of carbon-containing fuels. Oil, gasoline, diesel fuels, wood, coke, and coal are the major sources of CO. All registered CO concentrations were below the EPA National Ambient Air Quality Standard (NAAQS) of 9 ppm.



Environmental Consultants and Engineers

1818 New York Avenue Suite 217  
Washington, DC 20002

[www.globalincusa.net](http://www.globalincusa.net)

### ***Carbon Dioxide***

Under conditions of maximum occupancy, ASHRAE Standard 62.1-2013, Appendix C, infers that the acceptable carbon dioxide upper limit is the prevailing outdoor carbon dioxide concentration plus 700 parts per million (ppm). On January 25, 2021, the outdoor (ambient) carbon dioxide concentration was approximately 396 ppm so indoor concentrations should not exceed approximately 1096 ppm (700 + 396). All indoor carbon dioxide measurements were within the ASHRAE standards.

### ***Mold-in-Air Samples***

There are no definitive regulations or standardized guidelines for addressing airborne mold in an indoor setting. If building systems (ventilation, envelope) are functioning properly, the indoor fungal ecology profile should be consistent with what is encountered outdoors and the spore concentrations should be below the ambient levels.

The analytical results of indoor air samples collected from Chambers Room 8B on January 25, 2021 indicated elevated presence of *Aspergillus/Penicillium*. The horizontal surfaces of the above location were thoroughly re-cleaned, and air scrubbers with HEPA filters were operated for 24-36 hours. Subsequently, they were reinspected on February 20, 2021, and the analytical results of air samples collected indicated normal fungal ecology. Laboratory analytical results are attached at the end of this report.

**Table 2: Air Quality Results (Inspected on January 25, 2021)**

<b>Sample Location</b>	<b>Temp °F</b>	<b>RH%</b>	<b>CO ppm</b>	<b>CO2 ppm</b>	<b>Normal Fungal Ecology?</b>
<b>Standards</b>	<b>ASHRAE 68 to 75°F</b>	<b>ASHRAE &lt;65%</b>	<b>NAAQS &lt;9</b>	<b>ASHRAE 1093</b>	
Ambient	36.0	55.0	0	396	Yes
Room 9	60.8	42.0	0	424	Yes
Room 3	66.4	48.6	0	406	Yes
Gymnasium Stage	66.0	49.9	0	412	Yes
Room 22	68.3	46.9	0	407	Yes
Chambers 8B	71.8	34.8	0	412	No



Environmental Consultants and Engineers

1818 New York Avenue Suite 217  
Washington, DC 20002

www.globalincusa.net

Table 3: Air Quality Results (Inspected on February 20, 2021)

Sample Location	Temp °F	RH%	CO ppm	CO2 ppm	Normal Fungal Ecology?
Standards	ASHRAE 68 to 75°F	ASHRAE <65%	NAAQS <9	ASHRAE 1244	
Ambient	30.0	15.0	0	544	Yes
Chambers 8B	57.0	24.0	0	400	Yes

### Conclusions and Recommendations

The indoor temperature readings of room 9, room 3, and Gymnasium were below the ASHRAE Standard. The indoor temperature should be maintained at the ASHRAE recommended range for general comfort.

The indoor mold samples collected from Chambers room 8B indicate an elevated presence of *Aspergillus/Penicillium* during the screening performed on January 25, 2020, while the other mold sample was found to have a normal fungal ecology for an indoor environment. The Chambers Room 8B was thoroughly recleaned and resampled on February 20, 2021, and the analytical results indicated normal fungal ecology.

It has been our pleasure to conduct these IAQ Screening services for the Prince Georges County Public School system. If you have any questions, please feel free to contact us.

Regards,

Channa Bambaradeniya, Ph.D., CIH, CSP, CHMM  
Certified Industrial Hygienist  
Global, Inc.  
Mobile: 443-691-0455



Environmental Consultants and Engineers

1818 New York Avenue Suite 217  
Washington, DC 20002

[www.globalincusa.net](http://www.globalincusa.net)

## **ATTACHMENT I**

### **Air Sample Analytical Results and Chain-Of-Custody Form**

Analysis Report prepared for

## Global, Inc.

1818 New York Ave.  
Suite 217  
Washington, DC, 20002

Phone: (443) 691-0455

**BB203**  
Indoor Air Quality Assessment  
PGCPS Marilton ES

Collected: **January 25, 2021**  
Received: **January 27, 2021**  
Reported: **January 27, 2021**

We would like to thank you for trusting Hayes Microbial for your analytical needs!  
We received 7 samples by FedEx in good condition for this project on January 27th, 2021.

The results in this analysis pertain only to this job, collected on the stated date, and should not be used in the interpretation of any other job. This report may not be duplicated, except in full, without the written consent of Hayes Microbial Consulting, LLC..

This laboratory bears no responsibility for sample collection activities, analytical method limitations, or your use of the test results. Interpretation and use of test results are your responsibility. Any reference to health effects or interpretation of mold levels is strictly the opinion of Hayes Microbial. In no event, shall Hayes Microbial or any of its employees be liable for lost profits or any special, incidental or consequential damages arising out of the use of these test results.



Steve Hayes, BSMT(ASCP)  
Laboratory Director  
Hayes Microbial Consulting, LLC.



EPA Laboratory ID: VA01419



Lab ID: #188863



DPH License: #PH-0198

Sample Number	1	MES-0125-01			2	MES-0125-02			3	MES-0125-03			4	MES-0125-04		
Sample Name	Ambient Outdoors			Room 9			Room 3			Gym by Stage						
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter						
Reporting Limit	13 spores/m <sup>3</sup>			13 spores/m <sup>3</sup>			13 spores/m <sup>3</sup>			13 spores/m <sup>3</sup>						
Background	2			2			1			2						
Fragments	ND			ND			ND			27/m <sup>3</sup>						
Organism	Raw Count	Count / m <sup>3</sup>	% of Total	Raw Count	Count / m <sup>3</sup>	% of Total	Raw Count	Count / m <sup>3</sup>	% of Total	Raw Count	Count / m <sup>3</sup>	% of Total				
Alternaria																
Ascospores	5	67	41.7%	1	13	50.0%	1	13	100.0%	2	27	66.7%				
Aspergillus Penicillium																
Basidiospores	1	13	8.3%	1	13	50.0%				1	13	33.3%				
Bipolaris Drechslera																
Chaetomium																
Cladosporium	5	67	41.7%													
Curvularia																
Epicoccum																
Fusarium																
Memnoniella																
Myxomycetes	1	13	8.3%													
Pithomyces																
Stachybotrys																
Stemphylium																
Torula																
Ulocladium																
Total	12	160	100%	2	26	100%	1	13	100%	3	40	100%				

Water Damage Indicator      Common Allergen      Slightly Higher than Baseline      Significantly Higher than Baseline      Ratio Abnormality

Collected: Jan 25, 2021

Received: Jan 27, 2021

Reported: Jan 27, 2021



Project Analyst:  
Ramesh Poluri, PhD

*P. Ramesh*

Date:  
01 - 27 - 2021

Reviewed By:  
Steve Hayes, BSMT

*Stephen N. Hayes*

Date:  
01 - 27 - 2021

Sample Number	5	MES-0125-05			6	MES-0125-06			7	MES-0125-07					
Sample Name	<b>Room 22</b>			<b>Chambers Room 8B</b>			<b>Field Blank for the Day</b>								
Sample Volume	75.00 liter			75.00 liter			0.00 liter								
Reporting Limit	13 spores/m <sup>3</sup>			13 spores/m <sup>3</sup>			1 spore/m <sup>3</sup>								
Background	1			2			NBD								
Fragments	ND			13/m <sup>3</sup>			ND								
Organism	Raw Count	Count / m <sup>3</sup>	% of Total	Raw Count	Count / m <sup>3</sup>	% of Total	Raw Count	Count / m <sup>3</sup>	% of Total						
Alternaria															
Ascospores	1	13	100.0%												
Aspergillus Penicillium				480	6400	99.6%									
Basidiospores															
Bipolaris Drechslera															
Chaetomium															
Cladosporium															
Curvularia															
Epicoccum				1	13	<1%									
Fusarium															
Memnoniella															
Myxomycetes				1	13	<1%									
Pithomyces															
Stachybotrys															
Stemphylium															
Torula															
Ulocladium															
<b>Total</b>	<b>1</b>	<b>13</b>	<b>100%</b>	<b>482</b>	<b>6426</b>	<b>100%</b>	<b>ND</b>	<b>ND</b>							

Water Damage Indicator      Common Allergen      Slightly Higher than Baseline      Significantly Higher than Baseline      Ratio Abnormality



Collected: **Jan 25, 2021**      Received: **Jan 27, 2021**      Reported: **Jan 27, 2021**

Project Analyst: Ramesh Poluri, PhD *P. Ramesh*      Date: **01 - 27 - 2021**      Reviewed By: Steve Hayes, BSMT *Stephen N. Hayes*      Date: **01 - 27 - 2021**



**Spore Trap Information**

<b>Reporting Limit</b>	The Reporting Limit is the lowest number of spores that can be detected based on the total volume of the sample collected and the percentage of the slide that is counted. At Hayes Microbial, 100% of the slide is read so the LOD is based solely on the total volume. Raw spore counts that exceed 500 spores will be estimated.					
<b>Blanks</b>	Results have not been corrected for field or laboratory blanks.					
<b>Background</b>	<p>The Background is the amount of debris that is present in the sample. This debris consists of skin cells, dirt, dust, pollen, drywall dust and other organic and non-organic matter. As the background density increases, the likelihood of spores, especially small spores such as those of <i>Aspergillus</i> and <i>Penicillium</i> may be obscured. The background is rated on a scale of 1 to 5 and each level is determined as follows:</p> <p><b>NBD:</b> No background detected due to possible pump or cassette malfunction. Recollect sample. (Field Blanks will display NBD)</p> <p><b>1 :</b> &lt;5% of field occluded. No spores will be uncountable.</p> <p><b>2 :</b> 5-25% of field occluded.</p> <p><b>3 :</b> 25-75% of field occluded.</p> <p><b>4 :</b> 75-90% of field occluded.</p> <p><b>5 :</b> &gt;90% of field occluded. Suggested recollection of sample.</p>					
<b>Fragments</b>	Fragments are small pieces of fungal mycelium or spores. They are not identifiable as to type and when present in very large numbers, may indicate the presence of mold amplification.					
<b>Control Comparisons</b>	There are no national standards for the numbers of fungal spores that may be present in the indoor environment. As a general rule and guideline that is widely accepted in the indoor air quality field, the numbers and types of spores that are present in the indoor environment should not exceed those that are present outdoors at any given time. There will always be some mold spores present in "normal" indoor environments. The purpose of sampling and counting spores is to help determine whether an abnormal condition exists within the indoor environment and if it does, to help pinpoint the area of contamination. Spore counts should not be used as the sole determining factor of mold contamination. There are many factors that can cause anomalies in the comparison of indoor and outdoor samples due to the dynamic nature of both of those environments.					
<table border="1"> <tr><td>Water Damage Indicator</td></tr> <tr><td>Common Allergen</td></tr> <tr><td>Slightly Higher than Baseline</td></tr> <tr><td>Significantly Higher than Baseline</td></tr> <tr><td>Ratio Abnormality</td></tr> </table>	Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality	<p><b>Blue:</b> These molds are commonly seen in conditions of prolonged water intrusion and usually indicate a problem.</p> <p><b>Green:</b> Although all molds are potential allergens, these are the most common allergens that may be found indoors.</p> <p><b>Orange:</b> The spore count is slightly higher than the outside count and may or may not indicate a source of contamination.</p> <p><b>Red:</b> The spore count is significantly higher than the baseline count and probably indicates a source of contamination.</p> <p><b>Violet:</b> The types of spores found indoors should be similar to the ones that were identified in the baseline sample. Significant increases (more than 25%) in the ratio of a particular spore type may indicate the presence of abnormal levels of mold, even if the total number of spores of that type is lower in the indoor environment than it was outdoors.</p>
Water Damage Indicator						
Common Allergen						
Slightly Higher than Baseline						
Significantly Higher than Baseline						
Ratio Abnormality						
<b>Color Coding</b>	Fungi that are present in indoor samples at levels lower than 200 per cubic meter are not color coded on the report, unless they are one of the water damage indicators.					

Organism Descriptions

---

<b>Ascospores</b>	<b>Habitat:</b> A large group consisting of more than 3000 species of fungi. Common plant pathogens and outdoor numbers become very high following rain. Most of the genera are indistinguishable by spore trap analysis and are combined on the report.
	<b>Effects:</b> Health affects are poorly studied, but many are likely to be allergenic.

---

<b>Aspergillus Penicillium</b>	<b>Habitat:</b> The most common fungi isolated from the environment. Very common in soil and on decaying plant material. Are able to grow well indoors on a wide variety of substrates.
	<b>Effects:</b> This group contains common allergens and many can cause hypersensitivity pneumonitis. They may cause extrinsic asthma, and many are opportunistic pathogens. Many species produce mycotoxins which may be associated with disease in humans and other animals. Toxin production is dependent on the species, the food source, competition with other organisms, and other environmental conditions.

---

<b>Basidiospores</b>	<b>Habitat:</b> A common group of Fungi that includes the mushrooms and bracket fungi. They are saprophytes and plant pathogens. In wet conditions they can cause structural damage to buildings.
	<b>Effects:</b> Common allergens and are also associated with hypersensitivity pneumonitis.

---

<b>Cladosporium</b>	<b>Habitat:</b> One of the most common genera worldwide. Found in soil and plant debris and on the leaf surfaces of living plants. The outdoor numbers are lower in the winter and often relatively high in the summer, especially in high humidity. The outdoor numbers often spike in the late afternoon and evening. Indoors, it can be found growing on textiles, wood, sheetrock, moist window sills and in HVAC supply ducts.
	<b>Effects:</b> A common allergen, producing more than 10 allergenic antigens and a common cause of hypersensitivity pneumonitis.

---

<b>Epicoccum</b>	<b>Habitat:</b> It is found in soil and plant litter and is a plant pathogen. It can grow indoors on a variety of substrates, including paper and textiles and is commonly found on wet drywall.
	<b>Effects:</b> It is a common allergen. No cases of infection have been reported in humans.

---

<b>Myxomycetes</b>	<b>Habitat:</b> Found on decaying plant material and as a plant pathogen.
	<b>Effects:</b> Some allergenic properties reported, but generally pose no health concerns to humans.


---



Company: Global Inc  
 Address: 1818 New York Ave NE Suite 217  
Washington DC 20002

N

SHIP: FEDEX - BOX 50  
 DATE: 01-27-2021



Job Number: BB203	Job Name: <b>Indoor Air Quality Assessment- PGCPS MARLTON ES</b>	Mobile: 443-691-0455	Email: Channab@globalincusa.net
Collector: JUDI DARNELL		Note:	
Date Collected: 01/25/21			

Analysis Type	Analysis Description	Turnaround	Accepted Media Types	
Spore Trap	S	Identification & Enumeration of Fungal Spores	24 Hour	Air Cassettes, Impact Slides
	S+	Spore Trap Analysis with Dander, Fiber, and Pollen counts	24 Hour	Air Cassettes, Impact Slides
Direct ID	D	ID & Semi-Quantative Enumeration of spores and mycelium	24 Hour	Bio-Tape, Tape, Swab, Bulk, Agar Plate
	D+	Direct Analysis with Fully Quantitative spore count	24 Hour	Bio-Tape, Tape, Swab, Bulk, Agar Plate
Culture	C1	Identification & Enumeration of Mold only	7 Day	Air Plate, Agar Plate, Swab, Bulk
	C2	Identification & Enumeration of Bacteria only	4 Day	Air Plate, Agar Plate, Swab, Bulk
	C3	Identification & Enumeration of Mold and Bacteria	7 Day	Air Plate, Agar Plate, Swab, Bulk
	C5	Coliform Screen for Sewage Bacteria	2 Day	Agar Plate, Swab, Bulk
Particle	TPA	Total Particulate Analysis, ID & Count (Does Not Include Mold)	24 Hour	Air Cassettes, Impact Slides, Bio-Tape

#	Number	Sample	Analysis	Volume	Notes
1	MES-0125-01	AMBIENT-OUTDOORS	S	75L	
2	MES-0125-02	ROOM 9	S	75L	
3	MES-0125-03	ROOM 3	S	75L	
4	MES-0125-04	GYM BY STAGE	S	75L	
5	MES-0125-05	ROOM 22	S	75L	
6	MES-0125-06	CHAMBERS ROOM 8B	S	75L	
7	MES-0125-07	FIELD BLANK FOR THE DAY	S	75L	
8					
9					
10					
11					
12					
13					
14					
15					
16					

Released by: <b>Judi Darnell</b>	Date: <b>1/25/21</b>	Received By:	Date: <b>1-27-21</b>
----------------------------------	----------------------	--------------	----------------------

Analysis Report prepared for

## Global, Inc.

1818 New York Ave.  
Suite 217  
Washington, DC, 20002

Phone: (443) 691-0455

20-064  
IAQ Reinspection  
Marlton ES  
8506 Old Colony Dr., S  
Upper Marlboro, MD 20772

Collected: **February 20, 2021**  
Received: **March 1, 2021**  
Reported: **March 1, 2021**

We would like to thank you for trusting Hayes Microbial for your analytical needs!  
We received 2 samples by FedEx in good condition for this project on March 1st, 2021.

The results in this analysis pertain only to this job, collected on the stated date, and should not be used in the interpretation of any other job. This report may not be duplicated, except in full, without the written consent of Hayes Microbial Consulting, LLC..

This laboratory bears no responsibility for sample collection activities, analytical method limitations, or your use of the test results. Interpretation and use of test results are your responsibility. Any reference to health effects or interpretation of mold levels is strictly the opinion of Hayes Microbial. In no event, shall Hayes Microbial or any of its employees be liable for lost profits or any special, incidental or consequential damages arising out of the use of these test results.



Steve Hayes, BSMT(ASCP)  
Laboratory Director  
Hayes Microbial Consulting, LLC.



EPA Laboratory ID: VA01419



Lab ID: #188863



DPH License: #PH-0198

Sample Number	1 01			2 02				
Sample Name	Ambient			Chambers Room 8B				
Sample Volume	75.00 liter			75.00 liter				
Reporting Limit	13 spores/m <sup>3</sup>			13 spores/m <sup>3</sup>				
Background	2			2				
Fragments	ND			ND				
Organism	Raw Count	Count / m <sup>3</sup>	% of Total	Raw Count	Count / m <sup>3</sup>	% of Total		
Alternaria								
Ascospores	6	80	75.0%	1	13	50.0%		
Aspergillus Penicillium								
Basidiospores	2	27	25.0%	1	13	50.0%		
Bipolaris Drechslera								
Chaetomium								
Cladosporium								
Curvularia								
Epicoccum								
Fusarium								
Memnoniella								
Myxomycetes								
Pithomyces								
Stachybotrys								
Stemphylium								
Torula								
Ulocladium								
Total	8	107	100%	2	26	100%		

Water Damage Indicator      Common Allergen      Slightly Higher than Baseline      Significantly Higher than Baseline      Ratio Abnormality



Collected: Feb 20, 2021

Received: Mar 1, 2021

Reported: Mar 1, 2021

Project Analyst:  
Ramesh Poluri, PhD *P. Ramesh*

Date:  
**03 - 01 - 2021**

Reviewed By:  
Steve Hayes, BSMT *Stephen N. Hayes*

Date:  
**03 - 01 - 2021**

**Spore Trap Information**

<b>Reporting Limit</b>	The Reporting Limit is the lowest number of spores that can be detected based on the total volume of the sample collected and the percentage of the slide that is counted. At Hayes Microbial, 100% of the slide is read so the LOD is based solely on the total volume. Raw spore counts that exceed 500 spores will be estimated.										
<b>Blanks</b>	Results have not been corrected for field or laboratory blanks.										
<b>Background</b>	<p>The Background is the amount of debris that is present in the sample. This debris consists of skin cells, dirt, dust, pollen, drywall dust and other organic and non-organic matter. As the background density increases, the likelihood of spores, especially small spores such as those of Aspergillus and Penicillium may be obscured. The background is rated on a scale of 1 to 5 and each level is determined as follows:</p> <p><b>NBD:</b> No background detected due to possible pump or cassette malfunction. Recollect sample. (Field Blanks will display NBD)</p> <p><b>1 :</b> &lt;5% of field occluded. No spores will be uncountable.</p> <p><b>2 :</b> 5-25% of field occluded.</p> <p><b>3 :</b> 25-75% of field occluded.</p> <p><b>4 :</b> 75-90% of field occluded.</p> <p><b>5 :</b> &gt;90% of field occluded. Suggested recollection of sample.</p>										
<b>Fragments</b>	Fragments are small pieces of fungal mycelium or spores. They are not identifiable as to type and when present in very large numbers, may indicate the presence of mold amplification.										
<b>Control Comparisons</b>	There are no national standards for the numbers of fungal spores that may be present in the indoor environment. As a general rule and guideline that is widely accepted in the indoor air quality field, the numbers and types of spores that are present in the indoor environment should not exceed those that are present outdoors at any given time. There will always be some mold spores present in "normal" indoor environments. The purpose of sampling and counting spores is to help determine whether an abnormal condition exists within the indoor environment and if it does, to help pinpoint the area of contamination. Spore counts should not be used as the sole determining factor of mold contamination. There are many factors that can cause anomalies in the comparison of indoor and outdoor samples due to the dynamic nature of both of those environments.										
<table border="1"> <tr> <td style="background-color: #ADD8E6;">Water Damage Indicator</td> <td><b>Blue:</b> These molds are commonly seen in conditions of prolonged water intrusion and usually indicate a problem.</td> </tr> <tr> <td style="background-color: #90EE90;">Common Allergen</td> <td><b>Green:</b> Although all molds are potential allergens, these are the most common allergens that may be found indoors.</td> </tr> <tr> <td style="background-color: #FFDAB9;">Slightly Higher than Baseline</td> <td><b>Orange:</b> The spore count is slightly higher than the outside count and may or may not indicate a source of contamination.</td> </tr> <tr> <td style="background-color: #FFB6C1;">Significantly Higher than Baseline</td> <td><b>Red:</b> The spore count is significantly higher than the baseline count and probably indicates a source of contamination.</td> </tr> <tr> <td style="background-color: #DDA0DD;">Ratio Abnormality</td> <td><b>Violet:</b> The types of spores found indoors should be similar to the ones that were identified in the baseline sample. Significant increases (more than 25%) in the ratio of a particular spore type may indicate the presence of abnormal levels of mold, even if the total number of spores of that type is lower in the indoor environment than it was outdoors.</td> </tr> </table>	Water Damage Indicator	<b>Blue:</b> These molds are commonly seen in conditions of prolonged water intrusion and usually indicate a problem.	Common Allergen	<b>Green:</b> Although all molds are potential allergens, these are the most common allergens that may be found indoors.	Slightly Higher than Baseline	<b>Orange:</b> The spore count is slightly higher than the outside count and may or may not indicate a source of contamination.	Significantly Higher than Baseline	<b>Red:</b> The spore count is significantly higher than the baseline count and probably indicates a source of contamination.	Ratio Abnormality	<b>Violet:</b> The types of spores found indoors should be similar to the ones that were identified in the baseline sample. Significant increases (more than 25%) in the ratio of a particular spore type may indicate the presence of abnormal levels of mold, even if the total number of spores of that type is lower in the indoor environment than it was outdoors.	
Water Damage Indicator	<b>Blue:</b> These molds are commonly seen in conditions of prolonged water intrusion and usually indicate a problem.										
Common Allergen	<b>Green:</b> Although all molds are potential allergens, these are the most common allergens that may be found indoors.										
Slightly Higher than Baseline	<b>Orange:</b> The spore count is slightly higher than the outside count and may or may not indicate a source of contamination.										
Significantly Higher than Baseline	<b>Red:</b> The spore count is significantly higher than the baseline count and probably indicates a source of contamination.										
Ratio Abnormality	<b>Violet:</b> The types of spores found indoors should be similar to the ones that were identified in the baseline sample. Significant increases (more than 25%) in the ratio of a particular spore type may indicate the presence of abnormal levels of mold, even if the total number of spores of that type is lower in the indoor environment than it was outdoors.										
<b>Color Coding</b>	Fungi that are present in indoor samples at levels lower than 200 per cubic meter are not color coded on the report, unless they are one of the water damage indicators.										

**Organism Descriptions**

---

<b>Ascospores</b>	<b>Habitat:</b> A large group consisting of more than 3000 species of fungi. Common plant pathogens and outdoor numbers become very high following rain. Most of the genera are indistinguishable by spore trap analysis and are combined on the report.
	<b>Effects:</b> Health affects are poorly studied, but many are likely to be allergenic.

---

<b>Basidiospores</b>	<b>Habitat:</b> A common group of Fungi that includes the mushrooms and bracket fungi. They are saprophytes and plant pathogens. In wet conditions they can cause structural damage to buildings.
	<b>Effects:</b> Common allergens and are also associated with hypersensitivity pneumonitis.

---





Company: Global Inc  
 Address: 1818 New York Ave NE Suite 217  
Washington DC 20002

P

SHIP: FEDEX - BOX 50  
 DATE: 03-01-2021



Job Number: 20-064  
 Collector: Shane Prabuddha  
 Date Collected: 2/20/2021

Job Name: IAQ Reinspection  
 Marilton ES (8506 Old Colony Dr S,  
 Upper Marlboro, MD 20772)

Mobile: 443-691-0455  
 Email: Channab@globalincusa.net  
 Note:

Analysis Type	Analysis Description	Turnaround	Accepted Media Types
Spore Trap	S	24 Hour X	Air Cassettes, Impact Slides
	S+	24 Hour	Air Cassettes, Impact Slides
Direct ID	D	24 Hour	Bio-Tape, Tape, Swab, Bulk, Agar Plate
	D+	24 Hour	Bio-Tape, Tape, Swab, Bulk, Agar Plate
Culture	C1	7 Day	Air Plate, Agar Plate, Swab, Bulk
	C2	4 Day	Air Plate, Agar Plate, Swab, Bulk
	C3	7 Day	Air Plate, Agar Plate, Swab, Bulk
	C5	2 Day	Agar Plate, Swab, Bulk
Particle	TPA	24 Hour	Air Cassettes, Impact Slides, Bio-Tape

#	Number	Sample	Analysis	Volume	Notes
1	01	Ambient	S	75L	T: 30 RH: 15 CO2: 544 CO: 0
2	02	Chambers Room 8B	S	75L	T: 57 RH: 24 CO2: 400 CO: 0
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					

Released by: Shane Prabuddha Date: 02/20/2021 Received By: CEL Date: 3/1/21