

Radon Test Report

November 22, 2023

Batch #: 111623-3

Customer:

ATI Inc.
9220 Rumsey Road
Ste.100
Columbia MD 21045

Test Site:

Beacon Heights ES
6929 Furman Pkwy
Riverdale Park MD 21737

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: ATI Inc.

The Results are as follows:

Serial	Chamber	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SDJ608		SST	Kitchen Office	03-Nov-2023 12:35 PM	06-Nov-2023 6:39 AM	1.5
SDP221		SST	Room 13	03-Nov-2023 12:16 PM	06-Nov-2023 6:40 AM	1.0
SJP520		SST	Room 17	03-Nov-2023 12:11 PM	06-Nov-2023 6:41 AM	0.8
SJX316		SST	Boiler Room	03-Nov-2023 12:38 PM	06-Nov-2023 6:38 AM	1.8
SJX383		SST	Room 7	03-Nov-2023 12:24 PM	06-Nov-2023 6:42 AM	0.8
SLY985		SST	Room 4	03-Nov-2023 12:20 PM	06-Nov-2023 6:44 AM	0.4
SMF244		SST	Room 18	03-Nov-2023 12:07 PM	06-Nov-2023 6:44 AM	0.7
SMI327		SST	Office across Counselor	03-Nov-2023 12:30 PM	06-Nov-2023 6:43 AM	0.2
SMU748		SST	Stage	03-Nov-2023 12:33 PM	10-Nov-2023 1:53 PM	0.7
SNB851		SST	Room 8	03-Nov-2023 12:27 PM	06-Nov-2023 6:45 AM	0.7

Deployed By:

Retrieved By:

Analyzed By: Kimberly Cage 20SS034

Reader S/N: E0125 **Reader Calibration Due:** 8/2/2024

Conditions: Closed-Building Conditions Not Met

Mitigation: Unknown

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: Kimberly Cage **Date:** 22-Nov-2023