

Radon Test Report

November 09, 2023

Batch #: 110923-6

Customer:

ATI Inc.
9220 Rumsey Road
Ste.100
Columbia MD 21045

Test Site:

Charles Carroll MS
6130 Lamont Dr
New Carrollton MD 20184
County

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: ATI Inc.

The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SDM189	SST	R114	03-Nov-2023 1:31 PM	06-Nov-2023 6:56 AM	0.5
SDM317	SST	Dance Studio 2	03-Nov-2023 1:48 PM	06-Nov-2023 6:56 AM	1.0
SDM528	SST	Media Center	03-Nov-2023 1:09 PM	06-Nov-2023 6:58 AM	1.0
SDW119	SST	Excr Z ?	03-Nov-2023 1:13 PM	06-Nov-2023 7:00 AM	0.7
SDW125	SST	R101	03-Nov-2023 1:13 PM	06-Nov-2023 7:00 AM	0.8
SDW214	SST	Gym Office	03-Nov-2023 1:45 PM	06-Nov-2023 7:07 AM	1.7
SHH014	SST	Broadcast Studio	03-Nov-2023 1:06 PM	06-Nov-2023 7:02 AM	1.2
SKP693	SST	R107	03-Nov-2023 1:24 PM	06-Nov-2023 7:03 AM	1.1
SLL483	SST	Health Rm.	03-Nov-2023 1:40 PM	06-Nov-2023 7:06 AM	1.2
SLQ763	SST	Boiler Rm.	03-Nov-2023 1:19 PM	06-Nov-2023 7:03 AM	0.6
SLR303	SST	R111	03-Nov-2023 1:29 PM	06-Nov-2023 7:05 AM	1.5
SMA839	SST	R112	03-Nov-2023 1:36 PM	06-Nov-2023 7:07 AM	1.7
SMR043	SST	R102	03-Nov-2023 12:58 PM	06-Nov-2023 7:07 AM	0.6
SNA128	SST	R104	03-Nov-2023 1:17 PM	06-Nov-2023 7:08 AM	0.5
SNB430	SST	Storage	03-Nov-2023 1:01 PM	06-Nov-2023 7:08 AM	0.7

Deployed By:

Retrieved By:

Analyzed By: Kimberly Cage 20SS034

Reader S/N: E0125 **Reader Calibration Due:** 8/2/2024

Conditions: Closed-Building Conditions Not Met

Vents: Open

Mitigation: Unknown

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: Kimberly Cage

Date: 13-Nov-2023